

Electrical Cable Test Results and Analysis During Fire Exposure (ELECTRA-FIRE)

**A Consolidation of Three Major
Fire-Induced Circuit and Cable
Failure Experiments Performed
Between 2001 and 2011**

Draft Report for Comment

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents
U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250
2. The National Technical Information Service
Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: U.S. Nuclear Regulatory Commission
Office of Administration
Publications Branch
Washington, DC 20555-0001

E-mail: DISTRIBUTION.SERVICES@NRC.GOV

Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

Electrical Cable Test Results and Analysis During Fire Exposure (ELECTRA-FIRE)

A Consolidation of Three Major Fire-Induced Circuit and Cable Failure Experiments Performed Between 2001 and 2011

Draft Report for Comment

Manuscript Completed: April 2012

Date Published: June 2012

Prepared by:

G. Taylor¹, N. Melly¹, H. Woods¹, and T. Pennywell¹

T. Olivier² and C. Lopez²

¹NRC, Office of Nuclear Regulatory Research

²Sandia National Laboratories

Office of Nuclear Regulatory Research

COMMENTS ON DRAFT REPORT

Any interested party may submit comments on this report for consideration by NRC staff. Comments may be accompanied by additional relevant information or supporting data. Please specify the report number "NUREG-2128, draft" in your comments and send them to the following address by July 31, 2012:

Chief, Rulemaking and Directives Branch
U.S. Nuclear Regulatory Commission
Mail Stop TWB-05-B01
Washington, DC 20555-0001

Comments may be submitted electronically using the NRC's website:
<http://www.nrc.gov/public-involve/doc-comment/form.html>

For any questions about the material in this report, please contact:

Gabriel Taylor
Mail Stop CSB-4-A07M
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001
Phone: 301-251-7576
E-mail: gabriel.taylor@nrc.gov

Please be aware that any comments that you submit to the NRC will be considered a public record and entered into the Agencywide Document Access and Management System (ADAMS). Do not provide information you would not want to be publicly available.

ABSTRACT

Over the past 10 years, there have been three major test programs exploring realistic electrical functionality of electrical cables under fire conditions. The three programs were:

- The Electric Power Research Institute (EPRI) and the Nuclear Energy Institute (NEI), 2002
 - o Comprehensive research and test efforts undertaken jointly by EPRI and NEI to investigate, characterize, and quantify fire-induced circuit failures.

- NRC Cable Response to Live Fire (CAROLFIRE), 2008
 - o CAROLFIRE was started at the end of the EPRI/NEI test program. It provides an experimental basis for resolving five of the six items identified as “Bin 2” circuit configurations in Regulatory Issue Summary (RIS) 2004-003, “Risk-Informed Approach for Post-Fire Safe-Shutdown Circuit Inspections.”
 - o Improved fire modeling tools for the prediction of cable damage under fire conditions.

- NRC Direct Current Electrical Shorting in Response to Exposure Fire (DESIREE-FIRE), 2012
 - o Provides fire-induced cable failures modes and effects data for dc-powered control circuits.

Corresponding EPRI and U.S. Nuclear Regulatory Commission (NRC) technical reports document the test results; however, only the EPRI tests provided an evaluation of various parameters affecting the likelihood of cable failure modes. However, these evaluations were based on a limited set of test data (18 tests). Since then, NRC-sponsored testing has added several hundred data points on the electrical failure characteristics of electrical cable exposure to severe thermal conditions. Evaluating these and other parameters using all available test data would improve understanding of the effects of various parameters on cable failure modes.

During an electrical expert Phenomena Identification and Ranking Table (PIRT) meeting in 2011, it became apparent that having individual experts independently analyze the three data sets to derive conclusions to support the PIRT was inefficient and impractical. Thus, the NRC, with support from EPRI and Sandia National Laboratories (SNL), began a project to analyze and catalogue the whole experimental data set to allow the PIRT panel members to make responsible technical decisions. This report documents the background work that was done to analyze the data sets and provides the results in tabular and graphical formats. The objective of this report is to present the data in a factual and coherent format to allow the PIRT panel members to make their best informed decisions. As such, the data set as a whole was analyzed and the authors did not attempt to remove outliers, conduct any specific detailed statistical analysis, or perform other probabilistic methods to arrive at the conclusions in this report. The authors limited their interpretation of the results to report only factual test information.

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
ABSTRACT	iii
TABLE OF CONTENTS	v
LIST OF FIGURES	vii
LIST OF TABLES.....	xi
EXECUTIVE SUMMARY	xiii
ACKNOWLEDGEMENTS	xvii
ACRONYMS AND ABBREVIATIONS.....	xix
1. INTRODUCTION	1-1
1.1 Background	1-1
1.2 Objective	1-3
1.3 The Approach.....	1-3
1.4 Report Organization	1-8
2. INTRA-CABLE – ALTERNATING CURRENT CIRCUITS	2-1
2.1 ac data analysis approach.....	2-1
2.2 Conductor Count	2-5
2.3 Thermal Exposure Conditions	2-6
2.4 Cable Orientation	2-9
2.5 Raceway Routing	2-11
2.6 Raceway Fill	2-13
2.7 Insulation Type	2-15
2.8 Insulation Material	2-17
2.9 Insulation-Jacket Type Combinations.....	2-19
2.10 CPT Size	2-21
2.11 Circuit Grounding	2-23
2.12 Wiring Configuration	2-25
2.13 Conductor Size	2-26
2.14 Suppression Effects on ac Circuit Failures.....	2-28
2.15 ac Circuit Concurrence of Hot Shorts.....	2-31
3. INTER-CABLE – ALTERNATING CURRENT CIRCUITS	3-1
4. INTRA-CABLE – DIRECT CURRENT CIRCUITS	4-1
4.1 dc Data Analysis Approach	4-1
4.2 Conductor Count	4-13
4.3 Thermal Exposure Conditions	4-14
4.4 Raceway Routing	4-16
4.5 Cable Orientation	4-18
4.6 Raceway Fill	4-18
4.7 Insulation Type	4-23
4.8 Insulation Material	4-24
4.9 Insulation-Jacket Type Combinations.....	4-26
4.10 Wiring Configuration	4-28
4.11 Conductor Size	4-30
4.12 Circuit Type	4-32
4.13 Fuse Size	4-34

<u>Section</u>	<u>Page</u>
4.14	Cable Shielding4-35
4.15	dc concurrence of hot shorts4-37
5.	INTER-CABLE DIRECT CURRENT CIRCUITS.....5-1
5.1	Traditional Inter-Cable Failure Analysis for DESIREE-FIRE Results5-1
5.2	Penlight Tests – Ground Fault Equivalent Hot Short.....5-5
5.3	Intermediate-Scale Tests – Ground Fault Equivalent Hot Short.....5-6
6.	SUMMARY OF FINDINGS6-1
6.1	Alternating Current Test Results (EPRI/NEI, CAROLFIRE, DESIREE-FIRE)....6-1
6.2	Direct Current Test Results (DESIREE-FIRE).....6-3
6.3	Ground Equivalent Hot Shorts.....6-3
7.	CONCLUSIONS7-1
8.	REFERENCES8-1
APPENDIX A: Penlight Ground Fault Equivalent Inter-Cable Failure Mode Evaluation A-1	
APPENDIX B: Supplemental Information for the CAROLFIRE Reports, Including Additional Data Retrieval..... B-1	

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1-1	Examples Global Approach failure mode column plot.....	1-6
1-2	Box and whisker plot example.....	1-6
2-1	CAROLFIRE ac MOV circuit	2-3
2-2	Conductor count column plot, global approach, ac tests.....	2-5
2-3	Conductor count box plot, duration, ac tests	2-6
2-4	Intermediate-scale cable raceway location	2-7
2-5	Thermal exposure conditions column plot, global approach, ac tests.....	2-8
2-6	Thermal exposure conditions box plot, duration, ac tests	2-9
2-7	Cable orientation column plot, global approach, ac tests.....	2-10
2-8	Cable orientation box plot, duration, ac tests	2-11
2-9	Raceway routing column plot, global approach, ac tests	2-12
2-10	Raceway routing box plot, duration, ac tests.....	2-13
2-11	Cable bundle arrangements (3-, 4-, 6-, & 12-cable bundles)	2-13
2-12	Cable tray fill intermediate.....	2-13
2-13	Single layer cable fill.....	2-14
2-14	Raceway fill column plot, global approach, ac tests.....	2-14
2-15	Raceway fill box plot, duration, ac tests	2-15
2-16	Insulation type column plot, global approach, ac tests.....	2-16
2-17	Insulation type box plot, duration, ac tests	2-17
2-18	Insulation material column plot, global approach, ac tests.....	2-18
2-19	Insulation material box plot, duration, ac tests	2-19
2-20	Insulation-Jacket type column plot, global approach, ac test data	2-20
2-21	Insulation-Jacket type box plot, duration, ac test data	2-21
2-22	CPT size column plot, global approach, ac tests	2-22
2-23	CPT size box plot, duration, ac tests.....	2-23
2-24	Circuit grounding column plot, global approach, ac tests.....	2-24
2-25	Circuit grounding box plot, duration, ac tests	2-24
2-26	Wiring configuration column plot, global approach, ac tests	2-25
2-27	Wiring configuration box plot, duration, ac tests.....	2-26
2-28	Conductor size column plot, global approach, ac tests	2-27
2-29	Conductor size box plot, duration, ac tests	2-28
2-30	EPRI/NEI Test 3 voltage plot - water spray.....	2-29
2-31	EPRI/NEI Test 10 voltage response following water spray	2-30
2-32	(a) CAROLFIRE and (b) DESIREE-FIRE intermediate-scale exposure location designation.....	2-32
2-33	Concurrent hot shorts - location a - 4 cables.....	2-32
2-34	Concurrent hot shorts - location a - 2 cables.....	2-34
2-35	Concurrent hot shorts - upper hot gas layer - 4 cables	2-34
2-36	Concurrent hot shorts - upper hot gas layer - 2 cables	2-35
3-1	EPRI/NEI inter-cable test tray fill	3-1
3-2	CAROLFIRE inter-cable test tray fill.....	3-2
3-3	EPRI/NEI cable configuration.....	3-3

Figure		Page
4-1	Line drawing of the dc-SIM panel layout for a 1-inch coil circuit	4-2
4-2	Line drawing for the dc large coil circuit	4-4
4-3	Line drawing for dc MOV circuit	4-6
4-4	Line drawing for dc SOV circuit	4-7
4-5	Line drawing for dc SWGR 1 circuit	4-9
4-6	Line drawing for dc SWGR 2 circuit	4-10
4-7	Conductor count column plot, global approach, dc tests	4-13
4-8	Conductor Count box Plot, duration, dc tests	4-14
4-9	Thermal exposure conditions column plot, global approach, dc tests	4-15
4-10	Thermal exposure conditions box plot, Duration, dc tests	4-16
4-11	Raceway routing column plot, global approach, dc tests	4-17
4-12	Raceway routing box plot, duration, dc tests	4-17
4-13	Circuit cable orientation within the cable trays for single fill	4-18
4-14	Circuit cable orientation for filled trays	4-19
4-15	Circuit cable orientation for partitioned trays	4-20
4-16	Circuit cable orientation for specialized trays	4-21
4-17	Raceway fill column plot, global approach, dc tests	4-21
4-18	Raceway fill box plot, duration, dc tests	4-22
4-19	Insulation type column plot, global approach, dc tests	4-23
4-20	Insulation type box plot duration, dc tests	4-24
4-21	Insulation material column plot, global approach, dc tests	4-25
4-22	Insulation material box plot, duration, dc tests	4-26
4-23	Insulation-jacket type column plot, global approach, dc tests	4-27
4-24	Insulation-jacket type box plot, duration, dc tests	4-28
4-25	Wiring configuration column plot, global approach, dc tests	4-29
4-26	Wiring configuration box plot, duration, dc tests	4-30
4-27	Conductor size column plot, global approach, dc tests	4-31
4-28	Conductor size box plot, duration, dc tests	4-31
4-29	Circuit type column plot, global approach, dc tests	4-32
4-30	Circuit type box plot, duration, dc tests	4-33
4-31	Fuse size column plot, global approach, dc tests	4-34
4-32	Fuse size - duration - box plot, dc tests	4-35
4-33	Cable shielding column plot, global approach, dc tests	4-36
4-34	Cable shielding, duration box plot, dc tests	4-37
4-35	Time plot of concurrent hot shorts for DESIREE-FIRE intermediate-scale test #5	4-39
4-36	Plot of intermediate-scale test #5 for MOV and SOV cable locations	4-39
4-37	Concurrent hot shorts - test #6	4-40
4-38	Plot of intermediate-scale test #6 for 1-inch valve and switchgear cable locations	4-41
4-39	Concurrent hot shorts - test #8	4-42
4-40	Concurrent hot shorts - test #9	4-43
5-1	DESIREE-FIRE inter-cable configuration	5-1
5-2	DESIREE-FIRE inter-cable test results penlight #47	5-2
5-3	dcMOV schematic showing current summation used in identifying inter-cable shorting behavior	5-4

<u>Figure</u>	<u>Page</u>
5-4	Penlight cable tray typical loading, showing two electrically instrumented cables and a thermal response (temperature recording) cable located in the center.5-5
5-5	Intermediate-scale test preliminary 1 cable loading configuration.....5-7
5-6	Intermediate-scale test preliminary 2 cable loading configuration.....5-8
5-7	Intermediate-scale test preliminary 2 – inter-cable shorting between SOV-2 and MOV-25-9
5-8	Intermediate-scale test 1 cable loading configuration5-10
5-9	Outstanding current hot shorting for Intermediate-Scale Test #1 between 1-inch valve, large coil, and MOV-1 circuits5-11
5-10	Intermediate-scale test 2 cable loading.....5-12
5-11	Outstanding current shorting in intermediate-scale test #2, between SOV-2 and MOV-25-13
5-12	Intermediate-scale test 3 cable loading.....5-14
5-13	Outstanding current shorting in intermediate-scale test #3,between SOV-2 and SWGR-T5-15
5-14	Outstanding current shorting in intermediate-scale test #3, between 1 inch valve and SWGR-T5-15
5-15	Intermediate-scale test 4 cable loading.....5-16
5-16	Intermediate-scale test 5 cable arrangement.....5-17
5-17	Outstanding current shorting in intermediate-scale test #5, between SOV-1 and SWGR-T5-18
5-18	Intermediate-scale test 6 cable arrangement.....5-19
5-19	Intermediate-scale test 7 cable arrangement.....5-20
5-20	Intermediate-scale test 8 cable arrangement.....5-21
5-21	Outstanding current shorting in intermediate-scale test #8, between MOV-1 and Lg Coil.....5-22
5-22	Intermediate-scale test 9 cable arrangement.....5-23
5-23	Intermediate-scale test 10 cable loading.....5-24
5-24	Intermediate-scale test 11 cable loading.....5-25
5-25	Intermediate-scale test 11 current summation5-26
5-26	Intermediate-scale test 12 cable loading.....5-27
5-27	Intermediate-scale test 12 current summation plot5-28
5-28	Ground fault detection voltage response for second large coil SA.....5-30
5-29	Intermediate-scale test contingency A cable loading configuration.....5-30

LIST OF TABLES

<u>Table</u>		<u>Page</u>
1-1	Example of failure mode table.....	1-5
2-1	ac threshold values used for MOV hot short & spurious operation determinations.....	2-1
2-2	CAROLFIRE ac MOV circuit path configuration.....	2-3
2-3	Conductor count, global approach, ac tests.....	2-5
2-4	Conductor count, duration data, ac tests.....	2-6
2-5	Thermal exposure conditions, global approach, ac tests.....	2-7
2-6	Thermal exposure conditions, duration data, ac tests.....	2-8
2-7	Cable orientation, global approach, ac tests.....	2-9
2-8	Cable orientation, duration data, ac tests.....	2-10
2-9	Raceway routing, global approach, ac tests.....	2-11
2-10	Raceway routing, duration data, ac tests.....	2-12
2-11	Raceway fill, global approach, ac tests.....	2-14
2-12	Raceway fill, duration data, ac tests.....	2-15
2-13	Breakdown of insulation material by type, ac tests.....	2-16
2-14	Insulation type, global approach, ac tests.....	2-16
2-15	Insulation type, duration data, ac tests.....	2-16
2-16	Insulation material, global approach, ac tests.....	2-17
2-17	Insulation material, hot short only, duration data, hot shorts, ac tests.....	2-18
2-18	Insulation material spurious operation only, duration data, ac tests.....	2-19
2-19	Insulation-jacket type, global approach, ac tests.....	2-20
2-20	Insulation-Jacket type, duration data, ac tests.....	2-20
2-21	Test project CPT size.....	2-21
2-22	CPT size, global approach, ac tests.....	2-22
2-23	CPT size, duration data, ac tests.....	2-22
2-24	Circuit grounding, global approach, ac tests.....	2-23
2-25	Circuit grounding, duration data, ac tests.....	2-24
2-26	Wiring configurations.....	2-25
2-27	Wiring configuration, global approach, ac tests.....	2-25
2-28	Wiring configuration, duration data, ac tests.....	2-26
2-29	Conductor size, global approach.....	2-27
2-30	Conductor size, duration data, ac tests.....	2-27
2-31	Concurrent spurious operations – test location A.....	2-33
2-32	Concurrent spurious operations – upper hot gas layer.....	2-35
3-1	EPRI/NEI inter-cable failure characteristics.....	3-3
3-2	CAROLFIRE ac inter-cable failure characteristics.....	3-4
4-1	Analysis Logic for 1-in Valve Penlight Tests.....	4-3
4-2	Analysis Logic for 1-in Valve Intermediate-Scale Tests.....	4-3
4-3	Analysis Logic for Large Coil Penlight and Intermediate-Scale Tests.....	4-5
4-4	Analysis Logic for MOV Penlight and Intermediate-Scale Tests.....	4-6
4-5	Analysis Logic for SOV Penlight and Intermediate-Scale Tests.....	4-8
4-6	Analysis Logic for SWGR Penlight Tests and Intermediate-Scale.....	4-11
4-7	Analysis Logic for SWGR Intermediate Scale Tests 1, 3, 5, 6, 7, 8, 9, 10, Cont 1, and Cont 2.....	4-12

<u>Table</u>	<u>Page</u>
4-8	Conductor count, global approach, dc tests4-13
4-9	Conductor count, duration data, dc tests.....4-14
4-10	Thermal exposure conditions, global approach, dc tests4-15
4-11	Thermal exposure conditions, duration data, dc tests4-16
4-12	Raceway routing, global approach, dc tests.....4-16
4-13	Raceway routing, duration data, dc tests4-17
4-14	Raceway fill, global approach, dc tests4-21
4-15	Raceway fill, duration data, dc tests.....4-22
4-16	Breakdown of insulation material by type, dc tests4-23
4-17	Insulation type, global approach, dc tests4-23
4-18	Insulation type, duration data, dc tests.....4-24
4-19	Insulation material, global approach, dc tests4-25
4-20	Insulation material, duration data, dc tests4-25
4-21	Insulation-jacket type, global approach, dc tests.....4-26
4-22	Insulation-jacket type, duration data, dc tests4-27
4-23	dc test data wiring configurations4-28
4-24	Wiring configuration, global approach, dc tests.....4-29
4-25	Wiring configuration, duration data, dc tests4-29
4-26	Conductor size, global approach, dc tests4-30
4-27	Conductor size, duration data, dc tests4-31
4-28	Circuit type, global approach, dc Tests4-32
4-29	Circuit type hot short only, duration data, dc tests4-33
4-30	Circuit type spurious operation only, duration data - dc tests.....4-33
4-31	Fuse size, global approach, dc tests4-34
4-32	Fuse size, duration data, dc tests.....4-35
4-33	Cable shielding, global approach, dc tests.....4-35
4-34	Cable shielding, duration data, dc tests4-36
4-35	Listing of concurrent spurious operations during intermediate-scale dc testing4-38
5-1	Results of inter-cable shorting during Penlight DESIREE-Fire tests5-6
5-2	Intermediate-Scale Preliminary Test #15-7
5-3	Intermediate-Scale Preliminary Test #25-8
5-4	Intermediate-Scale Test #15-10
5-5	Intermediate-Scale Test #25-12
5-6	Intermediate-Scale Test #35-14
5-7	Intermediate-Scale Test #45-16
5-8	Intermediate-Scale Test #55-17
5-9	Intermediate-Scale Test #65-19
5-10	Intermediate-Scale Test #75-20
5-11	Intermediate-Scale Test #85-21
5-12	Intermediate-Scale Test #95-23
5-13	Intermediate-Scale Test #105-24
5-14	Intermediate-Scale Test #115-26
5-15	Intermediate-Scale Test #125-29
5-16	Intermediate-Scale Contingency Test #A.....5-31
5-17	Intermediate-Scale Contingency Test #B.....5-31
5-18	Summary of initial failure mode for inter-cable test circuits5-31

EXECUTIVE SUMMARY

Background

This report documents an analysis of the test data from three major test series which evaluated cable electrical performance under severe thermal (fire exposure) conditions. The objective of this report is to support an electrical expert panel decision making in a Phenomena Identification and Ranking Table (PIRT) exercise on fire-induced effects of electrical cable. The PIRT is an effective tool for providing an expert assessment of safety-relevant fire-induced circuit damage phenomena, and for assessing the U.S. Nuclear Regulatory Commission's (NRC's) research and development needs. This report supports the PIRT by providing an analysis of test data in an objective and factual manner to support the panel's discussion of parameters affecting the failure modes of electrical cables under fire-induced damaging conditions. The contents of this report were discussed during the electrical expert PIRT panel meetings.

NRC regulatory requirements, guidance, and staff technical positions regarding post-fire safe-shutdown are contained in various NRC documents. One objective of the fire protection requirements and guidance is to provide reasonable assurance that fire-induced failure of associated circuits that could prevent the operation, or cause maloperation, of equipment necessary to achieve and maintain post-fire safe-shutdown will not occur. In the late 1990s the NRC began to receive a series of licensee event reports (LERs) identifying plant-specific problems related to potential fire-induced electrical circuit failures that could prevent operation or cause maloperation of equipment necessary to achieve and maintain hot shutdown.

The NRC determined that the issue should be treated generically and contracted with Brookhaven National Laboratory (BNL) to develop a post-fire safe-shutdown analysis letter report (ML023430533) while at the same time the industry (under the direction of the Nuclear Energy Institute (NEI)) performed a series of cable functionality fire tests to be used in NEI 00-01, "Guidance for Post-Fire Safe-Shutdown Analysis" (ML023010376). These EPRI/NEI (Electric Power Research Institute) tests are the first set of test data used in the analysis for this report. An expert panel reviewed the results of the NEI testing and documented their insights on fire-induced failures of electrical cables in EPRI Technical Report 1006961, "Spurious Operation of Electrical Circuits Due to Cable Fires: Results of an Expert Elicitation," dated May 2002.

In February 2003, the NRC facilitated a public workshop primarily driven by the new EPRI/NEI report to exchange information for identifying circuit configurations fitting into the following three bins:

- Bin 1 – the most risk-significant associated circuit configurations
- Bin 2 – other associated circuit configurations that require further research
- Bin 3 – low-risk-significant associated circuit configurations

The outcome of the facilitated workshop was the issuance of Regulatory Issue Summary 2004-03, "Risk-Informed Approach for Post-Fire Safe-Shutdown Associated Circuit Inspections." Of interest to the research community were "Bin 2" items that required additional data as a basis for either including or excluding these configurations from the inspection procedures. The basis for the Bin 2 items was subsequently provided by an NRC-sponsored testing program conducted by Sandia National Laboratories, referred to as the "Cable Response to Live Fire

(CAROLFIRE)” project. This project provides the second major testing data set to be used in this report. The results of the CAROLFIRE project are documented in NUREG/CR-6931, Volumes 1 - 3.

Concurrent with the CAROLFIRE testing, a nuclear utility conducted its own fire-induced circuit failure testing on an armored cable that is used extensively in its plants. The results of this testing, although proprietary, established that control circuits under direct current (dc) power may fail differently than those tested previously in the CAROLFIRE and EPRI/NEI tests, which were powered solely by alternating current (ac) configurations. As a result of these different failure characteristics and the large number of risk-significant control circuits powered using dc, the NRC sponsored a confirmatory testing project to evaluate the risks and the failure characteristics of dc-powered control circuits. This testing has become known as “Direct Electrical Shorting In Response to Exposure Fire (DESIREE-FIRE),” and is the third major set of experimental data that will be used in this report.

Analysis Overview

The general purpose of the analysis is to evaluate the entire data set to identify parameters that may influence fire-induced failure modes. The analysis conducted in this report attempts to present the experimental data in a factual and clear format to allow for the identification of any influencing factors. The majority of the data is used to evaluate influencing parameters for intra-cable faults (i.e., fire-induced cable damage that results in the failure of conductors within a cable). A small fraction of the data has applicable information regarding inter-cable (cable-to-cable) interactions; however, the minimal data set limits the effectiveness of using a systematic approach to evaluate the test results for inter-cable interactions. Important parameters of the inter-cable data are simply presented instead, and the reader is left to decide how to use this information.

This report documents the intra-cable results using a substantial number of tables and graphical techniques. Graphical tools help to gain insights on the data set related to testing assumptions, relationship identification, and outlier detection. Our use of graphical tools relies on column plots to present the failure mode likelihood data (i.e, fuse clears, hot shorts, spurious operations) and box plots to present the hot short duration data. Presenting the consolidated test information in tabular and graphical forms aided in the determination of any trends in the data. General conclusions are made, and any potential causes are identified.

Conclusions

The data consolidation and analysis documented in this report identify several important fire-induced circuit phenomena. The systematic review of the ac and dc data has identified raceway fill, thermal exposure conditions, fuse size, circuit type, cable construction, and raceway routing as parameters that can influence the likelihood of experiencing a specific intra-cable failure mode and/or influence the length of intra-cable fire-induced hot short duration. This analysis has also identified areas in the data set where additional information would be beneficial to better understand how variations in parameters affect the circuit response under severe fire conditions.

Information pertaining to fire-induced inter-cable (cable to cable) failure data is sparse at best; however, the available data on this type of failure is presented for both ac and dc circuits. The

results show that although the likelihood of experiencing these failures is lower than it is for intra-cable, there are several cases where inter-cable hot shorts were experienced. Most of this data comes from the CAROLFIRE and EPRI/NEI test data sets.

The DESIREE-FIRE test data has revealed a newly observed failure mode in which multiple shorts to ground (from ungrounded systems) cause spurious operation in a circuit. This failure mode has been identified as “ground fault equivalent hot short,” and is the only inter-cable failure mode observed in the DESIREE-FIRE testing program. The only cable-to-cable shorts observed in the dc testing occurred through the ground plane. This unique failure mode may require some industry attention for circuits routed in dedicated conduits. Depending on the physical configurations in the plants, there may be some scenarios where safety significant electrical cables routed in dedicated conduits may be damaged by a severe fire, and, depending on the types of cables in the area, the ground fault equivalent hot short may be capable of causing hot short-induced spurious operations for a specific circuit.

ACKNOWLEDGEMENTS

The authors would like to offer their thanks and appreciation to the many individuals who provided support and comments during the development of this report. First we acknowledge the contributions of the NRC-RES/EPRI electrical expert Phenomena Identification and Ranking Table (PIRT) panel members. Their contributions and review resulted in a higher quality product that will help its readers to make informed decisions, both now and in the future. The electrical PIRT panel members include:

- Harold Barrett
- Robert Daley
- Steven Nowlen
- Gabriel Taylor
- David Crane
- Daniel Funk
- Thomas Gorman
- Andy Ratchford

Rick Wachowiak of EPRI also made numerous contributions that improved this report and provided an added level of insight, and also facilitated this work via the NRC-RES/EPRI Memorandum of Understanding (MOU) Addendum to Fire Risk. Working with EPRI under the MOU collaborative research agreement has allowed for the use of the EPRI fire-induced test data set, which has greatly supplemented the amount of data related to fire-induced cable failure phenomena.

The authors would also like to thank the individuals at Sandia National Laboratories (SNL) who performed and documented the testing and answered numerous questions during the analysis of the data and the development of this report.

The authors would like to thank Mark Henry Salley for supporting the development of this report and providing the resources needed to complete this effort. The authors are also grateful for the individuals at the NRC who worked on this report, and would like to extend their gratitude specifically to Mollie Semmes and H. Roy Woods.

ACRONYMS AND ABBREVIATIONS

ac	alternating current
ADAMS	Agencywide Document and Access Management System
AT	active target
AWG	American Wire Gauge
BNL	Brookhaven National Laboratories
/C	conductor
CAROLFIRE	Cable Response to Live Fire
CPT	control power transformer
CSPE	chlorosulfonated polyethylene
DAQ	Data Acquisition System
dc	direct current
DESIREE-FIRE	Direct Current Electrical Shorting in Response to Exposure Fire
EPR	ethylene propylene rubber
EPRI	Electric Power Research Institute
FR-Kerite	flame-retardant kerite™
HGL	hot gas layer
IN	Information Notice
IR	insulation resistance
IRMS	insulation resistance measurement system
IT	intermediate-scale test
LER	Licensee Event Report
MOV	motor-operated valve
NEC	National Electric Code
NEI	Nuclear Energy Institute
NFPA	National Fire Protection Association
NPP	nuclear power plant
NRC	Nuclear Regulatory Commission
NRR	Office of Nuclear Reactor Regulation
PE	polyethylene
PIRT	Phenomena Identification and Ranking Table
PRA	probabilistic risk assessment
PT	passive target
PVC	polyvinyl chloride
RES	Office of Nuclear Regulatory Research
SA	spurious operation

SCDU	surrogate circuit diagnostic unit
SNL	Sandia National Laboratories
SOV	solenoid-operated valve
SR	silicone rubber
SR-V	silicone rubber vitalink
SWGR	switchgear
TEF	Tefzel™
TP	thermoplastic
TS	thermoset
VA	volt-amp
XLPE	cross-linked polyethylene
XLPO	cross-linked polyolefin

1. INTRODUCTION

1.1 Background

In 1997, U.S. Nuclear Regulatory Commission (NRC) staff began to notice that an increasing number of licensee event reports (LERs) were identifying plant-specific problems related to potential fire-induced electrical circuit failures. These problems were documented in Information Notice (IN) 99-17, "Problems Associated with Post-Fire Safe-Shutdown Circuit Analysis." The NRC determined that this issue should be treated generically and began working with stakeholders to understand the issue.

The NRC contracted with Brookhaven National Laboratories (BNL) to develop a post-fire safe-shutdown analysis letter report (Agencywide Document Access and Management System (ADAMS) Accession No. ML023430533). Meanwhile, the nuclear industry, working with the Electric Power Research Institute (EPRI) under the direction of the Nuclear Energy Institute (NEI), performed a series of cable functionality fire tests to better understand the failure modes of cables and circuits under severe fire conditions. Following the completion of the NEI testing, the NRC hosted a facilitated public workshop¹ in Rockville, MD to discuss and gather stakeholder input on a proposed risk-informed post-fire safe-shutdown circuit analysis inspection. The workshop grouped circuit issues into three bins. Bin 1 contained the most risk-significant associated circuit configurations, Bin 2 included configurations that required additional research before a risk-significance determination could be made, and Bin 3 contained low-risk-significant associated circuits of concern. Bin 2 items included:

- A. Inter-cable shorting for thermoset cables
- B. Inter-cable shorting between thermoplastic and thermoset cables
- C. Configurations requiring three or more cable failures
- D. Multiple spurious operations in control circuits with properly sized control power transformers (CPTs)
- E. Fire-induced hot shorts that must last more than 20 minutes to impair a plant's ability to achieve hot shutdown
- F. Cold shutdown circuits

To provide the needed information to disposition the Bin 2 items into either of the other two bins, following the EPRI/NEI testing, the NRC sponsored a testing project at Sandia National Laboratories (SNL). The SNL project was entitled "Cable Response to Live Fire (CAROLFIRE)," and it provided enough data on five of the six Bin 2 circuit configurations that a determination of risk-significance could be made. Test data was not required to resolve RIS 2004-03, Bin 2, Item F. CAROLFIRE also provided data that resulted in the development of a better predictive model for cable thermal response in deterministic fire models.

Around the same time that the CAROLFIRE testing was being conducted, Duke Energy Corporation, a U.S. nuclear utility, performed its own fire-induced circuit failure testing on a unique armor-type cable used extensively in its plants. Although the test results from this program are proprietary, the NRC was able to witness these tests and gain the unique insights of the testing.

¹ The facilitated public workshop was an open forum meeting between the NRC staff and its stakeholders where the discussion was facilitated by an independent third party.

The results of the Duke testing indicated that risk-significant circuits operating on direct current (dc) may experience unique failure modes when compared to alternating current (ac) circuits. The NRC and the industry also experienced difficulties in developing methods and conditional probabilities for dc circuits based solely on the results of ac testing. To evaluate these concerns, the NRC sponsored a confirmatory testing project with SNL to evaluate the risks associated with ungrounded dc control circuits exposed to severe fire conditions. This project was code-named “Direct Current Electrical Shorting In Response to Exposure Fire (DESIREE-FIRE).” The dc testing identified three unique failure characteristics of dc control circuits. First, the physical cable failures were more energetic than they were in the ac tests, with sparks and electrical arcing readily visible to the test engineer. Second, open circuits were noted to occur as the first failure mode. Third, fuse sizing played a role in the duration of the hot short failures. In some cases the hot short durations lasted for longer than 20 minutes.

It is important to note that one additional testing program was completed to specifically evaluate the thermal failure temperature threshold of a unique cable insulation material manufactured by Kerite. This unique insulation material, “Kerite-FR” has shown poor insulation resistance characteristics at elevated temperature in past testing. As such, the NRC guidance indicated using a generic thermoplastic failure threshold when analyzing the Kerite-FR performance, instead of the higher temperature failure threshold for thermoset materials. Chemically Kerite-FR is a thermoset material. However it also exhibits thermoplastic properties such as self healing. Via its collaborative research agreement under the Memorandum of Understanding with EPRI, the NRC was able to obtain sample of 1970’s vintage Kerite-FR cables. Because of its unique construction having insulation thicknesses much greater than typically electrical cables found in U.S nuclear power plants, the results from this fourth testing project have not been included in this report or analysis. A limited amount of data on Kerite-FR cables obtained from the DESIREE-FIRE project were the limit of the Kerite-FR data evaluated here. The results and conclusions from the Kerite-FR test program can be found in a separate report, NUREG/CR-7102, “Kerite Analysis in Thermal Environment of FIRE (KATE-Fire): Test Results.”

Following the completion of this testing, the NRC (in collaboration with EPRI) convened a panel of electrical experts with a background in nuclear and fire protection engineering to evaluate the various parameters that affect fire-induced cable failures. This electrical expert Phenomena Identification and Ranking Table (PIRT) panel experienced difficulties in making informed decisions due to the massive amount of test data on which to base its decisions. As a result, the NRC began an effort among its staff and the staff at SNL to systematically evaluate and present the experimental data in a clearer format to assist the PIRT panel in making informed decisions. This report documents that effort.

1.2 Objective

There have been numerous testing projects aimed at evaluating the fault modes of electrical cables and circuits exposed to severe fire conditions. Only one of these projects thoroughly evaluated specific aspects of a small number of the test results. The objective of this report is to provide a simplistic presentation of all of the available test data, using various circuit parameters to identify any correlations among fault modes and any correlations among hot short duration. The core set of parameters selected by the PIRT panel for comparison of the intra-cable results includes:

- Conductor Count
- Thermal Exposure Conditions
- Cable Orientation (ac only)
- Raceway Routing
- Raceway Fill
- Insulation Type
- Insulation Material
- Insulation-Jacket Type
- CPT Size (ac only)
- Circuit Grounding (ac only)
- Wiring Configuration
- Conductor Size
- Circuit Type (dc only)
- Fuse Size (dc only)
- Cable Shielding (dc only)

In addition to these parameters, the report documents a review of the data for inter-cable failures, effects of suppression on circuit response, multiple circuit concurrent hot shorting events, and a phenomenon observed in the dc testing, identified as the “ground fault equivalent hot short.”

Conducting the evaluation in this systematic manner allows for a better understanding of the data and identification of the areas in which additional data may be needed, and also supports the electrical expert PIRT work. The focus of this report is to document the data analysis that was conducted to support the PIRT panel; however, insights from this report may be used in other regulatory aspects, although it does not serve as NRC endorsement. Limited statistical methods but no probabilistic risk assessment methods were employed in the evaluation, just factual inference of the data.

1.3 The Approach

The data used in developing this report was obtained from the EPRI/NEI cable testing report [4], along with the NRC-sponsored CAROLFIRE (NUREG/CR-6931)[1-3] and DESIREE-FIRE (NUREG/CR-7100) testing project [5]. It is assumed that the reader is familiar with those reports, and only brief descriptions of the testing will be provided in this report. A reader unfamiliar with this testing is urged to review the test reports to better understand the testing methods and results.

A database was generated from the information provided in the reports and associated electronic data files. The database included all pertinent information regarding the circuit configuration and failure modes/characteristics. The cable failure data were obtained from the actual data files and cross-referenced with the results documented in the associated reports. This provided an increased level of quality assurance to ensure that the electronic files and data report information were consistent, thereby minimizing the likelihood of information transfer errors. Once the database was populated with information found to be important for this project, it was sorted by parameters of interest so that specific information could be collected, reviewed, and reported.

Staff members from the NRC's Office of Nuclear Regulatory Research (RES) were responsible for analyzing the ac test data from EPRI/NEI and CAROLFIRE testing, while staff from SNL processed and reviewed the dc test data. The intent was to have two groups complete the work in parallel to reduce time and increase efficiency. Throughout the process, NRC-RES and SNL staff coordinated with each other to ensure a high level of consistency between the two efforts.

The analysis focuses on presenting the test data in a manner that will assist the electrical expert PIRT panel members in making informed decisions regarding the ranking of various circuit parameters and key phenomena. This information was determined by identifying the number of specific failure modes (fuse clear, hot shorts, and spurious operations), given a particular circuit or cable parameter. For this analysis, the following definitions, which were developed by the PIRT panel, were used to classify fire-induced circuit failures:

Hot Short: Energized conductors coming into contact with a separate conductor, other than neutral/ground, with the potential to provide voltage/current to a device, such as a relay/coil/resistor/indicating light. This includes an energized conductor coming into contact with a spare conductor. For the purposes of the PIRT, only a hot short that is of sufficient quality to actuate the end device is of interest.

Hot Short-Induced Spurious Operation²:

Inadvertent energization of a device due to a hot short. In the context of fire test data interpretation, the device of interest only includes the end device subjected to the test (solenoids, motor starter contactors, breaker coils, etc.) but does not include energization of spare conductors or energization of indicating lights (burden resistors simulating light bulbs). By definition, these form a subset of Hot Shorts.

Duration: The time (reported in seconds) that a particular hot short or spurious operation persisted. In cases where sequential hot shorts or spurious operations occurred one after another, the durations of all occurrences were summed to obtain a total duration, which was then reported (i.e., the reported total duration was not necessarily continuous).

1.3.1 Failure mode data presentation of data

There are three primary circuit failure modes of interest to the electrical expert PIRT panel: fuse clear failures, hot shorts, and hot short-induced spurious operation. These failure modes are provided in this report, using what is referred to as the "global approach," which evaluates failure modes in a binary fashion. This binary approach defines the first failure mode as being either a fuse clear or a hot short. For a given cable/circuit combination, either a fuse clears or a hot short occurs. To facilitate a better understanding of the fraction of hot shorts that are spurious operations, the spurious operation data are also reported separately, but ***it must be understood that the hot short data includes spurious operations by definition***. Therefore, for the global approach in reporting failure mode data, the number of hot shorts is always by definition larger than or equal to the number of spurious operations.

In general, fire-induced circuit testing has shown that a damaged cable will eventually short to a common ground and cause the protective fuses to clear. In this report, it must be clear that the

² "Spurious Operation" and "Spurious Actuation" are used synonymously throughout this report.

fuse clear category only counts fuse clear failures from the first failure mode. For example, if a circuit experienced a spurious operation at 100 seconds and then experienced a fuse clear at 130 seconds, this report would count the hot short and spurious operation, but not the fuse clear. Specifics on how the failure modes are counted and reported are presented in Section 2.1 for ac circuits and in Section 4.1 for dc circuits.

Another aspect of this analytical approach, relative to the spurious operation count, is best shown with another example. Start with a circuit that experiences a hot short on a conductor that is not associated with a device that can cause a spurious operation (e.g., indicating lamp – a passive target). Sometime in the future, another hot short occurs, this time on a conductor that can cause a spurious operation. In this case, the hot short and the spurious operation would be included in the count (i.e., # hot shorts = 1, # spurious operations = 1). Note that the hot short count is not two, even though two hot shorts have occurred in an individual circuit (i.e., one hot short for the passive target and one hot short for the active target). The analysis was done in this manner to ensure that if a spurious operation occurred, it would be counted and reported. In reality, when circuits fail from fire-induced exposures, it is common for a single circuit to experience multiple hot shorts.

An example of how the global approach failure mode information is presented in this report is shown in Table 1-1 and Figure 1-1. Table 1-1 documents the number and types of failure modes for each scenario, while Figure 1-1 shows this information graphically in a column chart. In this example, there are three different scenarios (A-C), and the columns identify the number of individual failure modes associated with the specific scenario. The first failure mode is a “fuse clear” failure. This refers to failures in which the circuit failed in such a way as to cause the protective fuse to clear, meaning that no hot shorts occurred. The next failure mode represents the number of spurious operations. This information identifies the number of circuits that experienced hot short-induced spurious operations. The next column, “Hot Shorts,” represents the number of circuits that experienced a hot short. If we take Scenario A as an example, six spurious operations and 13 hot shorts occurred. However, of those 13 hot shorts, six were spurious operations (by definition); thus, seven of the hot shorts in Scenario A were associated with conductors that, when energized, would not result in a spurious operation (e.g., indicating lamps, spare conductors, etc). The column plots also have the associated percentages at the top of each column.

Table 1-1. Example of failure mode table

	Scenario A	Scenario B	Scenario C
Fuse Clear	5	20	10
Hot Short	13	5	17
Spurious Operation	6	5	15
HS/SA Possible	18	25	27




Figure 1-1. Examples global approach failure mode column plot

1.3.2 Failure mode duration presentation of data

To provide a realistic and simple graphical representation of the duration data set, this report provides hot short and spurious operation duration box plots, also known as box and whisker plots. An example of a box and whisker plot is provided in Figure 1-2. The example data set used to prepare this example plot is a continuous set of integers ranging from 21 to 80.




Figure 1-2. Box and whisker plot example

The duration of hot shorts and spurious operations were evaluated on a conductor by conductor basis. In this way, the duration of each hot short was tabulated by evaluating each conductor voltage and current profile for each test and summing the duration of the hot short(s) for each conductor. The conductor durations were then used to produce the box plots. Since spurious operations are a form of hot short, this report presents hot short duration box plots that

represent both hot short and spurious operation durations, while the spurious operation duration box plots only account for conductors that are associated with an end device which actually spurious operated.

Box plots show a measure of central location (median), two measures of dispersion (the interquartile range, defined as the difference between the first and third quartiles), the skew, and potential outliers. Box plots do this by using the minimum and maximum values, along with the first, second, and third quartiles of the data set. Quartiles are related to percentiles in that the first quartile (designated q1) is the 25th percentile. The second quartile (q2) is the 50th percentile, and is also referred to as the median. The third quartile (q3) is the 75th percentile of the data. It should be noted that no distributions are assumed in presenting data using box plots.

The box plots identify the minimum and maximum values in the data set. Lines from these two points are referred to as the whiskers, and connect to the boxes' limits. The boxes' lower and upper limits indicate the first and third quartiles, respectively. The median is located within the box and is a reference point for identifying any skewness in the data set. As a general rule, any whisker which is three times longer than the length of the box most likely indicates an outlier. As you will see in the test result sections below, the duration data has several long duration outliers that make it difficult to interpret any variations of the core data. Rather than remove these long duration data points, the authors have reduced the plot ranges (y-axis) to provide a better representation of the data variations, with the maximum values designated at the top of the plot. Tables are included with these box plots to provide all of the information numerically, in tabular form.

There are numerous methods for calculating quartiles. For simplicity, the authors chose to use the built-in "quartile" function of Microsoft Excel. Excel uses the following equations to calculate quartiles:

$$y = (1 - g) * x(j + 1) + g * x(j + 2) \quad \text{(Equation 1-1)}$$

$$(n - 1) * p = j + g \quad \text{(Equation 1-2)}$$

where

n = number of values

y = observation number (when values are arranged in ascending order)

p = percentile

j = integer

g = decimal

x() = specific value in ascending list

These equations can be simplified into the following form for the first, second, and third quartiles:

- 1st quartile (q1): $\frac{1}{4} * (n+3)$ th observation
- 2nd quartile (median): $\frac{1}{2} * (n+1)$ th observation
- 3rd quartile (q3): $\frac{1}{4} * (3*n+1)$ th observation.

1.4 Report Organization

Section 2 presents the ac data taken from the EPRI/NEI, CAROLFIRE, and DESIREE-FIRE testing projects, evaluating the various intra-cable failure parameters where data was available. A summary of the systematic parameter evaluation is presented in the latter portion of Section 2, along with evaluations of the effects of suppression and hot short concurrence.

Section 3 provides a review of inter-cable failures observed during testing and the authors' identification of any influencing parameters. This discussion identifies what was done in the EPRI and NRC testing programs to provide tests that could be used to evaluate the likelihood of inter-cable fire-induced hot shorts of ac circuits.

Section 4 presents the dc data taken from the DESIREE-FIRE testing project, evaluating the various intra-cable failure parameters. This analysis complements the information from Section 2 on the ac data, but also evaluates several additional parameters. This section also includes a summary of the systematic evaluation of the dc data, along with a review of concurrent hot shorts that occurred in the intermediate-scale testing of dc circuits.

Section 5 provides a summary of test data related to inter-cable interactions for ac circuits, similar to what was done in Section 3. The larger portion of Section 5 involves the evaluation of what is being called "ground equivalent hot shorts," where multiple cables experience hot shorts.

Section 6 provides a summary of findings for the entire report.

Section 7 contains the report conclusions.

Section 8 provides references.

Appendix A contains data on the penlight ground fault equivalent inter-cable failure mode evaluation.

Appendix B contains supplemental information for the CAROLFIRE reports, including additional data retrieval.

2. INTRA-CABLE – ALTERNATING CURRENT CIRCUITS

2.1 ac data analysis approach

An alternating current (ac) motor-operated valve (MOV) circuit was the primary circuit used in the Electric Power Research Institute/Nuclear Energy Institute (EPRI/NEI) and Cable Response to Live Fire (CAROLFIRE) testing projects to evaluate the likelihood of spurious operations. A small set of tests in the Direct Current Electrical Shorting In Response to Exposure Fire (DESIREE-FIRE) project also used the ac MOV circuitry. The ac MOV circuit typically had passive targets representing indicating lamps, two active targets (forward and reverse motor starter contactor), spare conductors, one to two energized (source) conductors, and at least one common return.

The definition of a hot short is important to this work. As stated previously, only a hot short that is of sufficient quality to actuate the end device is of interest. Thus, low-quality hot shorts that would not cause the circuit to respond would not be of interest. Therefore, threshold values are defined as identifying the energy levels (voltage or current) that would be required to cause the active and passive targets to change state. This information is presented in Table 2-1, identifying the failure threshold values for the ac MOV circuit. Active targets are considered to be those cable conductors which are connected to one of the two MOV contactors. If these active target conductors become energized during fire-induced cable failure with sufficient voltage and current, the contactors will pull in, and, in real plant systems, the motor will become energized to move in either the open or close direction, depending upon which contactor becomes energized. For the ac test data, a hot short on a passive target or on a spare conductor was counted when that electrical conductor achieved a voltage level of 80V. The choice of 80V is based on the authors' judgment and discussion with the Phenomena Identification and Ranking Table (PIRT) panel. For an indication lamp, 80V is sufficient to illuminate the lamp, and for an ungrounded spare the 80V threshold was thought to be sufficient to eliminate the likelihood that the measurement would derive from induced voltages on the spare conductor.

Table 2-1. ac threshold values used for MOV hot short & spurious operation determinations

		EPRI/NEI	CAROLFIRE	DESIREE-FIRE
Active Targets	Pick-up Voltage	80V	72V	80V
	Drop-out Voltage	60V	65V	60V
Passive Targets	Voltage	80V	80V	80V
Spare	Voltage	100V	100V	100V

For continuous hot shorts, the duration time was calculated from the start of a hot short to the end, which was typically a fuse clear. In several cases, a circuit will experience several successive hot shorts on the same conductor. In these cases, the duration is based on the **sum of the individual durations**. For example, let's assume that conductor number three of circuit A experienced three hot shorts lasting 10, 15, and 5 seconds respectively; the duration reported would be 30 seconds, based on the authors' judgment and discussions among the expert electrical PIRT panel. This is considered to be a conservative approach, but also realistic for

components, such as a motor-operated valve, that don't return to their original state following the clearing of the hot short/spurious operation, requiring a finite stroke time to open or close. Once all of the information from the tests was entered into the spreadsheet, the data was reviewed for circuit configurations that fell outside of the majority of the test data. These outlier circuit configurations were removed from further use in the study. For instance, in CAROLFIRE, there were several tests that were designed to evaluate the likelihood of inter-cable shorting. Since this analysis is only concerned with intra-cable interactions, the inter-cable data was removed from this analysis, but is used in Section 3 to evaluate inter-cable hot shorting. In some of the CAROLFIRE and several of the EPRI/NEI tests, the cables did not fail. In the cases where the cables are not driven to thermal failure, there is no information on the failure modes to be learned. Thus, the test circuits that did not fail were removed from further use in this study.

The final type of data points that were removed from the spreadsheet were instances where the circuit was instrumented in such a way that it was impossible for the electrical protective device (fuse) to clear or configure, so that the only method that would allow a fuse clear would be a short to an external ground. The majority of these cases are from the DESIREE-FIRE testing, where a flame-retardant Kerite™ (FR-Kerite) cable was tested using ac diagnostics to evaluate the thermal failure temperature. Here, only source conductors and active target conductors were included in the test cables. As such, there were no common return paths within the cable that would cause a fuse clear, which could only occur when an energized conductor came in contact with a ground plane at low resistance. Although configurations in the plants may exist when there is no common power source return in a cable with sources and targets, the authors believed that this data would skew the results, especially for hot short likelihood and duration. As such, these data points were removed, and were not used in this study.

The last point to make clear is the manner in which the data is presented in the report. Specifically, there are several ways to present the fault mode data in terms of counting hot shorts. The discussion that follows provides clarification on the methods that were used in this report.

Figure 2-1 is a schematic of the surrogate circuit diagnostic unit (SCDU) used in CAROLFIRE to represent an ac MOV motor starter circuit. Similar circuits were used in the EPRI/NEI and DESIREE-FIRE testing projects. In Figure 2-1, there are two energized source conductors, shown as circuit paths 1 and 2. A resistor used to represent an indication lamp is considered to be a passive target (PT), and is connected to circuit path 4. Circuit paths 5 and 6 are connected to the forward and reverse motor starter contactors, "K1" and "K2." These two paths are considered active targets (AT). Circuit path 7 is connected to the common power supply return, and circuit path 8 is considered to be an ungrounded spare conductor.




Figure 2-1. CAROLFIRE ac MOV circuit

Table 2-2 provides information pertaining to the circuit path configuration for the CAROLFIRE ac MOV SCDU. As shown, paths 5 and 6 can experience both hot shorts and spurious operations. Circuit Paths 4 and 8 can experience a hot short only.

Table 2-2. CAROLFIRE ac MOV circuit path configuration

	Source	Hot Short	Spurious Operation	Power Supply Common Return
Circuit Path 1	X			
Circuit Path 2	X			
Circuit Path 4		X		
Circuit Path 5		X	X	
Circuit Path 6		X	X	
Circuit Path 7				X
Circuit Path 8		X		

Using the global approach, there can only be one of two outcomes: (1) the cable experiences hot short(s), or (2) the cable experiences a ground fault (clearing of the circuit fuse). Note that spurious operations are a subset of hot shorts. The global approach does not provide an indication on the number of hot shorts that occur within a multi-conductor cable; either it occurs, or it doesn't. This method does not make any distinction between the numbers of hot shorts. From these examples, it is important to note that there will always be at least as many hot shorts as spurious operations. This is because every spurious operation is classified as a hot short, but not every hot short is classified as a spurious operation.

For example, let's assume that the ac MOV circuit shown in Figure 2-1 is used in a test, and that the following failure modes occurred in this case:

- @ 954 seconds – circuit path 4 experienced a hot short
- @ 1005 seconds – circuit path 6 experienced a hot short
- @ 1013 seconds – circuit path 6 experienced a hot short
- @ 1020 seconds – the circuit fuse cleared

In this example, using the global approach to counting hot shorts and spurious operations, there was one hot short, one spurious operation, and no fuse clears. In reality there were three hot shorts, two spurious operations, and one fuse clear. Again, the global approach looks at the circuit failure modes in a binary fashion. This point is important for understanding the information that follows in this section and in Section 4.

With regard to calculating duration of the hot shorts and hot short induced spurious operations, more information is required to calculate the duration using the method outlined above. Using the previous example, the duration of the hot short and spurious operation is presented using the following information:

- circuit path 4, hot shorts as follows;
 - 954 seconds – hot short starts
 - 1020 seconds - hot short ends
- circuit path 6 experienced a hot short induced spurious operation as follows;
 - 1005 seconds - spurious operation begins
 - 1010 seconds - spurious operation ends
 - 1013 seconds - spurious operation begins
 - 1020 seconds - spurious operation ends

For circuit path 4, since only one fire-induced hot short occurred, the duration is calculated as the hot short end time (1020s) minus the hot short start time (954s) resulting a hot short duration of 66 seconds. For circuit path 6, multiple hot short-induced spurious operations occur on the same end device. Here the duration is calculated for each individual spurious operation and all of the individual durations are summed together to arrive at a total duration for circuit path 6. This is shown in Equation 2-1.

$$\text{Circuit Path 6 duration: } (1010 \text{ s} - 1005 \text{ s}) + (1020 \text{ s} - 1013 \text{ s}) = 12 \text{ seconds} \quad \text{Equation 2-1}$$

The last point to make regarding the analysis of the ac test data is that some of CAROLFIRE and DESIREE-FIRE tests also employed SNL's patented Insulation Resistance Measurement System (IRMS), which was operated using ac power. This system provides measurements of a monitored electrical cable's insulation resistance as a function of time during fire-induced cable failure. The IRMS can provide detailed information as to how the individual conductors are failing; however, it does not represent any type of electrical circuit used in a nuclear power plant. Several concepts regarding the use of the IRMS data to evaluate failure modes were discussed during the electrical expert PIRT meetings, but none were technically accurate enough to be used to supplement the data analysis documented here.

The remainder of this section presents the ac test data evaluated by the various parameters outlined earlier. Each parameter discusses how the data was binned and then presents the failure mode likelihood, followed by information on the hot short duration.

2.2 Conductor Count

The effects of the conductor count on failure modes are evaluated here. The test data included multi-conductor cables with 3, 5, 6, 7, 8, and 9 conductors. The PIRT members suggested that the conductor count bins be labeled “1/C,” “2-6/C,” “7-9/C,” “10-15/C,” and “Greater than 15/C.” Table 2-3 provides the failure mode likelihood data, separated into conductor count ranges. There is no data publically available for 1/C cables, or for cables with conductor counts greater than 10/C.

Table 2-3. Conductor count, global approach, ac tests

Global Approach	1/C	2-6/C	7-9/C	10-15/C	>15/C
Fuse Clear	-	4	41	-	-
Hot Short	-	2	65	-	-
Spurious Operation	-	2	56	-	-
HS/SA Possible	-	6	106	-	-

Figure 2-2 presents the information from the above tables in column format. These figures show that a large portion of data has been collected in the 7-9 conductor range, making it difficult to assess the influence that conductor count has on hot short and spurious operation likelihood.




Figure 2-2. Conductor count column plot, global approach, ac tests

Table 2-4 presents data related to the durations of hot shorts and spurious operations, divided into the same conductor count ranges used above. Figure 2-3 presents this data visually, in a box plot. Again, the sparse data limits the amount of information that can be obtained relating to the influence of conductor count on hot short and spurious operation likelihood.

Table 2-4. Conductor count, duration data, ac tests

	Hot Short					Spurious Operation				
	1/C	2-6/C	7-9/C	10-15/C	>15/C	1/C	2-6/C	7-9/C	10-15/C	>15/C
q1	-	3	8	-	-	-	4	10	-	-
min	-	1	1	-	-	-	1	1	-	-
median	-	6	27	-	-	-	8	33	-	-
max	-	15	1345	-	-	-	15	456	-	-
q3	-	10	79	-	-	-	11	81	-	-
mean	-	7	69	-	-	-	8	61	-	-




Figure 2-3. Conductor count box plot, duration, ac tests

2.3 Thermal Exposure Conditions

The test data used to evaluate the thermal exposure parameter is separated into four general exposure conditions, radiant, flame, plume, and hot gas layer (HGL). Figure 2-4 shows the intermediate-scale testing rig used in the CAROLFIRE and DESIREE-FIRE testing projects. It is important to note that the locations were identified differently in the two testing projects, and that the lower exterior HGL locations in the CAROLFIRE project (i.e., B and D) were not used in the DESIREE-FIRE testing project. Care was taken during the analysis to ensure that the naming conventions did not cause the different exposure locations to be combined within the same bin.

Flame exposures were considered to be any electrically monitored cable in location A. In addition, if location A was filled with cables to provide a fuel source during an experiment, the locations directly above location A (C for CAROLFIRE and B for DESIREE-FIRE) would also be considered flame exposure locations. Plume exposure locations were considered to be locations C and F in CAROLFIRE and locations B and D in DESIREE-FIRE unless designated as flame locations, as discussed previously. HGLs were considered to be those locations outside of the flame and plume locations. Therefore, HGL exposure bins included locations B, D, E, and G for CAROLFIRE, and locations C and E for DESIREE-FIRE. In addition, the penlight exposure provided a radiated thermal exposure to the cables, and all of the Penlight

data is separated into an individual bin labeled “radiant.” The exposure conditions classification used in the EPRI test report were adopted as reported.




Figure 2-4. Intermediate-scale cable raceway location

Table 2-5 and Figure 2-5 present the ground fault, hot short, and spurious operation data. This data shows some deviations between thermal exposure conditions with regard to ground faults, hot shorts, or spurious operations. Here the flame region has a lower likelihood of experiencing a fuse clear fault and a higher likelihood of experiencing hot shorts and spurious operations. The limited number of ac circuit radiant energy tests (five in total) are all from the ac tests conducted during the DESIREE-FIRE project. Three of these cable samples were of the FR-Kerite variety, and the remaining two samples were cross-linked polyethylene (XLPE)-insulated.

Table 2-5. Thermal exposure conditions, global approach, ac tests

Global Approach	Flame	Plume	HGL	Radiant
Fuse Clear	7	15	19	4
Hot Short	18	22	26	1
Spurious Operation	17	17	23	1
HS/SA Possible	25	37	45	5




Figure 2-5. Thermal exposure conditions, global approach, ac tests

Table 2-6 and Figure 2-6 present the duration data, separated by thermal exposure conditions of flame, plume, and HGL exposures. The box and whisker plot shows that there may be a correlation between hot short/spurious operation duration and thermal exposure conditions. For flame exposures, the durations are very short, lasting between 1 and 32 seconds. The plume thermal exposure conditions have durations with a slightly longer and wider range of 6 to 120 seconds³. The hot gas layer thermal exposures have the largest range of duration, running from 1 to 456 seconds.

This observation is consistent with the physical response of the cables to these exposure conditions. In a flame impingement exposure, there is a very intense thermal insult on the cables and the insulation degrades rapidly, thus progressing from the onset of electrical failure to final circuit failures (fuse clear) in a short time frame. As the exposure conditions become less severe (i.e., plume then HGL exposures), the degradation of the conductor insulation is slower and the failures do not cascade to full failure as rapidly.

Table 2-6. Thermal exposure conditions, duration data, ac tests

	Hot Short				Spurious Operation			
	Flame	Plume	HGL	Radiant	Flame	Plume	HGL	Radiant
q1	2.3	17.5	20.7	0.6	4.2	24	28.9	0.6
min	0.2	5.8	0.4	0.6	0.2	6	0.8	0.6
median	7.3	45.6	78.8	0.6	8	47.4	78.8	0.6
max	31.6	1345	456	0.6	31.6	126	456	0.6
q3	20	72	169.7	0.6	24.6	60	120.7	0.6
mean	11.1	80.6	106.6	0.6	12.7	51.1	103.4	0.6

³ Note that one duration for the hot short plume data set was 1345 seconds. This data point has been removed from the generalized discussion, but is important when considering maximum test data durations.




Figure 2-6. Thermal exposure conditions box plot, duration, ac tests

2.4 Cable Orientation

Available test data consists of cable arrangement in the vertical and horizontal orientations. However, only one test project (EPRI/NEI) included testing cables in the vertical orientation, and the majority of the test data is for cables oriented horizontally. As such, there is too little information on fire-induced cable failures in the vertical orientation to allow for comparisons. Table 2-7 and Figure 2-7 present the data, which is separated by cable orientation.

Table 2-7. Cable orientation, global approach, ac tests

Global Approach	Horizontal	Vertical	Total
Fuse Clear	42	3	45
Hot Short	65	2	67
Spurious Operation	56	2	58
HS/SA Possible	107	5	112




Figure 2-7. Cable orientation, global approach, ac tests

Table 2-8 and Figure 2-8 present the duration information based on cable orientation binning. Again, the minimal amount of data in the vertical position inhibits an evaluation of how cable orientation affects hot short duration.

Table 2-8. Cable orientation, duration data, ac tests

	Hot Short		Spurious Operation	
	Horizontal	Vertical	Horizontal	Vertical
q1	7	11	10	12
min	1	6	1	6
median	27	15	32	18
max	1345	120	456	120
q3	77	44	79	69
mean	69	39	60	48




Figure 2-8. Cable orientation box plot, duration, ac tests

2.5 Raceway Routing

Open ladder-back cable trays, rigid steel conduits, and air drop configurations were all used during testing. However, the use of cable trays was predominant, and the lack of sufficient data in the air drop and conduit configurations makes it difficult to determine the effects of raceway routing type on fire-induced circuit failures. In addition, no data is available for cable trays with solid bottom covers or vented covers. Table 2-9 and Figure 2-9 present the test data separated by raceway routing configurations and air, conduit, and tray configurations.

Table 2-9. Raceway routing, global approach, ac tests

Global Approach	Air	Conduit	Tray
Fuse Clear	0	2	43
Hot Short	2	2	63
Spurious Operation	2	2	54
HS/SA Possible	2	4	106




Figure 2-9. Raceway routing column plot, global approach, ac tests

Table 2-10 and Figure 2-10 present the duration data separated by raceway routing configurations. This information indicates that air drop tests last longer than configurations using conduit or cable tray raceways. This observation is likely the result of the ground plane's influence on the circuit's ability to clear fuses. In an air drop test configuration, there is typically only one conductor that can cause a circuit to experience a fuse clear. This is a common power supply return (the neutral from the power supply), and it is typically grounded. For a circuit to clear its protective fusing, a source conductor is required to come in contact with a common ground. In conduit and cable tray configurations, a more substantial ground plane exists for source conductors to contact during cable failure. Thus, the lack of ground plane is likely the cause of the longer durations in the air drop configurations. The effects of gravity, cable type, and cable clamps/ties may also affect the failure modes among horizontal and vertical configurations. Although this hypothesis seems reasonable, it should be stated that the air drop and conduit data are scarce and additional data points may help reinforce this hypothesis.

Table 2-10. Raceway routing, duration data, ac tests

	Hot Short			Spurious Operation		
	Air	Conduit	Tray	Air	Conduit	Tray
q1	79	18	7	179	46	9
min	28	3	1	34	23	1
median	247	48	24	261	75	30
max	320	126	1345	296	126	456
q3	295	86	65	295	100	62
mean	195	56	62	213	75	53




Figure 2-10. Raceway routing box plot, duration, ac tests

2.6 Raceway Fill

Numerous cable raceway fill configurations were used during testing. To sort the data, three configuration groups were selected based on the testing configurations, namely bundles, intermediate fill, and single cable fill. Figure 2-11, Figure 2-12, and Figure 2-13 provide illustrations of the bundles, intermediate and single cable fill, respectively. Note that no tests involved cable trays or conduits filled to their maximum loading per the national electric code (NEC – NFPA 70). Even though the EPRI/NEI test configurations used a 7/c cable surrounded by three single conductors, that configuration has not been considered a bundle in this work, as it was loaded into cable trays with numerous other fill cables, as shown in Figure 2-12 and Figure 2-13.




Figure 2-11. Cable bundle arrangements (3-, 4-, 6-, & 12-cable bundles)




Figure 2-12. Cable tray fill intermediate



Figure 2-13. Single layer cable fill

Table 2-11 and Figure 2-14 present the failure mode data binned by raceway fill. One observation from this data is that the bundle data deviate from the intermediate and single cable arrangement in both ground faults and hot short/spurious operation occurrences. The data shows that the occurrence of a ground fault is roughly twice as likely (~52-53%) for the intermediate and single cable configurations as it is for a bundle configuration (~26%). The lower likelihood of a ground fault has a dependent effect on the occurrence of a hot short or spurious operation in the bundle configurations versus the other two configurations. One possibility is that the bundle configurations typically involve electrical cables at the top of the cable bundle and are shielded from the cable tray by fill cables that are not monitored for electrical response. Thus, for grounded circuits, which make up the majority of the test data, there is a barrier between the electrically monitored cable and the cable tray/conduit, thus reducing the ground plane influence and decreasing the likelihood of a ground fault. Again, the ground plane may influence failure mode likelihoods.

Table 2-11. Raceway fill, global approach, ac tests

Global Approach	Bundle	Intermediate	Single
Fuse Clear	13	16	16
Hot Short	37	14	15
Spurious Operation	35	11	11
HS/SA Possible	50	30	31




Figure 2-14. Raceway fill column plot, global approach, ac tests

Table 2-12 and Figure 2-15 present the hot short and spurious operation duration data separated by raceway fill categories (bundle, intermediate, and single). From this data, there is some indication that the intermediate fill duration data differs from that of the other two configurations; however, the reasoning behind this observation is unclear. One possibility is that the fill cables act as a heat sink and/or shield for the target cables from the thermal exposure, thus lowering the thermal exposure condition for the electrically monitored cables.

Table 2-12. Raceway fill, duration data, ac tests

	Hot Short			Spurious Operation		
	Bundle	Intermediate	Single	Bundle	Intermediate	Single
q1	7	18	11	8	24	7
min	1	1	1	1	1	1
median	25	54	21	30	57	21
max	453	1345	198	296	456	198
q3	62	120	63	62	111	75
mean	56	126	43	51	95	51




Figure 2-15. Raceway fill box plot, duration, ac tests

2.7 Insulation Type

The insulation type parameter separates insulation materials into two polymer types, thermoset (TS) and thermoplastic (TP). Table 2-13 provides a breakdown of how insulation materials were classified by insulation type. Section 2.8 of this report provides a comparison of failure characteristics based on insulation materials. Table 2-14 and Figure 2-16 present the test data separated by cable conductor insulation type, TS and TP. A comparison of the failure modes between the TS and TP data sets indicate that there is no substantial difference in fuse clear, hot short, or spurious operations.

Table 2-13. Breakdown of insulation material by type, ac tests

Thermoset Materials (TS)	Thermoplastic Materials (TP)
EPR – ethylene propylene rubber	PE – polyethylene
FR-Kerite – Flame Retardant Kerite™	PVC – polyvinyl chloride
SR – Silicone Rubber	TEF – Tefzel
SR-V – Silicone Rubber Vitalink™	
XLPE – cross-linked polyethylene	
XLPO – cross-linked polyolefin	

Table 2-14. Insulation type, global approach, ac tests

Global Approach	TP	TS
Fuse Clear	17	28
Hot Short	22	45
Spurious Operation	20	38
HS/SA Possible	39	73




Figure 2-16. Insulation type column plot, global approach, ac tests

Table 2-15 and Figure 2-17 present the duration data for test configurations segregated by cable conductor insulation type. Although the mean duration times are slightly higher for TP materials (73-80 seconds) than for TS materials (53-61 seconds), the interquartile range for the data presented in the box and whisker plot in Figure 2-17 shows no trend between TS and TP insulation types.

Table 2-15. Insulation type, duration data, ac tests

	Hot Short		Spurious Operation	
	TP	TS	TP	TS
q1	5	11	6	15
min	1	1	1	1
median	23	28	24	39
max	456	1345	456	231
q3	100	72	64	81
mean	80	61	73	53




Figure 2-17. Insulation type box plot, duration, ac tests

2.8 Insulation Material

In the previous section, the data was segregated by insulation type. In this section, the data expanded to insulation type classifications to show how insulation materials differ. Table 2-16 and Figure 2-18 present the ground fault, hot short, and spurious operation data segregated by cable conductor insulation material.

Table 2-16. Insulation material, global approach, ac tests

	TS				TP		
	EPR	XLPE	SR	FR-Kerite	PE	PVC	TEF
Fuse Clear	11	11	3	2	9	4	4
Hot Short	23	19	1	1	9	9	4
Spurious Operation	16	19	1	1	7	9	4
HS/SA Possible	34	30	4	3	18	13	8




Figure 2-18. Insulation material column plot, global approach, ac tests

As shown in the figures above, there is minimal data for silicone rubber (SR) and FR-Kerite. Thus, interpreting the results is difficult, and it will not be attempted here. Figure 2-18 indicates that the ethylene propylene rubber (EPR) material differs from the others in that there is a relatively larger gap between hot shorts and spurious operations (about 20%). The other materials show a nearly unified correlation between hot short and spurious operations based on the global analysis approach. Over 50% of the EPR data comes from the EPRI/NEI test set, and that test set-up may influence these results. However, the direct reasoning behind this difference is unclear to the authors. A comparison of the remaining cable conductor insulation materials shows similar results related to ground fault, hot short, and spurious operation likelihoods.

Table 2-17, Table 2-18, and Figure 2-19 present the duration data segregated by cable insulation material. Note that SR and FR-Kerite have been removed due to a lack of data. One interesting aspect of this duration data is the small interquartile range for polyvinyl chloride (PVC)-insulated conductors versus the other two TP cable types, polyethylene (PE) and Tefzel™ (TEF). Both PE and TEF insulation materials show the longest average durations, which was reflected in the previous section. However, PVC insulation materials have a very short duration.

Table 2-17. Insulation material hot short only, duration data, ac tests

	TS		TP		
	EPR	XLPE	PE	PVC	TEF
q1	12	11	18	1	33
min	1	1	1	1	8
median	60	30	55	4	168
max	324	1345	453	32	456
q3	90	49	233	10	203
mean	64	65	117	8	158

Table 2-18. Insulation material spurious operation only, duration data table, ac tests

	TS		TP		
	EPR	XLPE	PE	PVC	TEF
q1	12	19	27	1	33
min	2	1	3	1	10
median	62	38	55	6	126
max	198	231	296	32	456
q3	100	54	114	14	264
mean	63	50	95	10	172




Figure 2-19. Insulation material box plot, duration, ac tests

2.9 Insulation-Jacket Type Combinations

The previous two sections evaluated the effects of conductor insulation type and materials. The next logical parameter to evaluate would be cable jacket materials and polymer types. Although this was done initially, a review by the electrical expert PIRT panel found that the analysis was less than useful, and it was suggested that the synergistic effects of cable jacket type and cable insulation type should be evaluated instead.

This section provides that evaluation by looking at the insulation/jacket polymer type combinations available from the test data. This evaluation creates three bins, which include cables with (1) TP insulation and TP jacket, (2) TS insulation and TS jacket, and (3) TS insulation and TP jacket (mixed cable type). Table 2-19 and Figure 2-20 present the failure mode likelihood information, while Table 2-20 and Figure 2-21 reference the duration data for these configurations. The likelihood information provides little value in identifying any influence by insulation/jacket types on a particular failure mode. The duration evaluation indicates that the TS-TS cables have longer durations in general than the TP-TP and TS-TP configurations, based on the mean and the inter-quartile range.

Table 2-19. Insulation-jacket type, global approach, ac tests

Global Approach	TP-TP	TS-TS	TS-TP
Fuse Clear	17	20	8
Hot Short	22	36	9
Spurious Operation	20	29	9
HS/SA Possible	39	56	17




Figure 2-20. Insulation-jacket type column plot, global approach, ac tests

Table 2-20. Insulation-jacket type, duration data, ac tests

	Hot Short			Spurious Operation		
	TP-TP	TS-TS	TS-TP	TP-TP	TS-TS	TS-TP
q1	5	12	7.6	6	16.7	14.45
min	0.2	0.4	0.2	0.2	0.6	0.8
median	23.3	43.2	24	24	47.6	27.1
max	456	1345	62.4	456	231	62.4
q3	96.6	94.6	32.9	64.2	96.3	43.05
mean	79.8	76.1	23.1	73.4	61.9	28.8




Figure 2-21. Insulation-Jacket type box plot, duration, ac tests

2.10 CPT Size

Several differently sized control power transformers (CPTs) were used in the testing to evaluate the effects of CPT size on fire-induced circuit response. Table 2-21 provides information on the size of CPTs used during the various testing projects. At the time of this writing, the authors were not able to determine the size of the CPTs used in the EPRI/NEI testing project; thus, this data has been separated into its own bin for this review.

Table 2-21. Test project CPT size

	75VA	100VA	150VA	200VA	Unknown Size	No CPT
EPRI/NEI					X	X
CAROLFIRE		X	X	X		X
DESIREE-FIRE	X	X	X	X		

Table 2-22 and Figure 2-22 provide the circuit fault modes based on variously sized CPTs used during testing. The limited number of tests (two in total) using the 75VA CPT, and the fact that one test cleared the fuse while the other resulted in a spurious operation; provide little information on this configuration's effect on failure mode. The 100VA and 150VA data are very similar to the ~32-33% ground fault mode likelihood and the ~65-67% hot short/spurious operation likelihood. The 200VA CPT and no CPT data are also similar to the ground fault likelihood of ~40-41% and the spurious operation likelihood of ~50-53%.

The EPRI/NEI data doesn't conform to the fault mode characteristics of the SNL data, as it shows a much higher likelihood of ground faults (~59%), a lower likelihood of hot shorts (~41%), and a much lower likelihood of spurious operations (~18%). Although there are many aspects within the EPRI/NEI testing that could lead to these results, the authors are unable to pinpoint the exact cause of the differences between the EPRI/NEI test data and the other data.

Table 2-22. CPT size, global approach, ac tests

Global Approach	75VA	100VA	150VA	200VA	Unknown Size (EPRI)	None
Fuse Clear	1	5	10	7	10	12
Hot Short	1	10	21	10	7	18
Spurious Operation	1	10	20	9	3	15
HS/SA Possible	2	15	31	17	17	30




Figure 2-22. CPT size, global approach, ac tests

Table 2-23 and Figure 2-23 present the duration data segregated by CPT size. The data shows that the hot short and spurious operation duration for cases where no CPT is used is on average longer than when a CPT is used. In general, there is not much difference between the CPT size and the duration of the hot short or the spurious operation.

Table 2-23. CPT size, duration data, ac tests

	Hot Short						Spurious Operation					
	75VA	100VA	150VA	200VA	EPRI	None	75VA	100VA	150VA	200VA	EPRI	None
q1	21	4	5	7	12	18	37	5	9	7	24	22
min	9	1	1	1	6	1	32	1	1	1	18	6
median	32	38	24	10	21	57	42	38	30	10	54	60
max	52	453	320	238	198	1345	52	97	296	231	198	456
q3	42	65	54	41	57	120	47	62	61	42	120	114
mean	31	67	53	47	50	108	42	37	56	46	83	83




Figure 2-23. CPT size box plot, duration, ac tests

2.11 Circuit Grounding

This section explores how circuit grounding affects fire-induced circuit response by examining the effects of having a grounded versus an ungrounded power supply on the fault mode likelihood during fire exposures. For grounded circuits that are powered from a CPT, the neutral on the secondary side of the CPT would be connected to the ground. For a grounded circuit not using a CPT, but connected directly to outlet power, the neutral would be grounded. The circuit ground connection for the experiments is the same ground plane associated with the cable raceway, cable trays, and conduits.

Table 2-24 and Figure 2-24 provide the ground fault, spurious operation, and hot short fault mode information. The data indicates that circuits that are ungrounded have a higher likelihood of experiencing a hot short (~85%) than a circuit that is grounded (~58%). Looking at the data in the fuse clearing aspects, a grounded circuit has a higher chance of clearing a fuse (~42%) than an ungrounded circuit (~15%). For the grounded configurations, 3% of the fuse clears are attributed to seven test points that used armored cable. Direct current (dc) testing by EPRI/NEI, Duke Energy Corporation, and the U.S. Nuclear Regulatory Commission (NRC) has shown that when an armored cable is used in a grounded circuit, the likelihood of experiencing a fuse clear failure is approximately 1.

Table 2-24. Circuit grounding, global approach, ac tests

Global Approach	Un-Grounded	Grounded
Fuse Clear	2	41
Hot Short	11	56
Spurious Operation	11	47
HS/SA Possible	13	97




Figure 2-24. Circuit grounding, global approach, ac tests

Table 2-25 and Figure 2-25 present the duration data segregated by circuit grounding (grounded versus ungrounded). The data indicates that the grounded circuits have a slightly higher average duration time, but the ranges of durations shown in Figure 2-25 indicates few differences.

Table 2-25. Circuit grounding, duration data, ac tests

	Hot Short		Spurious Operation	
	Grounded	Ungrounded	Grounded	Ungrounded
q1	8	7	10	16
min	1	1	1	1
median	24	29	31	33
max	1345	224	456	121
q3	84	62	84	71
Mean	74	44	63	45




Figure 2-25. Circuit grounding box plot, duration, ac tests

2.12 Wiring Configuration

Wiring configuration refers to the number of sources, targets, and neutrals/grounds located within a cable of interest. This parameter evaluation does not evaluate circuit-to-conductor connection patterns within a cable. EPRI conducted an evaluation of conductor connection patterns and determined that the “source-centered” configuration resulted in the highest likelihood of a circuit experiencing a hot short. The NRC-sponsored CAROLFIRE and DESIREE-FIRE projects typically connected circuits in the source-centered configuration. Thus, there is little to no new data to provide an evaluation of conductor connection patterns.

Table 2-26 provides a breakdown of the three wiring configurations and the number of source, target, and common return conductors in each configuration. A vast majority of the tests used a common configuration with two (2) energized source conductors, four (4) target conductors (passive targets, active targets, and spares), and one (1) common power supply return conductor (either a ground or a neutral, depending on circuit grounding configuration). Table 2-27 and Figure 2-26 present the spurious operation likelihood information by wiring configuration.

Table 2-26. Wiring configurations

	# Sources	# Targets	# Returns
Configuration 1	2	4	1
Configuration 2	2	3	1
Configuration 3	2	2	1

Table 2-27. Wiring configuration, global approach, ac tests

Global Approach	Config. 1	Config. 2	Config. 3
Fuse Clear	41	1	3
Hot Short	65	1	1
Spurious Operation	56	1	1
HS/SA Possible	106	2	4




Figure 2-26. Wiring configuration column plot, global approach, ac tests

The duration data is difficult to interpret for this parameter due to the lack of data for configurations 2 and 3. Table 2-28 and Figure 2-27 present the duration data based on wiring configuration.

Table 2-28. Wiring configuration, duration data, ac tests

	Hot Short			Spurious Operation		
	Config. 1	Config. 2	Config. 3	Config. 1	Config. 2	Config. 3
q1	7	8	1	10	15	1
min	1	6	1	1	15	1
median	27	10	1	33	15	1
max	1345	15	1	456	15	1
q3	79	12	1	81	15	1
mean	69	10	1	61	15	1




Figure 2-27. Wiring configuration box plot, duration, ac tests

2.13 Conductor Size

Control cables used in nuclear power plants (NPPs) are typically constructed with # 12 or # 14 American wire gauge (AWG) conductors. From the test data, only one ac MOV test used a cable conductor size outside of this range, and it was a 3/C # 8 AWG cable using a modified MOV circuit. To evaluate this parameter, the conductor size data was segregated into three bins, <12 AWG, 12 AWG, and 14 AWG. All of the 14 AWG data came from the EPRI/NEI testing project. The 12 AWG bin contains test data from all three test projects, and the single <12 AWG data point came from the CAROLFIRE project.

Table 2-29 and Figure 2-28 present the test data segregated by conductor size in tabular and graphical format. From this data, there is no direct indication that conductor size has any effect on the hot short likelihood. However, a comparison of the spurious operation likelihood between 12 AWG and 14 AWG (EPRI/NEI tests) indicates that there is a lower likelihood for 14 AWG conductor cables to experience a spurious operation. Although this is what the data shows, the

authors believe that some other parameter is influencing this outcome, possibly the EPRI CPT circuit data, which showed low spurious operation probability.

Table 2-29. Conductor size, global approach, ac tests

Global Approach	<12 AWG	12 AWG	14 AWG
Fuse Clear	1	30	14
Hot Short	0	47	20
Spurious Operation	0	43	15
HS/SA Possible	1	77	34




Figure 2-28. Conductor size, global approach, ac tests

Table 2-30 and Figure 2-29 present the duration data based on the conductor size bins. The data indicates that the smaller 14 AWG conductor cables have a longer duration (60 second median) than 12 AWG conductor-sized cables (24-27 second median).

Table 2-30. Conductor size, duration data, ac tests

	Hot Short			Spurious Operation		
	<12 AWG	12 AWG	14 AWG	<12 AWG	12 AWG	14 AWG
q1	-	7	15	-	8	18
min	-	1	1	-	1	6
median	-	24	60	-	27	60
max	-	453	1345	-	296	456
q3	-	55	120	-	56	120
mean	-	52	115	-	49	94




Figure 2-29. Conductor size box plot, duration, ac tests

2.14 Water Based Fire Suppression Effects on ac Circuit Failures

The effect of water spray on thermally fragile cables was only explored in a minimal set of tests. During the EPRI/NEI tests, a single sprinkler head was located in the ceiling corner of the fire test enclosure above the cable tray bend in the general fire location. The sprinkler was manually activated, and it was not used in every test. There were also a few tests in which manual water suppression was applied using a garden hose. In CAROLFIRE, a single open head sprinkler was installed near the ceiling center of the intermediate-scale test structure, on a pendant about 150 mm (6 in.) long. The water flow was manually initiated using a small electric pump and only initiated in those tests where one or more of the cables had not experienced electrical failure (silicone rubber). No water suppression was used in the DESIREE-FIRE testing.

Water spray was observed to cause spurious operations in only one EPRI/NEI test, Test 3. In this case, a spurious operation did coincide with water spray, and persisted for approximately 24 seconds before a fuse clear occurred. This test cable was located at the center of the top layer of a two-layer cable fill test. Figure 2-30 provides a voltage plot of test circuit 3 for EPRI/NEI Test #3, showing the spurious operation on the target conductor, Wire #4 but only hot shorts on non-spurious operation target Wire #5 and Wire #7.




Figure 2-30. EPRI/NEI Test 3 voltage plot - water spray

In Test 10 of the EPRI program, water spray was applied during an ongoing spurious operation. The application of water terminated the spurious operation (cleared for 42 seconds), followed by a brief operation of a target conductor (6 seconds), followed by a fuse clear failure. These electrical interactions are shown in Figure 2-31. In two other tests, water spray showed marginal effects on the cable electrical response. In one case, an induced voltage had built upon the spare conductor. When water spray was initiated, the induced voltage was rapidly lost. In the other case, very minimal current spikes (~0.05 amps) were observed in the 1/C cables, coincident with water application. The reader is encouraged to refer to the EPRI test report for more information.




Figure 2-31. EPRI/NEI Test 10 voltage response following water spray

The CAROLFIRE intermediate-scale tests used the water sprinkler in five tests (IT5, IT6, IT9, IT10, IT13). In all of these tests, the only cable types operating at the time of manual sprinkler activation were the Silicone Rubber or Vita-Link cables. In one instance, the sprinkler activation caused an SR cable to fail in a manner that resulted in a spurious operation. All other cables exposed to the water spray were connected to the insulation resistance measurement system. Of those seven cables, six resulted in a short circuit of less than 1,000 ohms⁴. A single cable experienced a short circuit of less than 1,000 ohms, followed momentarily by some insulation resistance recovery above 1,000 ohms.

Another complicating matter for evaluating water spray effects on cable response is that water suppression was applied near the end of the testing, and many of the circuits had already experienced fuse clear circuit failures. Although there is data available on the effects of water spray on thermally fragile cables, an understanding of the cables' response to water at earlier stages of cable damage is unavailable at this time.

⁴ 1,000 ohms was used as the insulation resistance threshold for failure of a cable. Insulation resistance measurements under 1,000 ohms indicate that insulation is not capable of performing its design function.

2.15 ac Circuit Concurrence of Hot Shorts

Concurrence of hot shorts (or spurious operations), as discussed in this report, occurs when multiple circuits (cables) experience hot shorts at the same time, concurrently. The ac test circuit configurations eliminated the possibility of a single cable causing multiple concurrent hot shorts affecting multiple circuits. Thus, when reviewing the test results, two cables are required to experience a hot short at the same time to be considered concurrent hot shorts.

In all of the ac testing to date, the concurrence of hot shorting has not been observed within any individual test. In some cases, the concurrence between two circuits was missed by only a few seconds, but, given the strict definition of concurrent hot shorts, this phenomenon was not observed in any ac circuit testing.

There are several reasons that this phenomenon was not observed in testing. First, only a limited number of cables/circuits can be instrumented electrically during each test. The NRC/SNL small-scale radiant was limited to two electrically instrumented cables per test, while the larger scale testing (both industry- and NRC-sponsored) was limited to four surrogate ac MOV circuits for the ac testing. Secondly, the exposure conditions for the majority of the test were fairly severe, as the testers needed to cause failure within 10-30 minutes for a risk-significant scenario. These severe exposures resulted in the cables quickly cascading through failure modes, as well as shorter hot short durations. Thirdly, a variety of cable types were tested (especially in the NRC/SNL testing), and each cable type has a unique thermal failure threshold; thus, even with fairly uniform exposure conditions to multiple cables, the failure times may never align. Lastly, the larger scale testing allowed for a variety of thermal exposure conditions due to the locations of the cables relative to the heat source and their locations within a tray loaded with cables. For instance, a cable located on the bottom row of cables in an open ladder-back cable tray in a fire plume will be exposed to more severe thermal conditions than a cable in the same cable tray, but insulated from the fire conditions by other cables.

During a PIRT panel meeting, it was suggested that the NRC/SNL tests could be combined based on exposure location in the intermediate-scale test apparatus to evaluate their likelihood of concurrence. As the thermal exposures were kept fairly constant among the NRC/SNL intermediate-scale tests (~200kW), this concept was explored.

To complete this comparison, the intermediate-scale test data from CAROLFIRE and the intermediate-scale ac test data from DESIREE-FIRE were combined and separated by location. As shown in Figure 2-32, the locations were labeled differently between projects, so care was taken to ensure that labeling differences did not lead to binning errors. Symmetrical cable locations were grouped together as one location because of identical exposure conditions. For example, in the CAROLFIRE configuration in Figure 2-32(a), locations E and G were grouped together, as well as locations C and E of the DESIREE-FIRE configuration in Figure 2-32(b). However, locations C and F of CAROLFIRE and locations B and D of DESIREE-FIRE were not grouped together because the plume transition zone near the top location (F in CAROLFIRE, D in DESIREE-FIRE) likely has different exposure conditions than the location directly below. Trays grouped by location would be exposed to the same fire conditions, heat release rate, and location relative to the wall. The data was then analyzed to find times when hot shorts occurred in the same location at the same times (i.e., concurrence).




Figure 2-32. (a) CAROLFIRE and (b) DESIREE-FIRE intermediate-scale exposure location designation

Analyzing the data in this way shows that concurrent hot shorts were observed in CAROLFIRE/DESIREE-FIRE location A and CAROLFIRE location G/E (DESIREE-FIRE location C/E), “upper hot gas layer,” when the individual test data was grouped together. At location A, two sets of concurrence were identified, as shown in Figure 2-33 and Figure 2-34.




Figure 2-33. Concurrent hot shorts - location a - 4 cables

The blue diamonds in these figures indicate the start of a hot short, the red squares indicate the end, and the black lines represent the duration. The blue vertical lines separate the individual

tests. A concurrence occurs when hot shorts within different cables have overlapping times. The information on the horizontal axis indicates:

- test series (C = CAROLFIRE),
- testing scale (IT = Intermediate, P = Penlight),
- test number,
- circuit number (CK#), and
- the conductor that experienced the hot short (C#).

Conductors C5 and C6 are the active targets in the ac MOV circuits, which represent spurious operations/hot short targets, while conductors C4 and C8 are the passive targets, which represent only hot short targets.

Figure 2-33 shows the first set of concurrences, which included four cables, none of which were the same cable type, XLPO/XLPO⁵, EPR/CPE, TEF/TEF, and XLPE/PVC. One instance of concurrence involved three cables from CAROLFIRE tests 6, 7, and 11. The number of hot short concurrences, especially in test 11, makes the combination of concurrences extensive and cumbersome to present in a list. Instead, concurrences that only involve spurious operation targets are identified in Table 2-31, along with the durations of these concurrences. Figure 2-34 presents the second set of concurrences that occurred in location A. Here, again, different cable types were involved XLPE/PVC and PE/PVC. There is only one instance where multiple spurious operations occurred concurrently. Table 2-31 presents the circuit identification and concurrence time duration information.

Table 2-31. Concurrent spurious operations – test location A

Circuit Conductors Involved	Duration (seconds)
C-IT-7-CK2-C6, C-IT-10-CK3-C5	7.8
C-IT-7-CK2-C6, C-IT-11-CK4-C6	7.8
C-IT-7-CK2-C5, C-IT-11-CK4-C5	2.8
C-IT-7-CK2-C5, C-IT-11-CK4-C6	10.8
C-IT-6-CK4-C6, C-IT-7-CK2-C5	4.8
C-IT-6-CK4-C6, C-IT-7-CK2-C5, C-IT-11-CK4-C6	4.8
C-IT-7-CK3-C5, C-IT-8-CK2-C5	5.0

The second set of hot short concurrences that occurred in location A is presented in Figure 2-34. Here circuit three of Test 7 experiences a spurious operation at the same time as circuit eight of Test 8.

⁵ A typical convention for identifying a cable's insulation and jacket materials is to write the insulation material first, followed by the jacket material. For example, XLPE/PVC is a cross-link polyethylene insulated cable with a polyvinyl chloride jacket.




Figure 2-34. Concurrent hot shorts - location A - 2 cables

The other instance in which concurrent hot shorting was identified in this analysis was in the upper hot gas layer exposure locations (CAROLFIRE location G/E, DESIREE-FIRE location C/E). Again, two sets of concurrence were observed. The first occurrence included four cables, of which three were of the same construction (PE/PVC) and the other was PVC/PVC. All were of the thermoplastic polymer variety. The second instance of concurrence included two cables; one was EPR/CPE, and the other was PVC/PVC. Figure 2-35 and Figure 2-36 present plots of the hot short durations, and Table 2-32 provides a listing of the circuits involved in spurious operation concurrences and associated durations. The durations of these concurrences are longer than those in location A, likely due to the difference in thermal exposure conditions.




Figure 2-35. Concurrent hot shorts - upper hot gas layer - 4 cables

Table 2-32. Concurrent spurious operations – upper hot gas layer

Circuit Conductors Involved	Duration (seconds)
C-IT-11-CK2-C5, C-IT-12-CK2-C6	97.4
C-IT-11-CK2-C5, C-IT-9-CK4-C5	38.2
C-IT-11-CK2-C5, C-IT-9-CK4-C6	47.4
C-IT-11-CK2-C5, C-IT-10-CK1-C6	1.0
C-IT-11-CK2-C5, C-IT-10-CK1-C6	31.0
C-IT-12-CK2-C6, C-IT-9-CK4-C5	25.8
C-IT-12-CK2-C6, C-IT-9-CK4-C6	47.4
C-IT-12-CK2-C6, C-IT-10-CK1-C5	48.6
C-IT-12-CK2-C6, C-IT-10-CK1-C6	1.0
C-IT-12-CK2-C6, C-IT-10-CK1-C6	53.0
C-IT-9-CK4-C6, C-IT-10-CK1-C6	1.0
C-IT-9-CK4-C6, C-IT-10-CK1-C6	6.8
C-IT-11-CK2-C5, C-IT-12-CK2-C6, C-IT-9-CK4-C5	25.8
C-IT-12-CK2-C6, C-IT-9-CK4-C6, C-IT-10-CK1-C6	1.0
C-IT-12-CK2-C6, C-IT-9-CK4-C6, C-IT-10-CK1-C6	6.8




Figure 2-36. Concurrent hot shorts - upper hot gas layer - 2 cables

The rest of the locations showed no instances of concurrence. Four tests were run using CAROLFIRE location B/D, ten tests were run using CAROLFIRE location C (DESIREE-FIRE location B), and fourteen tests were run using CAROLFIRE location F (DESIREE-FIRE location D). None of these tests produced any instances of hot short concurrences. Section 4.15 provides the concurrent hot shorting for the dc circuits tested in the DESIREE-FIRE project.

3. INTER-CABLE – ALTERNATING CURRENT CIRCUITS

The evaluation of circuit failure results becomes increasingly complex when more than one cable is involved in the electrical failure. Cable-to-cable interactions are referred to as “inter-cable,” and, for an inter-cable hot short to occur, a source conductor in one cable must come into electrical contact with a target conductor in a different cable.

The number of recorded cable-to-cable interactions from the ac tests is significantly lower than the number of intra-cable interactions (within a cable). Thus, testing to date has provided only a small pool of data from which to draw conclusions about the effects of parameters on the likelihood and duration of these inter-cable interactions. Even with these limitations, there are some conclusions that can be drawn from the data. These conclusions are presented below and may provide some insight into the influencing factors of inter-cable electrical interactions. This section will not systematically evaluate parameter effects on the fire-induced circuit failure response, as was done in the previous section for the intra-cable evaluation.

All of the major testing projects (Electric Power Research Institute/Nuclear Energy Institute (EPRI/NEI), Cable Response to Live Fire (CAROLFIRE), and Direct Current Electrical Shorting In Response to Exposure Fire (DESIREE-FIRE)) provide at least two test configurations to evaluate the occurrence of inter-cable failures. In most cases, the voltage and current measurements from the simulated circuit could be evaluated to determine whether any inter-cable interactions occurred. In addition, separate circuit configurations were used in all test programs to specifically focus on understanding, and, in some cases, stacking the odds to trigger inter-cable interaction. The following provides a description of how the tests were conducted and what results were achieved.

Figure 3-1 provides an illustration of how the cables were oriented within a cable tray for the inter-cable tests during the EPRI/NEI program. Cables 1-3 were monitored for electrical response, with cables 1 and 3 containing both energized source conductors and target conductors, while cable 2 only contained target conductors. The target conductors were connected to burden resistors to simulate a load. The black cables in Figure 3-1 represent fill cables that were not monitored for electrical response, but were used as a buffer between the electrically monitored cables and the metallic cable tray. These fill cables likely reduced the likelihood of an energized source coming in contact with the ground plane and causing a fuse clear failure.




Figure 3-1. EPRI/NEI inter-cable test tray fill

Two EPRI/NEI tests used this configuration, and both tests showed similar results. The voltage and current readings indicate that the cables failed internally prior to any external interactions between cables. Since this configuration didn't represent system circuits used in plants, it is

difficult to determine whether or not inter-cable interactions would have caused hot shorts of sufficient quality to result in a component repositioning in an actual plant system.

The CAROLFIRE inter-cable test set-up was slightly different in that all of the conductors in two multi-conductor cables were energized as sources and a third multi-conductor cable had all of its conductors connected to a motor starter contactor, a target. Thus, the CAROLFIRE circuit could detect inter-cable interactions, but was unable to recognize when conductors internal to the multi-conductor cables had failed. The CAROLFIRE inter-cable test set-up is shown in Figure 3-2.




Figure 3-2. CAROLFIRE inter-cable test tray fill

Twelve inter-cable circuit trials were used in a total of four intermediate-scale fire tests during CAROLFIRE. Three of these circuits were left ungrounded, resulting in no possibility for the circuit fuse to clear. Because of this configuration, hot shorts/spurious operations were inevitable, and, in all three instances, prolonged spurious operations did occur. Of the remaining nine test circuits, seven experienced fuse clear faults. The remaining two circuits, both from test IT-3, experienced some inter-cable induced voltages, although this was not sufficient to cause a spurious operation. The CAROLFIRE inter-cable failure data does not provide a strong basis for understanding the inter-cable shorting phenomenon. In actual fires involving energized control cables for safety significant systems, there is a competing factor between the conductors internal to the failing cable and any inter-cable interactions. It is unfortunate that the CAROLFIRE results could not provide more insights into this competitive factor.

As discussed above, all three testing programs used surrogate motor-operated valve (MOV) circuits to monitor cable electrical response during a fire test. A review of this data can provide information on how the cable fails internally versus failing externally. However, before looking at this data, it is important to understand some of the differences between the EPRI/NEI and U.S. Nuclear Regulatory Commission/Sandia National Laboratories (NRC/SNL) test arrangements.

First, the industry tests used a configuration in which a 7/C cable was surrounded by three individual 1/C insulated conductors (without jacketing), zip-tied to the 7/C cable. This configuration is shown in Figure 3-3. The 7/C cable contained source, target, spare, and neutral conductors, while the exterior single conductors were either an energized source or an active target. All energized conductors were powered by the same source (wall power or control power transformer (CPT)). It should be noted that this configuration is not commonly found in U.S. nuclear power plants (NPPs). If single conductor cables are used, they will typically have a protective jacket over the single conductor insulation. The EPRI/NEI testing simply used an unjacketed insulated conductor that was stripped from a multi-conductor cable. That said, the results are still valuable and may be considered more conservative in that this configuration may

increase the likelihood of inter-cable interactions because of the lack of jacket and the use of cable ties to keep the single conductors in close proximity to the 7/C cable.




Figure 3-3. EPRI/NEI cable configuration

The EPRI/NEI test results indicate that of the 12 test circuits that experienced inter-cable hot short(s) or spurious operation(s), seven were between the 1/C cables. In four cases, the 7/C cable acted as a source to a 1/C cable target, and, in the final case, a 1/C cable energized a target conductor in a 7/C cable. Table 3-1 presents the results of the EPRI/NEI inter-cable results.

Table 3-1. . EPRI/NEI inter-cable failure characteristics

Test ID	Source Cable (#/C, wire, insulation)	Target Cable (#/C, wire, insulation)	Duration (seconds)
Test 3, Circuit 1	1/C – S1 (TS)	1/C – S3 (TS)	6
Test 8, Circuit 1	1/C – S2 (TS)	1/C – S3 (TS)	18
Test 9, Circuit 4	1/C – S2 (TS)	1/C – S3 (TS)	18
Test 12, Circuit 3	7/C – W1 (TS)	1/C – S3 (TS)	12
Test 4, Circuit 2	1/C – S2 (TP)	1/C – S3 (TP)	66
Test 4, Circuit 3	1/C – S2 (TP)	1/C – S3 (TP)	342
Test 4, Circuit 4	7/C – W2 (TP)	1/C – S3 (TP)	312
Test 6, Circuit 1	7/C – W2 (TP)	1/C – S3 (TP)	492
Test 6, Circuit 1	7/C – W2 (TP)	1/C – S3 (TP)	606
Test 10, Circuit 2	1/C – S1 (TS)	1/C – S3 (TS)	126
Test 10, Circuit 4	1/C – S2 (TP)	1/C – S3 (TP)	486
Test 17, Circuit 1	1/C – S2 (TS)	7/C W5 & W4 (TS)	66

In the CAROLFIRE testing, multi-conductor cables were connected to individual surrogate circuit diagnostic units (SCDUs) and arranged in 3- or 6-cable triangular bundles. The results from the CAROLFIRE SCU testing where inter-cable interactions were observed are shown in Table 3-2. CAROLFIRE did not use NEI configuration. All inter-cable interactions were from adjacent cables.

Table 3-2. CAROLFIRE ac inter-cable failure characteristics

Test ID	Source Cable (Circuit, Insulation)	Target Cable (Circuit, Insulation)	Duration (seconds)
Test IP 4, Circuit 1*	Circuit 2, TP	7/C – W6, TP	1
Test IP 4, Circuit 3*	Circuit 2, TP	7/C – W5 & W6, TP	1
Test IP 4, Circuit 4	Circuit 2, TP	7/C – W6, TP	1
Test 1, Circuit 4*	Circuit 1, TS	7/C – W4 (HS), TS	1
Test 7, Circuit 2*	Circuit 3, TS	7/C – W4 (HS), TS	1
Test 8, Circuit 2*	Circuit 3, TS	7/C – W4 (HS), TP	44

* Indicates inter-cable interactions occurring after the circuit fuse cleared.

In the CAROLFIRE project, the insulation resistance measurement system (IRMS) was used during Penlight radiant exposure tests and during the intermediate-scale testing. The IRMS can detect the onset of inter-cable shorting behavior, can measure the relative timing of inter-cable shorting versus both intra-cable shorting and shorts to the external ground, and can measure the duration of inter-cable shorts (i.e., how long an inter-cable conductor-to-conductor short remains independent of the external ground) [NUREG/CR-6931, V1].

The CAROLFIRE tests did detect some cases of inter-cable shorting between thermoset (TS) cables; however, only one of these cases involved a clear-cut case of a sustained inter-cable short circuit between two TS cables (IRMS in Test IT-1) that could have led to a spurious operation. In other cases, the interactions were secondary or tertiary failure modes for at least one of the two involved cables. However, the test data clearly showed that TS-to-TS interactions are plausible, although the likelihood of risk-relevant interactions appears to be low, especially in comparison to the likelihood of intra-cable interactions leading to spurious operation [NUREG/CR-6931].

4. INTRA-CABLE – DIRECT CURRENT CIRCUITS

All of the fire-induced direct current (dc) circuit failure data and information available for the analysis documented in this report came from the U.S. Nuclear Regulatory Commission (NRC)–sponsored Direct Current Electrical Shorting In Response to Exposure Fire (DESIREE-FIRE) project. A substantial amount of effort was required to convert the dc data into a usable format for this work. The formatting was handled by Sandia National Laboratories (SNL), and led to identification of several errors documented in the draft test report for the DESIREE-FIRE project. These errors were subsequently corrected in the final version of NUREG/CR-7100, “Direct Current Electrical Shorting In Response to Exposure Fire (DESIREE-FIRE): Test Results.”

The only dc test data removed from the analysis were instances where the cable did not reach a failure point at the end of the test. The majority of these cases were for the Kerite cable testing, where it was important to stop the test prior to cable failure to evaluate the physical damage to the cable materials. Tests excluded from further analysis in this report included the following:

- D-P-27-MOV1
- D-P-27-MOV2
- D-P-26-SOV1
- D-P-26-SOV2
- D-P-38-SOV1
- D-P-38-SOV2
- D-IT-P1-1-Vlv
- D-IT-P1-LargeCoil

Section 4.1 details the specific set points used to clean up the data and a brief description of the five dc circuits. The rest of the section provides failure mode likelihood and duration information based on specific parameters, as was done for the alternating current (ac) test data.

4.1 dc Data Analysis Approach

The analysis for the dc is discussed in this section. The data that was analyzed corresponds to the experiments performed under the DESIREE-FIRE testing program [5]. For the intra-cable experiments, there were five different circuit types (1-in Valve, Large Coil, motor-operated valve (MOV), solenoid-operated valve (SOV), and switchgear (SWGR)); the analysis for each will be discussed here in detail.

The dc data required additional review and processing to ensure a consistent method of determining the specific failure points of concern. To accomplish this, threshold voltage levels were identified for specific conductors that corresponded with a specific failure mode. This information is presented below. These voltage levels were then used on the specific circuit data to generate state diagrams, which present a clear view of the circuit status, gleaned from the noisy data signals collected during testing. It was from these state diagrams that the failure mode timelines and duration information were imported into the database. Each circuit is discussed below, along with the criteria for evaluating each conductor for specific failure modes.

4.1.1 1-inch valve control circuit

The 1-inch valve circuit that was tested is shown below in Figure 4-1. As seen in the figure, seven conductors were monitored during the test. From these seven conductors, the electrical measurement data were analyzed based on the information displayed in Table 4-1 and Table 4-2 for the penlight and intermediate-scale tests, respectively. There is a slight difference in the

logic for the penlight and intermediate-scale tests, due to the fact that the switches (normally open (NO) and normally closed (NC) contacts) on the G and R conductors had worn out during the penlight tests. Thus, the switches were both physically wired closed for all the intermediate-scale tests. This data processing effort has taken this into account.

For the 1-inch valve circuit, conductor S was the hot short (HS)/spurious operation (SA) target, and conductors G and R were the HS targets for the penlight tests. For intermediate-scale tests, conductor S was the HS/SA target, and conductors G and R were not used for fuse status. The SP conductor was a non-energized target that could either short to the positive or negative sides of the circuit for all tests. The other conductors were used to determine whether a fuse had blown. Once the positive or negative fuse had blown, the durations for the HS and/or HS/SA were assumed to be complete.




Figure 4-1. Line drawing of the dc-SIM panel layout for a 1-inch coil circuit

Note: The NO contact on the "R" conductors and the NC contact on the "G" conductor were wired closed for all intermediate-scale tests.

Table 4-1. Analysis logic for 1-in valve penlight tests

Conductor	Spurious Operation (Status 2)	Hot Short (Status 1)	Normal (Status 0)	Fuse Clear or Spare Conductor Short (Status -1)
P			$V_{P\text{Modified}} > 100V$	$V_{P\text{Modified}} < 10V$ [Positive Fuse Clear]
G		S=2 & $V_{G\text{Modified}} > 100V$ [Hot Short]	$V_{G\text{Modified}} > 100V$	
R		S≠2 & $V_{R\text{Modified}} > 100V$ [Hot Short]	$V_{R\text{Modified}} < 10V$	
S	$V_{S\text{Modified}} > 48 V$ [Hot Short-Induced Spurious Operation]		$V_{S\text{Modified}} < 48 V$	
N1			$V_{N1\text{Modified}} < 10V$	$V_{N1\text{Modified}} > 100V$ [Negative Fuse Clear]
N2			$V_{N2\text{Modified}} < 10V$	$V_{N2\text{Modified}} > 100V$ [Negative Fuse Clear]
SP		$V_{Sp\text{Raw}} > 30V$ [Short to Positive]	$V_{Sp\text{Raw}} \sim 0V$	$V_{Sp\text{Raw}} < -30V$ [Short to Negative]

Raw – voltage reference is ground

Modified – voltage level is approximately battery negative

Table 4-2. Analysis logic for 1-in valve intermediate-scale tests

Conductor	Spurious Operation (Status 2)	Hot Short (Status 1)	Normal (Status 0)	Fuse Clear or Spare Conductor Short (Status - 1)
P			$V_{P\text{Modified}} > 100V$	$V_{P\text{Modified}} < 10V$ [Positive Fuse Clear]
G			$V_{G\text{Modified}} > 100V$	$V_{G\text{Modified}} < 10V$ [Positive Fuse Clear]
R			$V_{R\text{Modified}} > 100V$	$V_{R\text{Modified}} < 10V$ [Positive Fuse Clear]
S	$V_{S\text{Modified}} > 48 V$ [Hot Short-Induced Spurious Operation]		$V_{S\text{Modified}} < 48 V$	
N1			$V_{N1\text{Modified}} < 10V$	$V_{N1\text{Modified}} > 100V$ [Negative Fuse Clear]
N2			$V_{N2\text{Modified}} < 10V$	$V_{N2\text{Modified}} > 100V$ [Negative Fuse Clear]
SP		$V_{Sp\text{Raw}} > 30V$ [Short to Positive]	$V_{Sp\text{Raw}} \sim 0V$	$V_{Sp\text{Raw}} < -30V$ [Short to Negative]

4.1.2 Large coil control circuit

The large coil circuit that was tested is shown below in Figure 4-2. As seen in the figure, there are seven conductors that were monitored during the test. For those seven conductors, the electrical measurement data was analyzed based on the information displayed in Table 4-3 for all tests. For this, circuit conductor S was the HS/SA target, and conductor R was an HS target for all tests. The SP conductor was a non-energized target that could either short to the positive or negative sides of the circuit for all tests. The other conductors were used to determine whether a fuse had blown. Once the positive or negative fuse had blown, the durations for the HS and/or HS/SA were assumed to be complete.




Figure 4-2. Line drawing for the dc large coil circuit

Table 4-3. Analysis logic for large coil penlight and intermediate-scale tests

Conductor	Spurious Operation (Status 2)	Hot Short (Status 1)	Normal (Status 0)	Fuse Clear or Spare Conductor Short (Status - 1)
P			$V_{PModified} > 100V$	$V_{PModified} < 10V$ [Positive Fuse Clear]
G			$V_{GModified} > 100V$	$V_{GModified} < 10V$ [Positive Fuse Clear]
R		$V_{RModified} > 60V$ [Hot Short]	$V_{RModified} < 60V$	
S	$V_{SModified} > 60 V$ [Hot Short-Induced Spurious Operation]		$V_{SModified} < 60 V$	
N1			$V_{N1Modified} < 10V$	$V_{N1Modified} > 100V$ [Negative Fuse Clear]
N2			$V_{N2Modified} < 10V$	$V_{N2Modified} > 100V$ [Negative Fuse Clear]
SP		$V_{SpRaw} > 30V$ [Short to Positive]	$V_{SpRaw} \sim 0V$	$V_{SpRaw} < -30V$ [Short to Negative]

4.1.3 dc MOV control circuit

The MOV circuit that was tested is shown below in Figure 4-3. As seen in the figure, there are seven conductors that were monitored during the test. Those seven conductors' electrical measurement data was analyzed based on the information displayed in Table 4-4 for all tests. Each test had two MOV circuits designated as MOV1 and MOV2. Conductors YO1 and YC1 for MOV1 were HS/SA and HS targets. With MOV1, there were mechanical interlocks that caused YC1 to lock out if YO1 was engaged; thus, if YO1 had an HS/SA while YC1 got an HS, YC1 would not engage. Conductors G and R were HS targets. The SP conductor was a non-energized target that could short to either the positive or the negative side of the circuit for all tests. The other conductors were used to determine whether a fuse had blown. Once the positive or negative fuse had blown, the durations for the HS and/or HS/SA were assumed to be complete.




Figure 4-3. Line drawing for dc MOV circuit

Table 4-4. Analysis logic for MOV penlight and intermediate-scale tests

Conductor	Spurious Operation (Status 2)	Hot Short (Status 1)	Normal (Status 0)	Fuse Clear or Spare Conductor Short (Status - 1)
G		$V_{YO1Modified} > 100V$ & $V_{GModified} > 100V$	$V_{GModified} > 100V$	
N			$V_{NModified} < 10V$	$V_{NModified} > 100V$ [Negative Fuse Clear]
P			$V_{PModified} > 100V$	$V_{PModified} < 10V$ [Positive Fuse Clear]
R		$V_{YO1Modified} > 100V$ & $V_{RModified} > 100V$	$V_{RModified} > 100V$	
YC1 (MOV1)	$V_{YC1Modified} > 89.3V$ & $I_{YC1} > 0.06A$	$YO1=2$ & $V_{YC1Modified} > 89.3V$	$V_{YC1Modified} < 10V$ & $V_{YO1Modified} < 10V$	
YC1 (MOV2)	$V_{YC1Modified} > 50.7V$ & $YO1 \neq 2$	$YO1=2$ & $V_{YC1Modified} > 50.7V$	$V_{YC1Modified} < 10V$ & $V_{YO1Modified} < 10V$	
YO1 (MOV1)	$V_{YO1Modified} > 29.0V$ & $I_{YO1} > 0.06A$	$YC1=2$ & $V_{YO1Modified} > 29.0V$	$V_{YC1Modified} < 10V$ & $V_{YO1Modified} < 10V$	
YO1 (MOV2)	$V_{YO1Modified} > 50.7V$ & $I_{YO1} > 0.06A$	$YC1=2$ & $V_{YO1Modified} > 50.7V$	$V_{YC1Modified} < 10V$ & $V_{YO1Modified} < 10V$	
SP		$V_{SpRaw} > 30V$ [Short to Positive]	$V_{SpRaw} \sim 0V$	$V_{SpRaw} < -30V$ [Short to Negative]

4.1.4 Small pilot SOV control circuit

The SOV circuit that was tested is shown below in Figure 4-4. As seen in the figure, there are seven conductors that were monitored during the test. Those seven conductors' electrical measurement data was analyzed based on the information displayed in Table 4-5 for all tests. For this circuit conductor, S2 was the HS/SA target, and conductor R was an HS target for all tests. The SP conductor was a non-energized target that could short to either the positive or the negative side of the circuit for all tests. The other conductors were used to determine whether a fuse had blown. Once the positive or negative fuse had blown, the durations for the HS and/or HS/SA were assumed to be complete.




Figure 4-4. Line drawing for dc SOV circuit

Table 4-5. Analysis logic for SOV penlight and intermediate-scale tests

Conductor	Spurious Operation (Status 2)	Hot Short (Status 1)	Normal (Status 0)	Fuse Clear or Spare Conductor Short (Status - 1)
P,G,S1			$V_{Modified} > 100V$	$V_{Modified} < 10V$ [Positive Fuse Clear]
N			$V_{NModified} < 10V$	$V_{NModified} > 100V$ [Negative Fuse Clear]
R		$V_{RModified} > 60V$ [Hot Short]	$V_{RModified} < 60V$	
S2	$V_{S2Modified} > 56.05V$		$V_{S2Modified} < 60V$	
SP		$V_{SpRaw} > 30V$ [Short to Positive]	$V_{SpRaw} \sim 0V$	$V_{SpRaw} < -30V$ [Short to Negative]

4.1.5 Medium-voltage circuit breaker dc control circuit

There were two different medium-voltage circuit breakers (SWGR) circuits used during DESIREE testing. As mentioned in the report, there was a problem with the first breaker during intermediate-scale Test #8. The first SWGR circuit is displayed in Figure 4-5, with the instrumentation's data analysis displayed in Table 4-6. The internal manufacturer wired this SWGR in reverse, which is depicted in Figure 4-5. The wiring did not affect the functionality of the SWGR, the only difference being that the red light was not energized. Table 4-6 has a different set-up than the tables for the previous circuits analyzed. The SWGR circuits were more complex to analyze, resulting in the different format. Conductors G, T, and C1 were hot short targets, while T and C1 were used to determine whether the breaker had tripped or closed (HS/SA target). The duration for the HS/SA was never more than one time step. Conductor R was treated as a energized spare. The two SP conductors were non-energized targets that could short to either the positive or the negative side of the circuit for all tests. The other conductors were used to determine whether a fuse had blown. Once the positive or negative fuse had blown, the durations for the HS and/or HS/SA were assumed to be complete. The second SWGR circuit is displayed in Figure 4-6, with the instrumentation's data analysis displayed in Table 4-7. The only difference with this SWGR in terms of the data analysis logic was that R was an HS target and not an energized spare. It is also noted in Table 4-6 and Table 4-7 that there were two cables tested for each SWGR test. One cable was connected to the close circuit, and the other was connected to the trip circuit. The conductors associated with each are identified in the tables.




Figure 4-5. Line drawing for dc SWGR 1 circuit




Figure 4-6. Line drawing for dc SWGR 2 circuit

Table 4-6. Analysis logic for SWGR penlight tests and intermediate-scale

	Conductor	Logic Statements (adjusted voltage used)	Notes
Close Cable	C1	If($V_{C1} < 10V$, "EtC", if($45V < V_{C1} < 75V$, "Floating," if $V_{C1} > 100V$, "HS," "HS or Floating"))	EtC means enable to close. If a fuse clears on the close circuit, this conductor state becomes Not_EtC (not enable to close). HS means hot short.
	PC	If($V_P > 100V$, "Normal," "Pos. Fuse Blown")	
	N1	If($V_{N1} < 10V$, "Normal," "Neg. Fuse Blown")	
Trip Cable	G	If($V_G < 10V$, "G_On", "G_Off")	If the green light is off and T is floating, then there is a hot short.
	R	If($V_R < 60V$, "HS," "Normal")	Internal wiring was reversed; R was treated as a hot spare.
	PT	If($V_{PT} > 100V$, "Normal," "Pos. Fuse Blown")	
	N2	If($V_{N2} < 10V$, "Normal," "Neg. Fuse Blown")	
	T	If($V_T < 10V$, "EtT", if($V_T > 100V$, "HS," "Floating"))	EtT means enable to trip. If a fuse clears on the trip circuit, this conductor state becomes Not_EtT (not enable to trip).
	SP1	If($V_{S1} < 30V$, "Short_to_-, " If($V_{S1} > 90V$, "Short_to_+," "Floating/Normal"))	
	SP2	If($V_{S2} < 30V$, "Short_to_-, " If($V_{S1} > 90V$, "Short_to_+," "Floating/Normal"))	
	Breaker Position	Breaker position was determined by analysis of the conductors' behavior, as well as of the experimental field notes. This was necessary because of the interdependencies between the trip and close circuits.	

Table 4-7. Analysis logic for SWGR intermediate scale tests 1, 3, 5, 6, 7, 8, 9, 10, Cont. 1, and Cont. 2

	Conductor	If Statements (adjusted voltage used)	Notes
Close Cable	C1	If($V_{C1} < 10V$, "EtC," if($45V < V_{C1} < 75V$, "Floating," if $V_{C1} > 100V$, "HS," "HS or Floating"))	EtC means enable to close. If a fuse clears on the close circuit, this conductor state becomes Not_EtC (not enable to close). HS means hot short.
	PC	If($V_P > 100V$, "Normal," "Pos. Fuse Blown")	
	N1	If($V_{N1} < 10V$, "Normal," "Neg. Fuse Blown")	
Trip Cable	G	If($V_G < 10V$, "G_On," "G_Off")	If the green light is off and T is floating, then there is a hot short.
	R	If($V_R < 10V$, "R_On," "R_Off")	If the red light is on and T is floating, then there is a hot short.
	PT	If($V_{PT} > 100V$, "Normal," "Pos. Fuse Blown")	
	N2	If($V_{N2} < 10V$, "Normal," "Neg. Fuse Blown")	
	T	If($V_T < 10V$, "EtT," if($V_T > 100V$, "HS," "Floating"))	EtT means enable to trip. If a fuse clears on the trip circuit, this conductor state becomes Not_EtT (not enable to trip).
	SP1	If($V_{S1} < 30V$, "Short_to_-," If($V_{S1} > 90V$, "Short_to_+," "Floating/Normal"))	
	SP2	If($V_{S2} < 30V$, "Short_to_-," If($V_{S1} > 90V$, "Short_to_+," "Floating/Normal"))	
	Breaker Position	Breaker position was determined by analysis of the conductors' behavior, as well as of the experimental field notes. This was necessary because of the interdependencies between the trip and close circuits.	

4.2 Conductor Count

The test data used to evaluate the effect cable conductor count has on failure modes included multi-conductor cables with 2-6, 7-9, and 10-15 conductors. Table 4-8 provides summaries of the dc test data, separated into these three conductor count ranges. These ranges were suggested by the electrical Phenomena Identification and Ranking Table (PIRT) expert panel. Figure 4-7 provides a graphical representation of this data.

Table 4-8. Conductor count, global approach, dc tests

Global Approach	1/C	2-6/C	7-9/C	10-15/C	>15/C
Fuse Clear	-	1	22	1	-
Hot Short	-	4	142	5	-
Spurious Operation	-	3	89	2	-
HS/SA Possible	-	5	164	6	-




Figure 4-7. Conductor count column plot, global approach, dc tests

These fire-induced cable failure mode plots provide little insight into how conductor count affects the likelihood of any one failure mode. This is partially due to the abundance of conductor count data available for 7/C cables, as well as the fact that the data shows consistent results among the three bins even with minimal data for the other two bins. Table 4-9 and Figure 4-8 provide dc test data for hot short and spurious operation durations, separated by these same conductor count ranges.

Table 4-9. Conductor count, duration data, dc tests

	Hot Short					Spurious Operation				
	1/C	2-6/C	7-9/C	10-15/C	>15/C	1/C	2-6/C	7-9/C	10-15/C	>15/C
q1	-	101.5	14	18	-	-	203.5	10	105	-
min	-	1	1	7	-	-	193	1	105	-
median	-	193	47	63	-	-	214	31	105	-
max	-	1082	8545	2873	-	-	235	6417	105	-
q3	-	265	254	242	-	-	224	80	105	-
mean	-	302	409	471	-	-	214	195	105	-




Figure 4-8. Conductor count box plot, duration, dc tests

4.3 Thermal Exposure Conditions

This section presents the dc data evaluated by thermal exposure conditions' effects on fire-induced failure modes. The thermal exposure conditions include flame, hot gas layer (HGL), plume, and radiant conditions. The flame, hot gas layer, and plume data are from the intermediate-scale testing, while the radiant test data are from the Penlight (small-scale) radiant testing. These thermal exposure conditions are discussed in more detail in Section 2.3. Table 4-10 provides summaries of the dc test data failure mode evaluation by thermal exposure conditions, while Figure 4-9 presents this information graphically.

Table 4-10. Thermal exposure conditions, global approach, dc tests

Global Approach	Flame	Plume	HGL	Radiant
Fuse Clear	9	3	5	7
Hot Short	43	25	13	70
Spurious Operation	26	11	5	52
HS/SA Possible	52	28	18	77




Figure 4-9. Thermal exposure conditions column plot, global approach, dc tests

The failure mode data indicates that the HGL exposure data is an outlier compared to the other exposure conditions. The HGL test data shows a lower likelihood of experiencing a spurious operation (28%) and a higher chance of having the circuit protective fusing clear (28%). It is interesting to note that it was believed that the Penlight radiant exposure simulated an HGL exposure, due to the high radiative heat transfer that occurs in a sooty HGL. This assumption may be accurate for comparisons of the thermal conditions, but the failure mode data does not show this relation. This data tends to indicate that fire-induced cable failure modes do not follow this same logic, and, more specifically, that the radiant failure mode likelihood data is similar to the plume and flame exposure condition failure mode results. This may be due to the high intensity of the radiant exposure.

Table 4-11 and Figure 4-10 present the dc test's hot short and spurious operation duration data, separated by thermal exposure conditions. The data shows a weak trend (based on the median of the data) for shorter duration hot shorts in flame and radiant exposures as opposed to HGL exposure, with the plume exposure durations lying somewhere in the middle. There is a similar trend in the ac test data results (Section 2.3).

Table 4-11. Thermal exposure conditions, duration data, dc tests

	Hot Short				Spurious Operation			
	Flame	Plume	HGL	Radiant	Flame	Plume	HGL	Radiant
q1	16.4	27.5	57.95	12	13	10.7	34.8	10
min	2	2	7	1	3	3.4	26	1
median	40	154	115	43	34	20.6	70	31
max	2873	2590	4871	8545	124	198.4	115	6417
q3	119.2	740	714	210	66.7	60.5	90.0	98.3
mean	61.6	468.7	587.8	428.4	45.1	146.6	111.9	301.0




Figure 4-10. Thermal exposure conditions box plot, duration, dc tests

4.4 Raceway Routing

The two raceway routing configurations used during testing were open ladder-back cable trays and rigid steel conduit configurations that were tested in DESIREE-FIRE. The dominant use of ladder-back cable tray configurations makes it difficult to determine the effects that these configurations have on cable failure. A summary of these results is shown in Table 4-12 and Figure 4-11. The data evaluated shows no difference in failure mode between cable tray and conduit configurations for dc circuits.

Table 4-12. Raceway routing, global approach, dc tests

Global Approach	Conduit	Tray
Fuse Clear	4	20
Hot Short	18	133
Spurious Operation	13	81
HS/SA Possible	22	153




Figure 4-11. Raceway routing column plot, global approach, dc tests

Table 4-13 and Figure 4-12 present the data that was evaluated for raceway routing against hot short and spurious operation durations. The interquartile range, shown in Figure 4-12, is wider for the hot short durations than for the spurious operation durations, with the median for hot shorts being about 13-17 seconds longer.

Table 4-13. Raceway routing, duration data, dc data

	Hot Short		Spurious Operation	
	Conduit	Tray	Conduit	Tray
q1	14.1	16.0	16.4	10.0
min	1	1	3	1
median	56	50	39	33.5
max	2804	8545	431	6417
q3	278.5	255	87	90
mean	405.8	408.8	80.8	212.0




Figure 4-12. Raceway routing box plot, duration, dc tests

4.5 Cable Orientation

DESIREE-FIRE only tested cables in the horizontal orientation; thus, no comparison can be made on this parameter for dc circuits.

4.6 Raceway Fill

The dc test data was evaluated based on the raceway fill conditions (single, medium, partitioned) and their effect on the failure mode. The single cable raceway fill configurations are shown below in Figure 4-13. Most of this single-fill data came from the Penlight tests, with a few data points coming from the intermediate-scale tests. If two single cables were in a raceway (e.g., Figure 4-14, Fill Tray H), it was also considered a single cable fill. Cables next to a partitioned cable group but separate (e.g., Bundle Trays D & H), as shown in Figure 4-15 with the single cable off to the right, were also considered single cables for this specific analysis. Besides the few instances mentioned above, all fill trays represented in Figure 4-14 and Figure 4-16 were analyzed as medium-fill, and the fill trays represented in Figure 4-15 were analyzed as partitioned cable tray raceway fill. In Section 2.6, bundles represent cable groups held together by tie wraps. Tie wraps were not used in the dc testing to group cables together; instead, thin steel right-angle plates were connected to the cable tray rungs.



Figure 4-13. Circuit cable orientation within the cable trays for single fill




Figure 4-14. Circuit cable orientation for filled trays




Figure 4-15. Circuit cable orientation for partitioned trays




Figure 4-16. Circuit cable orientation for specialized trays

Table 4-14 provides summaries of the dc failure mode test data, separated by raceway fill type. The graphical representation of this data is shown in Figure 4-17. As shown in these figures, there is not a significant effect on failure modes based on raceway fill configurations. One observation of note is the slightly lower likelihood of experiencing a spurious operation in the partitioned tray configuration. However, this was not observed in the medium-full configurations, making it difficult to explain this result as the shielding effect of the other cables surrounding the monitored cables.

Table 4-14. Raceway fill, global approach, dc tests

Global Approach	Partitioned	Medium	Single
Fuse Clear	8	6	10
Hot Short	35	39	77
Spurious Operation	16	21	57
HS/SA Possible	43	45	87




Figure 4-17. Raceway fill column plot, global approach, dc tests

The duration data was also evaluated against the raceway fill configurations. The analysis results are shown below in Table 4-15 and Figure 4-18. No trend was identified for the duration data based on raceway fill.

Table 4-15. Raceway fill, duration data, dc tests

	Hot Short			Spurious Operation		
	Bundle	Medium	Single	Bundle	Medium	Single
q1	31	17.6	12.6	14.4	13	10.2
min	2	2	1	3	2	1
median	115	42	46	34	35	31
max	4871	2873	8545	198	124	6417
q3	675	124	240.5	73.6	82.5	97.2
mean	530	219	444	53	47	289




Figure 4-18. Raceway fill box plot, duration, dc tests

4.7 Insulation Type

The insulation type parameter separates insulation materials into two categories of polymer types, thermoset (TS) and thermoplastic (TP). Table 4-16 provides a breakdown of how insulation materials are classified by insulation type. Table 4-17 and Figure 4-19 present the failure mode test data separated by cable conductor insulation type, TS and TP. Section 4.8 provides information on failure characteristics based on insulation materials, and Section 4.9 presents the data segregated by insulation and jacket type combinations.

Table 4-16. Breakdown of insulation material by type, dc tests

Thermoset Materials (TS)	Thermoplastic Materials (TP)
EPR – ethylene propylene rubber	PE – polyethylene
FR-Kerite – Flame Retardant Kerite™	PVC – polyvinyl chloride
XLPE – cross-linked polyethylene	TEF – Tefzel
XLPO – cross-linked polyolefin	

Table 4-17. Global approach - insulation type - dc tests

Global Approach	TP	TS
Fuse Clear	16	7
Hot Short	48	99
Spurious Operation	36	55
HS/SA Possible	64	106




Figure 4-19. Insulation type column plot, global approach, dc tests

The data indicates that insulation type has little effect on the likelihood of spurious operation, but has a minor effect on the likelihood of experiencing a fuse clear failure. Here the TS insulation has a lower likelihood of experiencing a fuse clear (7%), and, thus, a higher likelihood of experiencing a hot short than a TP-insulated cable. Once again, as was shown in the ac test results, there is no difference between cable insulation types relative to the likelihood of experiencing a spurious operation.

The insulation type data was used to determine its effect on failure mode durations, which is shown below in Table 4-18 and Figure 4-20. The TP-insulated cables showed slightly longer hot short and spurious operation duration, based on the median and inter-quartile range.

Table 4-18. Insulation type, duration data, dc tests

	Hot Short		Spurious Operation	
	TP	TS	TP	TS
q1	23.3	12.8	27.5	5.0
min	1	1	1	1
median	79	42	90	22
max	6417	8545	6417	1195
q3	372.8	212.2	142.6	36.8
mean	476	376	420	57




Figure 4-20. Insulation type box plot, duration, dc tests

4.8 Insulation Material

The next cut-set evaluates the different types of cable insulation materials. The cable insulation materials used during the dc testing were ethylene propylene rubber (EPR), cross-linked polyethylene (XLPE), flame-retardant kerite™ (FR-Kerite), polyethylene (PE), polyvinyl chloride (PVC), and Tefzel™ (TEF), which can also be separated into TS and TP materials. These materials were analyzed for a better understanding of their effects on cable failure modes, as shown in Table 4-19. This data is presented graphically in Figure 4-21. The data suggests that conductors insulated with PE or PVC have a higher likelihood (20% and 17%, respectively) of experiencing a fuse clear failure than the other materials. It is interesting to note that both PE and PVC are TP materials, and that TEF, another TP material, experienced zero fuse clear failures, while the TS material also experienced a low number of fuse clear failures (~6%).

Table 4-19. Insulation material, global approach, dc tests

Global Approach	TS			TP		
	EPR	XLPE	Kerite-FR	PE	PVC	TEF
Fuse Clear	1	4	1	15	1	0
Hot Short	17	66	15	35	5	8
Spurious Operation	5	41	8	26	4	6
HS/SO Possible	18	70	16	50	6	8




Figure 4-21. Insulation material column plot, global approach, dc tests

This data set was analyzed with the failure durations summarized in Table 4-20 and displayed in Figure 4-22. The data shows that the PVC- and EPR-insulated cables have a very short duration; however, only a limited number of PVC cables were tested (6 total).

Table 4-20. Insulation material, duration data, dc tests

	Hot Short					Spurious Operation				
	TS		TP			TS		TP		
	EPR	XLPE	PE	PVC	TEF	EPR	XLPE	PE	PVC	TEF
q1	7.3	12.3	33.9	1.3	17	3.9	10	28	1	425
min	1	1	1	1	2	3	1	10	1	91
median	53	38	95	13	72	5	23	90	1	759
max	724	4871	6417	84	1433	34	115	6417	1	1427
q3	149	115	676	28.8	290	9.5	37	124	1	1093
mean	146	289	575	22	293	10	28	409	1	759




Figure 4-22. Insulation material box plot, duration, dc tests

4.9 Insulation-Jacket Type Combinations

The test data was next evaluated based on the combination of cable insulation and jacket types. There are three combinations identified from the data, namely (1) thermoplastic-insulated, thermoplastic-jacketed, (2) thermoset-insulated, thermoset-jacketed, and (3) thermoset-insulated, thermoplastic-jacketed. Table 4-21 provides summaries of the dc test data, divided into these three categories. This information is displayed in column plots in Figure 4-23, which shows that when TS-TS cables are compared to TP-TP cables, the failure mode likelihood data is similar to the results obtained from the comparison of the insulation type. It is probable and logical that insulation material is the dominant influencing factor for the failure mode likelihood.

The TS-TP category comprises a single cable type, namely, the armored cable provided through the NRC-RES/EPRI Memorandum of Understanding (MOU). The failure modes show a high likelihood of experiencing a spurious operation and hot short. These results are consistent with industry testing of armored cable. The high percentage of spurious operation and hot shorts is a result of an ungrounded power supply and electrical interactions with the armor during fire-induced failure.

Table 4-21. Insulation-jacket type, global approach, dc tests

Global Approach	TP-TP	TS-TS	Armored (TS-TP)
Fuse Clear	16	6	0
Hot Short	48	70	12
Spurious Operation	36	41	9
HS/SA Possible	64	76	12




Figure 4-23. Insulation-jacket type column plot, global approach, dc tests

The durations for the hot shorts and spurious operations for the jacket types were evaluated using the global approach. The data is presented in Table 4-22 with the box plots shown in Figure 4-24. Similar to what was shown in the insulation type analysis of Section 4.7, the TP-TP material cables show longer duration than the TS-TS cables. The mechanism for this phenomenon is unclear to the authors, but it may be the insulation polymer material's sequence of physical thermal degradation.

Table 4-22. Insulation-jacket type, duration data, dc tests

	Hot Short			Spurious Operation		
	TP-TP	TS-TS	Armored (TS-TP)	TP-TP	TS-TS	Armored (TS-TP)
q1	23.3	14	19.8	27.5	9	4.8
min	1	1	1	1	1	4
median	79	42	39	90	24	21
max	6417	8545	2590	6417	1195	42
q3	372.8	255.8	182	142.6	37	37.5
mean	476	429	298	420	73	22




Figure 4-24. Insulation-jacket type box plot, duration, dc tests

4.10 Wiring Configuration

The test data used to evaluate the wiring configuration effects on failure modes included five types of configurations. These configurations are shown in Table 4-23, identifying the number of source, target, and common return conductors within a test cable, along with the associated circuit type.

Table 4-23. dc test data wiring configurations

	# Sources	# Targets	# Returns	dc Circuit
Configuration 1	2	4	1	MOV
Configuration 2	2	3	1	N/A
Configuration 3	2	2	1	N/A
Configuration 4	3	3	1	SOV
Configuration 5	2	3	2	1-IN & LG COIL
Configuration 6	1	1	1	SWGR - C
Configuration 7	1	5	1	SWGR - T

Table 4-24 provides summaries of the dc test data, divided into the different types of configurations. This information is shown graphically in Figure 4-25. Configuration 6 had zero fuse clears, and configuration 7 had the highest percentage of fuse clears. Configuration 1 had the highest percentage (61%) of spurious operations, while configuration 6 had the lowest (41%). Configuration 7 had the lowest percentage of hot shorts (65%), as well as the lowest source-to-target ratio (1:5).

Table 4-24. Wiring configuration, global approach, dc tests

Global Approach	Config. 1	Config. 4	Config. 5	Config. 6	Config. 7
Fuse Clear	4	7	5	0	8
Hot Short	50	35	29	22	15
Spurious Operation	33	19	19	9	14
HS/SA Possible	54	42	34	22	23




Figure 4-25. Wiring configuration column plot, global approach, dc tests

This data set was analyzed to determine wiring configuration influence on hot short duration. This is shown below in Table 4-25 and Figure 4-26. It should be noted that the durations for spurious operations for configurations 6 and 7 are not calculated, as mentioned above. Since these are the close and trip circuits of the switchgear, the duration is less than a second, and is never continuous; therefore, it is not relevant to this analysis. Configuration 6 had a significantly longer median for hot short duration.

Table 4-25. Wiring configuration, duration data, dc tests

	Hot Short					Spurious Operation				
	Config. 1	Config. 4	Config. 5	Config. 6	Config. 7	Config. 1	Config. 4	Config. 5	Config. 6	Config. 7
q1	11	17.5	13.2	35.2	8.9	10.8	23	7	N/A	N/A
min	1	1	1	2	1	1	3	1	N/A	N/A
median	37	59	46.5	176	76	33.5	37	13	N/A	N/A
max	8545	724	1143	4871	1397	6417	198.4	1052	N/A	N/A
q3	173.2	96.2	121.8	1085.8	709	96.0	69.6	90	N/A	N/A
mean	405	110	195	736	351	286	53	129	N/A	N/A




Figure 4-26. Wiring configuration box plot, duration, dc tests

4.11 Conductor Size

The test data was used to evaluate the effect that conductor size has on failure modes (12 AWG vs. 14 AWG). Table 4-26 provides summaries of the dc test data, divided into the different conductor sizes. The majority of the test data is for 12 WG cables, with only 8% being of the 14 AWG variety. The global approach does not result in any significant differences among failure modes as a result of cable conductor size. Figure 4-27 provides the graphical representation of the failure mode characteristics for cable conductor size.

Table 4-26. Conductor size, global approach, dc tests

Global Approach	12 AWG	14 AWG
Fuse Clear	23	1
Hot Short	138	13
Spurious Operation	86	8
HS/SA Possible	161	14




Figure 4-27. Conductor size column plot, global approach, dc tests

Table 4-27 and Figure 4-28 display the data that was analyzed based on conductor size for failure mode durations. The data shows that the 14 AWG cables experience longer-lasting hot shorts and spurious operations, which is based on a limited set of data for the 14 AWG cables.

Table 4-27. Conductor size, duration data, dc tests

	Hot Short		Spurious Operation	
	12 AWG	14 AWG	12 AWG	14 AWG
q1	14	20.8	11	15.5
min	1	1	1	1
median	47	194	33	193
max	6417	8545	6417	1195
q3	211.2	898.5	80	270.5
mean	355	965	186	280




Figure 4-28. Conductor size box plot, duration, dc tests

4.12 Circuit Type

This cut-set separates the test data by circuit type (MOV, SOV, SWGR, 1-inch, and Large Coil). These circuits are explained above in Section 4.1. Table 4-28 presents the data for the circuit type's effect on failure mode occurrence. Figure 4-29 presents this data graphically.

The MOV and 1-inch valve circuits show a higher likelihood for spurious operation at 76% than the SOV, switchgear, and large coil circuit at 55%, 51%, and 53%, respectively. No specific mechanism for this has been identified. Circuit type has no significant bearing on the likelihood of fuse clears and hot shorts.

Table 4-28. Circuit type, global approach - dc tests

Global Approach	MOV	SOV	SWGR	1-inch	Large Coil
Fuse Clear	4	7	8	2	3
Hot Short	50	35	37	15	14
Spurious Operation	33	19	23	12	7
HS/SA Possible	54	42	45	17	17




Figure 4-29. Circuit type column plot, global approach, dc tests

The circuit types were also evaluated to determine whether circuit type had an effect on failure mode durations. This information is displayed below in Table 4-29 and Table 4-30, and is shown graphically in Figure 4-30. It should be noted that in Table 4-30 the duration for SWGR spurious operations were not analyzed for this data set because the duration of a breaker tripping or closing in only about one time step in data collection would skew the duration data. Hot short duration is unaffected by the circuit design, and the durations of hot shorts have been reviewed. The switchgear and large coil circuits have the longest median hot short durations (136.5s and 71.5s respectively). The large coil has the longest median spurious operation duration (52s), while the 1-inch coil has the shortest median spurious operation duration (13s). No specific mechanism for this has been identified.

Table 4-29. Circuit type hot short only, duration data, dc tests

	Hot Short				
	MOV	SOV	SWGR	1-inch	Large Coil
q1	11	17.5	32.2	11.0	21.5
min	1	1	1	1	3
median	37	59	136.5	33	75.5
max	8545	724	4871	855	1143
q3	173.2	96.2	1082.8	91.5	124
mean	405	110	695	154	239

Table 4-30. Circuit type spurious operation only, duration data, dc tests

	Spurious Operation				
	MOV	SOV	SWGR	1-inch	Large Coil
q1	10.8	23	N/A	9.8	4.3
min	1	3	N/A	1	3
median	33.5	37	N/A	12.5	90
max	6417	198.4	N/A	811	1052
q3	96	69.6	N/A	37.2	111
mean	286	53	N/A	90	197




Figure 4-30. Circuit type box plot, duration, dc tests

4.13 Fuse Size

The effects of fuse size on failure mode likelihood and duration were evaluated at the request of the PIRT panel. Although this evaluation only slightly differentiated the data from the previous evaluation based on the circuit type, the PIRT panel thought that the effects of fuse size on failure mode and duration could be significant and warranted an evaluation here. The dc testing data is the only data that was binned by fuse size, and there were four (4) fuse sizes used in the circuits tested in the dc testing program (DESIREE-FIRE). Table 4-31 presents the failure mode data, and Figure 4-31 presents the information from the tables in column plots.

The data for the 35A and 15A fuse bins are entirely from the switchgear circuit and the trip and close portions of that circuit, respectively. The 35A bin is an outlier, based on its lack of fuse clear failures and lower likelihood of spurious operation (41%). The lack of fuse clear failures is likely a result of finite insulation impedance during fire-induced failures, limiting the fault current enough that it doesn't exceed the fuse clear limits.

Table 4-31. Global approach, fuse size, dc tests

Global Approach	35A	15A	10A	5A
Fuse Clear	0	8	7	9
Hot Short	22	15	64	50
Spurious Operation	9	14	40	31
HS/SA Possible	22	23	71	59




Figure 4-31. Fuse size column plot, global approach, dc tests

The effects of fuse size on duration are presented in Table 4-32, and a box plot is provided in Figure 4-32 to graphically illustrate this information. There is a clear trend (based on median and inter-quartile range) indicating that, as the fuse size decreases, so does the duration of the hot shorts and spurious operations.

Table 4-32. Fuse size, duration data, dc tests

	Hot Short				Spurious Operation			
	35A	15A	10A	5A	35A	15A	10A	5A
q1	35.2	8.9	12	12.3	0	0	10	12
min	2	1	1	1	0	0	1	1
median	176	76	42	43	0	0	36	33
max	4871	1397	8545	855	0	0	6417	811
q3	1085.8	709	171.8	96	0	0	98.5	64
mean	736	351	382	123	0	0	273	68




Figure 4-32. Fuse size, duration, box plot

4.14 Cable Shielding

This section evaluates the effect a cable shield has on the failure modes of electrical cable exposed to damaging thermal conditions. As it is only intended to evaluate the shield, all armored cable data has been removed from this analysis. Table 4-33 and Figure 4-33 present the failure mode likelihood data in tabular and graphical form. The results of this analysis show no significant difference for the global approach based on cable shielding.

Table 4-33. Cable shielding, global approach, dc tests

Global Approach	Shield	No Shield
Fuse Clear	2	22
Hot Short	10	141
Spurious Operation	6	88
HS/SA Possible	12	163




Figure 4-33. Cable shielding, global approach, dc tests

The effects of shielding on hot short durations are presented below in Table 4-34 and Figure 4-34. This comparison doesn't present any characteristics that differentiate the length of hot short durations among cables with or without shields.

Table 4-34. Cable shielding, duration data, dc tests

	Hot Short		Spurious Operation	
	Shield	No Shield	Shield	No Shield
q1	18	14	80.9	10.8
min	1	1	9	1
median	161	47	149	32
max	2873	8545	235	6417
q3	268.5	252	203.5	82.5
mean	398	409	135	198




Figure 4-34. Cable Shielding box plot, duration, dc tests

4.15 dc concurrence of hot shorts

Concurrence of hot shorts, as discussed in this report, occur when more than one circuit (or cable) experiences individual hot shorts at the same time (i.e., concurrence). The intermediate-scale tests performed in DESIREE-FIRE consisted of 12 tests, which included six to seven dc circuits per test. This section documents how the test results were analyzed to identify times when hot short-induced spurious operations occurred concurrently.

The DESIREE-FIRE project tested five different types of dc surrogate circuits: solenoid-operated valves (SOVs), motor-operated valves (MOVs), 1-inch valve solenoids, large coils similar in size to a power-operated relief valve, and a medium-voltage circuit breaker, referred to as switchgear (SWGR). The testing included two SOV and two MOV circuits, resulting in a total of eight circuits (SOV-1, SOV-2, MOV-1, MOV-2, 1-inch valve, large coil, and switchgear trip and close circuits). Most circuits were included in every intermediate-scale test. Since these are the most realistic fire exposure conditions, this information has the most applicability to plant configuration.

Table 4-35 presents a listing of the four tests in which concurrent spurious operations occurred. Note that this analysis differs from what was done in the ac concurrent hot short review, since only circuits in an individual test are evaluated for concurrence. In the review of ac concurrent hot shorts, all circuits in a specific fire location (A-G) were analyzed for every test.

Table 4-35. Listing of concurrent spurious operations during intermediate-scale dc testing

Test #	Circuit Experiencing Concurrent SA	Duration of individual SA (seconds)	Duration of Concurrent SA (seconds)	Cable Physical Location	Cable Insulation Type
5	SOV-2	211	3	D	TP
	SOV-1	12		B in Conduit	TP
5	SOV-2	211	16	D	TP
	dc MOV-1 Open	16		B in Conduit	TP
6	1-inch valve	89	1	C	TP
	SWGR-Close	1		B in Conduit	TP
6	1-inch valve	89	1	C	TP
	SWGR-Trip	1		B in Conduit	TP
8	Large coil	123	90	A	TP
	SOV-1	90		A	TP
8	Large coil	123	9	A	TP
	dc MOV-1 close	95		A	TP
9	SOV-1	112	7	B	TS
	dc MOV-1 close	7		B	TS
9	SOV-1	112	1	B	TS
	dc MOV-1 close	1		B	TS

The following discussion provides additional information related to the individual concurrent hot shorts in each test identified in Table 4-35. The plots that follow identify the circuit, times of failure, and concurrence duration of the hot short. The figures show the start of a hot short, represented as a diamond, while the squares indicate the end and the black lines represent the duration of a hot short. The information on the horizontal axis of the figure indicates the circuit-naming convention:

- test series (D = DESIREE)
- testing scale (IT = Intermediate)
- test number
- the circuit that experienced the hot short




Figure 4-35. Time plot of concurrent hot shorts for DESIREE-FIRE intermediate-scale test 5

Figure 4-35 depicts the dc hot short concurrence between SOV-2, SOV-1, and MOV-1 for intermediate-scale test #5. It is important to note the physical location of the cables because thermal exposure conditions can influence the timing of cable failure. The SOV-2 cable is located in position D (upper plume), while the SOV-1 and MOV-1 cables are both located in a conduit in position B (lower plume). As referenced in Table 4-36, SOV-2 and SOV-1 have a concurrent spurious operation duration of three seconds, while SOV-2 and MOV-1 have a concurrent spurious operation duration of 16 seconds. Figure 4-36 provides the temperature profile for the two cable locations that experienced concurrent hot shorts.




Figure 4-36. Plot of intermediate-scale test 5 for MOV and SOV cable locations

To summarize the data presented in Figure 4-36 and Table 4-35, intermediate-scale test #5 experienced two concurrent hot shorts among three circuits; the cables are physically located in Location D and Location B (inside the conduit). All of the cable insulation is thermoplastic. Figure 4-36 plots temperature versus time for MOV and SOV cable locations in intermediate-scale test #5. According to Figure 4-36, the cables located in the B Position fail at approximately 600 °C, whereas the cable located in the D Position fails at approximately 630 °C. This indicates the importance of understanding thermal exposure conditions and the effect that they have on concurrent failure timing. Although the cables are in different locations, each has a similar temperature profile, which is why they failed at approximately the same time.




Figure 4-37. Concurrent hot shorts - test 6

Figure 4-37 depicts the dc hot short concurrence between the 1-inch valve circuit and switchgear circuits for intermediate-scale test #6. There are two data points for the SWGR circuits since one is for the close function and the other for the trip function. The 1-inch valve cable is located in position C (hot gas layer), while the switchgear close and trip cables are both located inside a conduit at position B (lower plume). As referenced in Table 4-35, the 1-inch valve and switchgear (close) circuits have a concurrent spurious operation duration of one second, as do the 1-inch valve and switchgear (trip) circuits.




Figure 4-38. Plot of intermediate-scale test 6 for 1-inch valve and switchgear cable locations

To summarize the data presented in Figure 4-37 and Table 4-35 intermediate-scale test #6 experienced two concurrent hot shorts among three circuits; the cables are physically located in Locations C and B inside the conduit. All of the cable insulation is thermoplastic. Figure 4-38 plots temperature versus time for intermediate-scale test #6 for 1-inch valve and switchgear cable locations. According to the plot, cables located in B Position fail at approximately 460 °C, whereas the cable located in C Position fails at approximately 340 °C. Both of these temperatures fall within the typical range of cable failures for this cable type. This plot provides an analytical representation of the importance of cable location and the thermal exposure conditions due to the HGL effects.

Circuit	Time		Duration	Detail
	SA Start	SA End		
<i>D-IT-8-LrgCl</i>	940	1063	123	Cable S
<i>D-IT-8-SOV1</i>	960	1050	90	S2
<i>D-IT-8-MOV1</i>	1054	1149	95	Closed Coil




Figure 4-39. Concurrent hot shorts - test 8

Figure 4-39 depicts the dc circuit hot short concurrence between Large Coil, SOV-1, and MOV-1 for intermediate-scale test #8. In the case of the two concurrent hot shorts observed in this test, all circuit cables were located in Position A (flame exposure). As referenced in Table 4-35, large coil and SOV-1 have concurrent spurious operation durations of 90 seconds, while the large coil and MOV-1 have concurrent spurious operation durations of nine seconds. All of the cable insulation is thermoplastic. Given that all of the cables are located in A, in the flame, this is consistent with the concurrent failure timing because all cables are experiencing similar thermal insult.




Figure 4-40. Concurrent hot shorts - test 9

Figure 4-40 depicts the dc hot short concurrence as falling between SOV1 and MOV1 for intermediate-scale test #9. In this test, all cables involved in the concurrent hot shorts were located in the same tray, namely Position B (lower plume). As referenced in Table 4-35, SOV1 and MOV1 have concurrent spurious operation durations of seven seconds, while SOV1 and MOV1 have concurrent spurious operation durations of one second. All of the cable insulation is thermoset. Given that all of the cables are located in B, in the plume; this is consistent with the concurrent failure timing as a result of being exposed to similar thermal insults.

5. INTER-CABLE DIRECT CURRENT CIRCUITS

5.1 Traditional Inter-Cable Failure Analysis for DESIREE-FIRE Results

As was done in other testing projects, the Direct Current Electrical Shorting in Response to Exposure Fire (DESIREE-FIRE) project attempted to evaluate inter-cable interactions using multiple methods. To explicitly explore this failure mode, an inter-cable test configuration was used. In addition, the data (voltage and current measurements) from the surrogate circuits could be analyzed post-test to evaluate inter-cable shorting behavior.

The inter-cable test configuration used during the DESIREE-FIRE testing focused on arranging the cables to evaluate the likelihood of proper polarity in inter-cable shorting. These tests stacked the deck by placing the cables on an insulated marinite board located in a cable tray and having multiple source cables surrounding a single target cable. This configuration is shown in Figure 5-1, with a target cable co-located in the center of the arrangement and two positive source cables and two negative source cables located on the side and above a target cable. The target cable conductors were all connected to a network of resistors and monitored for voltage response only (no current transducers were used). Each source conductor was powered by one side of a nominal 125Vdc battery and protected with a 10-amp fuse.




Figure 5-1. DESIREE-FIRE inter-cable configuration

Thirteen intermediate-scale and four penlight tests were conducted using the five-cable inter-cable arrangement shown above. Of those tests, only one showed weak signs of multiple external shorts to separate conductors within the target cable. This particular case is shown in Figure 5-2, where the maximum induced voltage difference is roughly 20Vdc. In all other tests, the data shows that internal faults occurred prior to inter-cable faulting of the target cable.




Figure 5-2. DESIREE-FIRE inter-cable test results penlight #47

The second method involved reviewing the voltage and current data from individual tests. Inter-cable short circuit failures involve conductors of separate cables coming in electrical contact with each other due to fire damage. When analyzing the data for these types of failures, voltage and current traces are needed to understand which conductors are involved (i.e., voltage alone will not provide sufficient information to identify source and target conductors). In addition, knowledge of fuse operability is beneficial so that potential sources can be ruled out following the clearing of these protective devices. The direct current (dc) test circuits all had two fuses, one on the positive battery side and one on the negative battery side of the circuit. When a circuit's positive battery side fuse cleared, it could no longer be considered a potential source; likewise, when its negative fuse cleared, its target conductors could no longer be considered targets (i.e., hot shorts to active and passive devices could no longer occur). However, if only one of the two circuit fuses cleared, then the circuit could still experience inter-cable shorting faults that could cause spurious operations.

The small-scale penlight tests were simpler to evaluate for inter-cable shorting because there were typically no more than two circuits in any individual test. The intermediate-scale testing, however, used all seven circuits (eight energized cables), along with the inter-cable testing configuration. The larger number of circuits provided additional source and target conductor shorting opportunities, and complicated the evaluation of the inter-cable shorting events.

The ungrounded battery supply also provided complications in analyzing the data for inter-cable shorting. If the dc battery is ungrounded, which is common practice in U.S. nuclear power plants (NPPs), a single short to ground from a positively or negatively energized conductor would not cause a fuse to clear in and of itself. To have a fuse clear either a plus or a minus, a conductor-to-conductor short would be required, or multiple shorts to a ground plane (plus and minus) of sufficiently low resistance to result in over current, either of which would clear a circuit

protective device. However, because the dc circuit had two fuses per circuit, one on the positive side and one on the negative side, the fuses would not always clear simultaneously. Thus, in about half of the cases, only one fuse in a particular circuit would clear at any time. This single-fuse clearing would eliminate the possibility of intra-cable shorting, but the side of the circuit whose fuse did not clear would still be functional from an inter-cable shorting perspective. For example, if circuit A experienced a low-resistance short when its positive side fuse cleared, but its negative fuse remained intact, then this circuit could still experience a short from another conductor in another cable, which could lead to a spurious operation if the respective conductors shorted together.

The purpose of this lengthy discussion is to identify a unique failure mode that has not been observed thus far in the associated testing. With a common ungrounded power supply, the ground plane (cable trays, conduit, and ground conductors) can act as an electrical conductive pathway to aid in inter-cable shorting. This observation results in the need to analyze hot shorts and spurious operations more closely to identify the failure mode type (inter- or intra-cable). In alternating current (ac) tests, the control power transformer (CPT) was typically grounded (as is done in the majority of U.S. NPPs), and any energized conductor experiencing a low-resistance short to the reference ground (due to fire damage) would experience a high-current rush, resulting in the clearing of an upstream protective device (fuse or circuit breaker) and the de-energizing of the circuit.

To aid in identifying inter-cable shorting, a simple yet beneficial approach was taken. For an individual circuit (MOV-1, SOV-2, Lg Coil, etc.), the current within that circuit was summed, that is, the currents coming from the positive battery terminal were added and the currents returning to the negative battery terminal were subtracted. Figure 5-3 and Equation 5-1 provide the graphical and mathematical representations of this approach. Under normal conditions, Kirchoff's current law states that the currents within a circuit sum up to zero. This law also holds under intra-cable-only circuit failures, in that the current within the circuit/cable remains inside the cable, and the sum is equal to zero. However, when inter-cable interactions occur, the current from one circuit leaves the electrical circuit and enters another; thus, for the inter-cable case, the individual circuit currents do not sum up to zero, and there is a net current (negative if the circuit is receiving currents from some other circuit, positive if the circuit is supplying currents to some other circuit).




Figure 5-3. dcMOV schematic showing current summation used in identifying inter-cable shorting behavior

$$i_{sum_dcMOV} = i_P + i_G + i_R - (i_{YC1} + i_{YO1} + i_N) \quad \text{Equation 5-1}$$

Although this method provides an efficient tool to quickly identify which circuits were involved in inter-cable shorting, there are a few drawbacks. First, this method only shows which circuits were involved, and not which conductors. To compensate for this, the analyst must review the data from the respective circuits and determine which conductors were involved. Secondly, in the intermediate-scale testing, the inter-cable circuit was included, but it was not monitored for current. Thus, in some cases the analysis could not identify the source of the inter-cable short, although it can be assumed that the source was the inter-cable circuit. Thirdly, there were a few circuits (small SOVs in particular) that had a very low operating current (0.042A) when energized. Although they were typically discernible in the analysis, they were not as apparent as the other circuits' inter-cable shorts. Fourthly, there may be cases where a circuit is leaking current and gaining current from other circuits simultaneously; these interactions can cancel each other out, and can lead to difficulties in identifying the inter-cable short. Lastly, there were several cases where a single circuit shorted abruptly to the common ground plane and caused several circuit protective devices to clear without direct indication of which circuit initiated the event. It is assumed that because there were multiple simultaneous fuse clears, there was a very abrupt current spike, followed by fuse clearing, which the data acquisition system (DAQ) was unable to capture.

As a result of these aspects, the analysis for this section is focused on identifying spurious operations that resulted from inter-cable (cable-to-cable) shorting. There were some cases where it was possible to determine how individual circuit fuses cleared via inter-cable shorting; that information is noted in the summary tables. At this time, an evaluation of inter-cable hot shorting of the passive targets has not been conducted, mainly due to the low-level currents required to energize these devices and the complications associated with the auxiliary contacts and reed switches used to control the passive target sources.

The following two sections present the inter-cable analysis of the surrogate circuit data for the small-scale Penlight and intermediate-scale open-flame tests. Due to the number of circuits used in the intermediate-scale testing and the use of actual flaming combustions, those results are analyzed in more detail than they are in the penlight tests, where only two circuits were co-located within the same cable tray. The intermediate-scale results also show unique failures in which cables located within a rigid steel conduit interact with other cables located in cable trays at different locations.

5.2 Penlight Tests – Ground Fault Equivalent Hot Short

Penlight tests for the DESIREE-FIRE project typically consisted of two cables, each connected to an individual circuit. The only exception for this type of configuration was the medium-voltage circuit breaker test, where two cables were connected to one circuit. In all tests using a cable tray, the cables were not in physical contact with anything except the cable tray. A cable instrumented for thermal response was typically placed between the two cables instrumented for electrical response, as shown in Figure 5-4. Thus, any inter-cable interactions are a direct result of cable interactions with the cable tray. In conduit tests, the two electrically monitored cables may be in physical contact, and a more detailed evaluation of any inter-cable interactions is necessary.




Figure 5-4. Penlight cable tray typical loading, showing two electrically instrumented cables and a thermal response (temperature recording) cable located in the center.

The Penlight results of the ground equivalent hot shorting analysis are documented in Appendix A. A summary of this analysis is presented here in Table 5-1.

Table 5-1. Results of inter-cable shorting during Penlight DESIREE-Fire tests.

Test #	Failure Mode Description
PT-8	MOV-2 hot short to "R" conductor from MOV-1 "P" conductor at 478 seconds (duration = 3 seconds).
PT-12	Interactions between MOV-1 "N" conductor and MOV-2 "P" conductor. This is a case of a high-resistance short between conductors connected to positive and negative battery potential.
PT-22	Four separate ground fault equivalent spurious operations occurred in this test. MOV-1 Open coil SA for 2 seconds, short from MOV-2 "G" conductor (starts at 585s) MOV-1 Open coil SA for 2 seconds, short from MOV-2 "G" conductor (starts at 589s) MOV-1 Open coil SA for 40 seconds, short from MOV-2 "G" conductor (starts at 593s) MOV-2 Open coil SA for 38 seconds, short from MOV-1 "G" conductor (starts at 595s)
PT-33	Interactions between MOV-1 "P" conductor and MOV-2 "N" and "YC" conductors (No SA or HS occur).
PT-37	MOV-2 Close coil SA for 16 seconds, short from MOV-1 "G" conductor to MOV-2 "YC" conductor.
PT-41	Two separate ground fault equivalent spurious operations occurred in this test. MOV-2 Close coil SA for 6 seconds, short from MOV-1 "G" conductor to MOV-2 "YC" conductor (starts at 2753s) MOV-1 Open coil SA for 1 second, short from MOV-2 "G" conductor to MOV-1 "YO" Interactions between MOV-1 "P" conductor and MOV-2 "N" conductor were also observed for approximately 9 seconds, starting at 2825 seconds.
PT-49	MOV-2 Open coil SA for <1 second, source is difficult to identify due to other conductor interactions among cable trays.
PT-50	MOV-2 Close coil SA for 22s, short from MOV-1 "G" conductor to MOV-2 "YC" conductor. Inter-cable interactions also cause a fuse clear on MOV-2 circuit.
PT-JPN3	False indication on MOV-1 Red lamp ON, due to inter-cable shorting with MOV-2.
PT-20	SOV-2 SA for 20 seconds, short from SOV-1 "G" conductor (starts at 508s).
PT-28	SOV-2 SA for 297seconds, short from SOV-1 "P" conductor (starts at 3393s).
PT-31	False indication on SOV-2 Green lamp ON, due to inter-cable shorting with SOV-1.
PT-11	Two separate ground equivalent hot shorts were observed in this test. Large coil SA for 52 seconds, short from 1-inch valve "G" and "R" conductors 1-inch valve SA for 798 seconds, short from large coil "P" conductor
PT-40	Large coil SA for 64 seconds, short from 1-inch valve "G" and "R" conductors (starts at 4100s).
PT-4	SWGR-trip SA (breaker opens), short from SWGR-Close "N1" conductor.
PT-JPN2	False indication Red lamp ON, inter-cable interaction between SWGR-Trip "R" conductor and SWGR-Close "N1" conductor.

5.3 Intermediate-Scale Tests – Ground Fault Equivalent Hot Short

5.3.1 Preliminary Test #1

Figure 5-5 presents an illustration of the test set-up for preliminary test #1. Location A contains fill cable that is represented by the gray area located within the cable tray, and is located directly above the fire source (200 kW propene diffusion sand burner). Location B contains two cables connected to the switchgear trip and close coil circuitry, location C contains two cables connected to two separate ac surrogate circuit diagnostic units (SCDUs), location D contains the inter-cable test configuration of cables, and location E contains two cables connected to the 1-inch valve and the large coil. During testing, the openings in the hood in which the cable trays and conduits are located are enclosed with a ceramic fiber material to develop and maintain a hot gas layer that is sufficient to damage the cables. The illustration does not show ceramic fiber.




Figure 5-5. Intermediate-scale test preliminary 1 cable loading configuration

Table 5-2 presents the failure mode sequence of events of preliminary test #1. The ac SCDU and inter-cable testing results are not discussed. Cables in location E did not fail during the test.

Table 5-2. Intermediate-Scale Preliminary Test #1

Time (s)	Failure Observation
502	SWGR-C SA
504	SWGR-C Fuse Clear – Positive
515	SWGR-T Fuse Clear – Negative
540	SWGR-C Fuse Clear – Negative (<i>INTER-CABLE with SWGR-T cond. 'P'</i>)
	NOTE: 1-inch valve and Lg Coil circuit did not fail max temp (~380 °C for both TS cables)

5.3.2 Preliminary Test #2

Figure 5-6 and Table 5-3 provide an illustration of the intermediate-scale layout and a summary of the test circuit failure sequence, respectively. Bold font is used to identify inter-cable interactions. Figure 5-7 presents the summed current plots for all circuits in this test. This plot indicates that MOV-2 open coil experiences an inter-cable hot short-induced spurious operation from SOV-2. Although the cables associated with MOV-2 and SOV-2 are in the same cable tray, they are not in physical contact with each other; thus, the only means for this interaction is by ground plane equivalent hot short failure mode. In this specific spurious operation, conductors “S1,” “P,” and “G” of the SOV-2 circuit are supplying power to the MOV-2 open coil contact conductor.




Figure 5-6. Intermediate-scale test preliminary 2 cable loading configuration

Table 5-3. Intermediate-Scale Preliminary Test #2

Time (s)	Failure Observation
312	SOV-1 Fuse Clear – Positive
343	MOV-1 Fuse Clear – Positive & Negative
820 – 1221	MOV-2 SA Open Coil INTER-CABLE shorting with SOV-2 conductor S1, P, G
888 – 1221	MOV-2 HS Close Coil (likely from inter-cable)
953 – 1020	SOV-2 SA (voltage but no corresponding current – unlikely an SA per SNL report)
1020	SOV-2 Fuse Clear – Negative
1221	MOV-2 Fuse Clear – Negative
1221	SOV-2 Fuse Clear – Positive




Figure 5-7. Intermediate-Scale Test Preliminary 2 – Inter-cable shorting between SOV-2 and MOV-2

5.3.3 Test 1

Figure 5-8 and Table 5-4 present an illustration of the intermediate-scale cable layout and the circuit response summary information, with inter-cable interactions shown in boldface type. Figure 5-9 provides an indication that the 1-inch valve circuit experienced interactions with the large coil and MOV-1 circuits. Upon closer review of the test data, it was determined that conductor “P” of the 1-inch valve circuit energized the conductor “S” of the large coil circuit, causing an inter-cable spurious operation. Shortly after the large coil spurious operation cleared, MOV-1 conductor YO1 on the open coil was energized by the same “P” conductor of the 1-inch valve circuit, causing spurious operation on the MOV-1 circuit. The 1-inch valve source conductor “P” energized two individual conductors in different cables and separate raceways. In addition, review of the ground fault circuitry measurements indicates that the positive side of the battery was grounded during these interactions. These results provide a clear indication that the ground plane was involved during both inter-cable hot shorts.




Figure 5-8. Intermediate-scale test 1 cable loading configuration

Table 5-4. Intermediate-Scale Test #1

Time (s)	Failure Observation
1361-1377	1-inch Valve SA
1375	SOV-1 Fuse Clear – Negative
1382 – 1384	1-inch Valve SA
1396	1-inch Fuse Clear – Negative
1449	Lg Coil SA <i>INTER-CABLE from 1-inch valve conductor P via Ground</i>
1452	Lg Coil SA <i>INTER-CABLE from 1-inch valve conductor P via Ground</i>
1460 – 1463	Lg Coil SA <i>INTER-CABLE from 1-inch valve conductor P via Ground</i>
1467	Lg Coil Fuse Clear – Negative
1475 – 1558	MOV-1 SA Open Coil <i>INTER-CABLE from 1-inch valve conductors P and G via Ground</i>
1516 – 1558	MOV-1 HS Close Coil
1558	MOV-1 Fuse Clear – Negative
1560	1-inch Valve Fuse Clear – Positive
2196	SWGR-C Fuse Clear – Negative
2269	MOV-1 Fuse Clear – Positive
2295	SOV-1 Fuse Clear – Positive
2512-2523	SOV-2 SA
2617 – 2661	MOV-2 HS Close Coil
2649	SOV-2 Fuse Clear – Positive & Negative
2654 – 2661	MOV-2 SA Open Coil
2663	MOV-2 Fuse Clear – Positive & Negative
2934	Lg Coil Fuse Clear – Positive
3938 – 4028	SWGR-T HS




Figure 5-9. Outstanding current hot shorting for Intermediate-Scale Test #1 between 1-inch valve, large coil, and MOV-1 circuits

5.3.4 Test 2

Table 5-5 presents the circuit failure chronologically. No inter-cable hot shorts occurred during this test. However, the cause of the fuse clear on SOV-2 is a result of inter-cable shorting between the SOV-2 and MOV-2 cables. These two cables were located in the same cable tray in the middle of the tray cable fill (see Figure 5-10). Review of the ground fault circuit data indicates that the battery negative was shorted to ground prior to the SOV-2 fuse clear. Thus, it is likely that the “N” conductor in SOV-2 shorted to ground initially, followed by MOV-2’s “P” conductor shorting to ground, resulting in an increased current, which would have caused the fuse in SOV-2 to clear. The current summation plot showing these interactions is presented in Figure 5-11.




Figure 5-10. Intermediate-scale test 2 cable loading

Table 5-5. Intermediate-Scale Test #2

Time (s)	Failure Observation
1030-1109	SOV-2 SA
1116 - 1142	MOV-2 HS Close
1145 - 1152	MOV-2 HS Close
1145 - 1152	MOV-2 HS Open
1156 - 1175	MOV-2 HS Close
1156 - 1173	MOV-2 HS Open
1164	SOV-2 Fuse Clear – Positive and Negative Due to INTER-CABLE shorting with MOV-2 conductor P via Gnd
3909-3977	SOV-1 SA
3979	SOV-1 Fuse Clear – Negative
3975	1-inch Valve Fuse Clear – Positive
4247 - 4362	MOV-1 SA Open
4492	Lg Coil Fuse Clear - Negative




Figure 5-11. Outstanding current shorting in Intermediate-Scale Test #2, between SOV-2 and MOV-2

5.3.5 Test 3

Three circuits were involved in inter-cable hot shorting during Intermediate-Scale Test #3. Figure 5-12 illustrates the cable loading arrangement, and Table 5-6 provides a circuit fault summary for Intermediate-Scale test 3. SOV-2 experienced two spurious operations as a result of an inter-cable hot short from the Switchgear Trip circuit cable located in a conduit. Because the switchgear cables were isolated from the other cables by their location in a conduit, the only possible way for this shorting to occur was through the ground plane. Figure 5-13 provides the current sum method plot showing the SOV-2 and switchgear circuit interactions.

Following the SOV-2 spurious operations, the 1-inch valve circuit also experienced two spurious operations. Upon review of the voltage and current data, both 1-inch valve spurious operations were also caused by inter-cable shorting through the ground plane from the switchgear trip circuit. Figure 5-14 provides the current sum method plot showing the 1-inch valve and switchgear interaction.




Figure 5-12. Intermediate-scale test 3 cable loading

Table 5-6. Intermediate-Scale Test #3

Time (s)	Failure Observation
1078 – 1090	MOV-2 SA Open Coil
1097 – 1128	MOV-2 SA Open Coil
1108	MOV-2 HS Close Coil
1111 – 1113	MOV-2 HS Close Coil
1127	MOV-2 HS Close Coil
1130	MOV-2 Fuse Clear – Positive
1168	MOV-2 Fuse Clear – Negative
1262	SOV-2 Fuse Clear – Positive
1361 – 1363	SOV-2 SA INTER-CABLE from SWGR-T conductor P via Ground
1375 – 1406	SOV-2 SA INTER-CABLE from SWGR-T conductor P via Ground
1419	SOV-2 Fuse Clear – Negative
1460 – 1468	SWGR-C SA
1468	SWGR-C Fuse Clear Positive and Negative
2188 – 2221	1-inch Valve SA INTER-CABLE from SWGR-T conductor P via Ground
2226 – 2229	1-inch Valve SA INTER-CABLE from SWGR-T conductor P via Ground
2231	1-inch Valve Fuse Clear – Negative
2286	1-inch Valve Fuse Clear – Positive
2288	Lg Coil Fuse Clear – Positive & Negative INTER-CABLE SWGR-T conductor PT
2784 – 2787	MOV-1 SA Open Coil
2787	MOV-1 SA Fuse Clear – Positive and Negative
3066	SOV-1 Fuse Clear – Positive and Negative




Figure 5-13. Outstanding current shorting in Intermediate-Scale Test #3, between SOV-2 and SWGR-T




Figure 5-14. Outstanding current shorting in Intermediate-Scale Test #3, between 1 inch valve and SWGR-T

5.3.6 Test 4

No inter-cable spurious operations were observed during this test. Figure 5-15 provides a cable loading illustration, and Table 5-7 provides the chronology of circuit failures. The fuse clearing for the 1-inch valve circuit and the large coil circuit were caused by inter-cable shorting from the inter-cable circuit.




Figure 5-15. Intermediate-scale test 4 cable loading

Table 5-7. Intermediate-Scale Test #4

Time (s)	Failure Observation
1530	1-inch valve Fuse Clear – Positive
1585	SOV-1 Fuse Clear – Positive – inter-cable with 1-inch valve conductor N
1671	Lg coil Fuse Clear – Positive <i>INTER-CABLE shorting from 1-inch valve conductor “N”</i>
1671	1-inch valve Fuse Clear – Negative <i>INTER-CABLE shorting from Lg coil conductor “G”</i>
1859 – 1895	MOV-1 SA Open Coil
1895	MOV-1 Fuse Clear – Positive and Negative
4766	SWGR-C Fuse Clear – Positive and Negative
4974	MOV-2 Fuse Clear – Positive and Negative
5216 – 5249	SOV-2 SA
5249	SOV-2 Fuse Clear – Positive and Negative
5305	SOV-1 Fuse Clear – Negative
5307	Lg coil Fuse Clear – Negative

5.3.7 Test 5

Figure 5-16 provides intermediate-scale test 5 cable loading, while Table 5-8 presents the circuit failure mode information in chronological order. As shown in Figure 5-17, SOV-1 experienced an inter-cable hot short at 1637 seconds from the SWGRS WGR-T circuit, which resulted in a spurious operation of the SOV-1 circuit. Conductor “PT” of the switchgear trip circuit shorted to ground, as did the SOV-1 coil conductor “S.” These two cables were located in different areas of the enclosure, and SOV-1 was actually located in a rigid steel conduit. Thus, these interactions required the ground plan. No other inter-cable spurious operations were identified.




Figure 5-16. Intermediate-scale test 5 cable arrangement

Table 5-8. Intermediate-Scale Test #5

Time (s)	Failure Observation
655	1-inch valve Fuse Clear – Negative
819 – 908	Lg Coil SA
908	1-inch Valve Fuse Clear – Positive
910	Lg Coil Fuse Clear – Negative and Positive
1424-1429	SWGR-C SA Close
1429	SWGR-C Fuse Clear – Positive
1500 – 1573	MOV-2 Hot Short Close Coil
1510 – 1532	MOV-2 Hot Short Open Coil
1542 – 1573	MOV-2 Hot Short Open Coil
1556	SOV-1 Fuse Clear – Positive
1575	MOV-2 Fuse Clear – Positive and Negative
1596	SWGR-C Fuse Clear – Negative
1637 – 1649	SOV-1 SA INTER-CABLE shorting from SWGR-T conductor PT
1646 – 1658	SOV-2 SA

Table 5-8. Intermediate-Scale Test #5

Time (s)	Failure Observation
1651	SOV-1 Fuse Clear – Negative
1667 – 1857	SOV-2 SA
1859	SOV-2 Fuse Clear – Negative
2255	SOV-2 Fuse Clear – Positive
1717 – 1734	MOV-1 SA Open Coil
1717 – 1734	MOV-1 HS Close Coil
1734	MOV-1 Fuse Clear – Positive and Negative




Figure 5-17. Outstanding current shorting in Intermediate-Scale Test #5, between SOV-1 and SWGR-T

5.3.8 Test 6

No inter-cable hot shorts resulted in spurious operation of any device in intermediate-scale test 6. Figure 5-18 illustrates the cable loading and arrangement for intermediate-scale test 6. Table 5-9 presents the summary of circuit failure modes in chronological order. There were several inter-cable interactions observed in the data set involving the MOV-2 circuit fuses clearing as a result of inter-cable shorting with the SOV-2 and SWGR-T circuits. There were also several current spikes in several circuit data plots, which were a result of inter-cable shorting. Although MOV-2 and SOV-2 were collocated in the same raceway, the switchgear circuit was in a different location, and shorting via the ground plane was likely the cause of these interactions.




Figure 5-18. Intermediate-scale test 6 cable arrangement

Table 5-9. Intermediate-Scale Test #6

Time (s)	Failure Observation
191	SOV-2 Fuse Clear – Negative
230	MOV-2 Fuse Clear – Negative <i>INTER-CABLE with SOV-2</i>
850	SWGR-T SA [Breaker Open]
1168	SOV-2 Fuse Clear – Positive
1170	MOV-2 Fuse Clear – Positive <i>INTER-CABLE with SWGR-T conductor N2</i>
1317	Lg Coil Fuse Clear – Positive and Negative
1400 – 1502	SOV-1 SA
1480 – 1507	MOV-1 SA Close Coil
1534 – 1567	Short between SOV-1 conductor G and SWGR-C conductor N1
1567	SOV-1 Fuse Clear – Positive and Negative
1548 – 1637	1-inch Valve SA
1603-1607	SWGR-C SA [Breaker Close]
1603-1607	SWGR-T SA [Breaker Open]
1638	1-inch Valve Fuse Clear – Negative
1728	SWGR-C and SWGR-T Fuse Clear – Negative

5.3.9 Test 7

No inter-cable hot shorts were identified in intermediate-scale test 7. Figure 5-19 and Table 5-10 provide the cable loading configurations and summarize the circuit failure modes in chronological order. Ground plane influences can be associated with the concurrent fuse

clearing of MOV-1, MOV-2, and SOV-2 1286 seconds into the test. At this point, the battery transitioned from being grounded on its positive side to being grounded on its negative side.




Figure 5-19. Intermediate-scale test 7 cable arrangement

Table 5-10. Intermediate-Scale Test #7

Time (s)	Failure Observation
302 – 363	SOV-1 SA
324	MOV-1 Fuse Clear – Negative
363	SOV-1 Fuse Clear – Positive and Negative
466	SOV-2 Fuse Clear – Negative
535	MOV-2 Fuse Clear – Negative
1095	SWGR-T SA [Breaker Open]
1258	SWGR-C Fuse Clear – Negative
1286	MOV-1 Fuse Clear – Positive
1286	MOV-2 Fuse Clear – Negative
1286	SOV-2 Fuse Clear Positive
1388	SWGR-T Fuse Clear – Negative
1426	Lg Coil Fuse Clear – Negative
1713 – 1762	1-inch Valve SA
1762	1-inch Valve Fuse Clear – Negative

5.3.10 Test 8

Figure 5-20 shows the cable loading configuration for intermediate-scale test 8 while Table 5-11 contains the failure mode summary information, presented in chronological order. One inter-cable hot short was observed, which resulted in the spurious operation of MOV-1 close coil. This short occurred when the G conductor of the large coil cable came into electrical contact

with close coil conductor YC1 of the MOV-1 circuit via a ground path. Figure 5-21 shows the unbalanced current profiles for large coil and MOV-1. Note that these two cables were located adjacent to each other in the same cable tray in location A, “flame exposure region.” Review of the ground fault circuit data indicates that the positive side of the battery shorted to ground at approximately 900 seconds and remained grounded for the duration of the test.




Figure 5-20. Intermediate-scale test 8 cable arrangement

Table 5-11. Intermediate-Scale Test #8

Time (s)	Failure Observation
900	1-inch Valve Fuse Clear – Negative
943 – 1060	Lg Coil SA
960 – 1052	SOV-1 SA
1052	SOV-1 Fuse Clear – Positive and Negative
1052 – 1149	MOV-1 SA Close Coil INTER-CABLE with Lg Coil conductor G via ground
1060	Lg Coil Fuse Clear – Negative
1149	MOV-1 Fuse Clear – Negative
1743	MOV-2 Fuse Clear – Negative
2354	SOV-2 Fuse Clear – Positive and Negative




Figure 5-21. Outstanding current shorting in Intermediate-Scale Test #8, between MOV-1 and Lg Coil

5.3.11 Test 9

Figure 5-22 presents the cable loading configuration for intermediate-scale test 9, and Table 5-12 provides the chronological order of the failure modes identified during this test. Three inter-cable spurious operations were observed during this test. MOV-2 open coil went through spurious operation for 24 seconds via inter-cable shorting from conductors “G” and “P” of the large coil circuit. Note that these two cables are set in different locations in the hood: MOV-2 is in location D, while the large coil circuit is in the cable tray immediately below in Location B. At 1552 seconds into the test, the SOV-2 circuit experienced an inter-cable spurious operation from the same source conductors as MOV-2 (namely conductors “G” and “P” from the large coil circuit). This spurious operation lasted for 28 seconds. Again, both cables involved in the shorting were set in different cable tray locations. The third and final inter-cable spurious operation occurred when the MOV-1 close coil actuated after being energized by the switchgear trip circuit. This spurious operation lasted for 16 seconds. In this case, the cables involved were located in the same cable tray and were not adjacent to each other, but were separated by a fill cable.




Figure 5-22. Intermediate-scale test 9 cable arrangement

Table 5-12. Intermediate-Scale Test #9

Time (s)	Failure Observation
628 – 638	1-inch Valve SA
765	Lg Coil Fuse Clear – Negative
765	1-inch Valve Fuse Clear – Positive and Negative
1253 – 1277	MOV-2 SA Open Coil <i>INTER-CABLE shorting with Lg Coil conductors G & P via ground</i>
1278	MOV-2 Fuse Clear – Negative
1552 – 1580	SOV-2 SA <i>INTER-CABLE shorting with Lg Coil conductors G & P via ground</i>
1583	SOV-2 Fuse Clear – Negative
1602	Lg Coil Fuse Clear – Positive – Short w/SWGR-T cond. N2 via ground
1604	SOV-2 Fuse Clear – Positive – Short w/SWGR-T cond. N2 via ground
1605	MOV-2 Fuse Clear – Positive – Short w/SWGR-T cond. N2 via ground
1920	SWGR-C Fuse Clear – Positive
2420	SWGR-C Fuse Clear – Negative – Short w/SOV-1 cond. P via ground
2584 – 2696	SOV-1 SA
2611 – 2627	MOV-1 SA Close Coil <i>INTER-CABLE shorting with SWGR-T conductor P via ground</i>
2638	MOV-1 Fuse Clear – Negative
2699	SOV-1 Fuse Clear – Positive and Negative – Short w/SWGR-T cond. P

5.3.12 Test 10

The cable configuration used in intermediate-scale test 10 is shown in Figure 5-23, and the chronological order of the cable failures is presented in Table 5-13. The results show that there were three spurious operations and one hot short as a result of ground fault equivalent shorting. In all four instances, the source of the interactions could not be identified; however, this test configuration has the inter-cable testing configuration in location A, directly above the fire. This experimental set-up likely caused the inter-cable source conductors (which were not monitored for current) to short to the ground plane and aid in the four cases of inter-cable shorting.

The first inter-cable spurious operation involved the MOV-2 close coil. It actuated at 2798s for 37 seconds, and the cable associated with this circuit was set in location B, directly above location A, where the inter-cable test configuration was located. The second inter-cable spurious operation occurred in location C and involved the MOV-1 open coil, which actuated at 3579s for 15 seconds.




Figure 5-23. Intermediate-scale test 10 cable loading

Table 5-13. Intermediate-Scale Test #10

Time (s)	Failure Observation
2502	SOV-2 Fuse Clear – Negative
2635 – 2644	1-inch Valve SA
2646	1-inch Valve Fuse Clear – Positive and Negative
2798 – 2835	MOV-2 SA Close Coil INTER-CABLE unknown source – likely inter-cable test circuit
2890	Lg Coil Fuse Clear – Positive and Negative
3108	SWGR-T SA [Breaker Open]
3177	SWGR-C Fuse Clear – Positive
3236	SWGR-C Fuse Clear – Negative
3579 – 3594	MOV-1 SA Open Coil

Table 5-13. Intermediate-Scale Test #10

Time (s)	Failure Observation
	<i>INTER-CABLE unknown source – likely inter-cable test circuit</i>
3594 – 3646	MOV-1 SA Close Coil <i>INTER-CABLE unknown source – likely inter-cable test circuit</i>
3594 – 3605	MOV-1 HS Open Coil <i>INTER-CABLE unknown source – likely inter-cable test circuit</i>
3646	SOV-2 Fuse Clear – Positive
3646	SOV-1 Fuse Clear – Positive and Negative
3646	MOV-1 Fuse Clear – Positive

The inter-cable interactions that occurred during intermediate-scale test #10 could not be linked to any of the circuits that monitored current. Thus, these inter-cable interactions are likely a result of interactions from the inter-cable circuit, which was not equipped with current-monitoring transducers. These inter-cable interactions occurred in the MOV-2 and MOV-1 circuits.

5.3.13 Test 11

Intermediate-scale test 11 experienced one inter-cable ground equivalent hot short. Figure 5-24 illustrates the cable loading configuration for test 11, and Table 5-14 presents the chronological fault mode sequence. The SOV-2 circuit went through spurious operation 2858s into the test, and was powered by the “P” conductor of the large coil circuit. This interaction is shown in Figure 5-25, where the large coil circuit is supplying power (positive current) and the SOV-2 circuit is absorbing power (negative current). The cables that are connected to this circuit are located in different exposure locations; SOV-2 is in location D, directly above the large coil cable in location B. The different locations and a review of the ground fault detection circuit response, which shows that the battery positive shorted to ground at approximately 1440 seconds, indicate that this inter-cable interaction is a result of ground equivalent hot shorting.




Figure 5-24. Intermediate-scale test 11 cable loading

Table 5-14. Intermediate-Scale Test #11

Time (s)	Failure Observation
1179 – 1197	MOV-1 SA Open Coil
1182 – 1197	MOV-1 HS Close Coil
1197	MOV-1 Fuse Clear – Positive and Negative
1310 – 1312	1-inch Valve SA
1319 – 1323	1-inch Valve SA
1429	1-inch Valve Fuse Clear – Negative
1432	Lg Coil SA
1437	Lg Coil Fuse Clear – Negative
1569	SOV-1 Fuse Clear – Positive and Negative
2749	MOV-2 Fuse Clear – Negative – short with Lg Coil cond. P & G
2858 – 2917	SOV-2 SA <i>INTER-CABLE shorting from Lg Coil conductors P</i>
2917	SOV-2 Fuse Clear – Negative
3351	MOV-2 Fuse Clear – Positive
3352	SOV-2 Fuse Clear – Positive




Figure 5-25. Intermediate-Scale Test #11 Current Summation

5.3.14 Test 12

The cable loading configuration for this test is shown in Figure 5-26. Intermediate-scale test 12 experienced four inter-cable hot short-induced spurious operations. The source of the first two spurious operations could not be identified, and, due to the location of the inter-cable test configuration (location A), it is likely that the source came from this circuit. The other possible source is a 35A +/- cable that was used to evaluate the response of the high-current transducers. The current transducers did not pick up any current measurements; however, the laboratory had difficulties getting these high-current transducers to function properly, so, although it is unlikely that the 35A +/- cable was the source of the inter-cable interactions, the lack of reliable data for the large 500A current transducers does not completely rule out the 35A +/- cable. Fuses of the inter-cable circuit cleared at approximately 3125 seconds. After this time, the remaining two inter-cable spurious operations occurred, and the source cables for these interactions could be identified. The last piece of information that pointed to the inter-cable test cables being the source of the first two inter-cable spurious operations was that the inter-cable test configuration was located in Location A, as was done in intermediate-scale test 10, which also experienced inter-cable shorting that could not identify the source cables. From all of these observations, it is highly probable that the source cable for the first two inter-cable shorting events is from the inter-cable test configuration in location A.




Figure 5-26. Intermediate-scale test 12 cable loading

Current summation plots are presented in Figure 5-27(a-d) for each of the inter-cable spurious operations. As shown in Figure 5-27(a) and (b), there is no source current in these plots from any of the surrogate circuits. Figure 5-27(c) and (d) show the source current from the 1-inch and large coil circuits, respectively. It is interesting to note that in Figure 5-27(d), the large coil cable is shorting via the ground to MOV-1 and 1-inch valve circuit, but no spurious operation results.




Figure 5-27. Intermediate-Scale Test 12 Current Summation Plot

Table 5-15 presents the circuit failure mode summary for intermediate-scale test 12. The first inter-cable ground fault equivalent hot short-induced spurious operation involved the energization of the MOV-2 close coil. The MOV-2 circuits-associated cable is in Location B, while the probable source (the inter-cable test configuration) is located directly below in Location A. Even if the 35A +/- cable is the source, it is located in a different tray than the MOV-2 circuit, specifically in location C in the hot gas layer exposure. The next inter-cable spurious operation

involves the large coil circuit at 2746 seconds. This cable is located at the highest exposure position in the plume (location D). The probable source cable is the inter-cable test configuration located in the flame exposure, Location A.

For the last two instances of spurious operation, it was possible to identify the source cables. The third ground equivalent hot short-induced spurious operation involved the 1-inch valve cable providing the source power to energize the large coil. In this case, both cables are in location D, and are located adjacent to each other (they make physical contact). The interactions between the ground plane and the battery potentials, as shown in Figure 5-28, indicate that this failure is associated with ground-plane interactions, so it is unlikely that this spurious operation was a cable-to-cable failure, and more likely that it was a ground equivalent hot short-induced spurious operation.

Table 5-15. Intermediate-Scale Test #12

Time (s)	Failure Observation
2233 – 2340	MOV-2 SA Close Coil <i>INTER-CABLE unknown source (not from 35A +/- cable)</i>
2314	SOV-2 Fuse Clear – Negative
2343	MOV-2 Fuse Clear – Positive and Negative
2540	SOV-2 Fuse Clear – Positive
2746 – 2797	Lg Coil SA <i>INTER-CABLE unknown source (not from 35A +/- cable)</i>
2901 – 2939	Lg Coil SA <i>INTER-CABLE 1-inch Valve conductor R via ground</i>
2939	1-inch Valve Fuse Clear – Positive
3031	MOV-1 Fuse Clear – Positive
3129	1-inch Valve Fuse Clear – Negative – shorting with Lg Coil
3131 – 3136	SOV-1 SA <i>INTER-CABLE Lg Coil conductor P via ground</i>
3141	SOV-1 Fuse Clear – Positive and Negative
3143	Lg Coil SA
3146 – 3154	Lg Coil SA
3155	Lg Coil Fuse Clear – Positive




Figure 5-28. Ground Fault Detection Voltage Response for Second Lg Coil SA

5.3.15 Contingency test A

Contingency test A evaluated the anti-pump circuit of the medium-voltage switchgear and only two cables co-located in the same cable tray (location B) connected to the trip and close circuitry. This test's cable loading configuration is shown in Figure 5-29, and a summary of the failure behavior is provided in Table 5-16. There were no inter-cable hot short-induced spurious operations observed during this test.




Figure 5-29. Intermediate-scale test contingency A cable loading configuration

Table 5-16. Intermediate-Scale Contingency Test #A

Time (s)	Failure Observation
	Note: Breaker is closed, and jumper is installed between C1 (close coil) and PC (positive power conductor); this is to evaluate anti-pump ckt
406	SWGR-T SA [Breaker open]
408	SWGR-C SA (self-induced due to jumper) [Breaker closed]
409	SWGR-T SA [Breaker open]
423	SWGR-C Fuse Clear – Negative

5.3.16 Contingency test B

Contingency test B is a repeat of contingency test A. The experimental set-up is the same as before, and is shown in Figure 5-29 above. Table 5-17 provides the circuit failure mode summary, indicating that no inter-cable hot short-induced spurious operations were observed during this test.

Table 5-17. Intermediate-Scale Contingency Test #B

Time (s)	Failure Observation
337	SWGR-T Fuse Clear – Negative
354	SWGR-C Fuse Clear – Positive
458	SWGR-C Fuse Clear – Negative

5.3.17 Intermediate Scale – Inter-cable shorting conclusions

Table 5-18 summarizes the failure modes for each test by breaking down the initial failure mode into an intra-cable short, a ground fault equivalent short, or a fuse clear. The table identifies the number of each failure type, and also lists the circuits that experienced those failures immediately below the number.

Table 5-18. Summary of initial failure mode for inter-cable test circuits

Test #	Intra-cable SA	Inter-cable SA (Gnd equivalent SA)	Fuse Clear
1	3 1-inch, MOV-2, SOV-2	2 Lg Coil, MOV-1	2 SOV-1, SWGR
2	3 MOV-1, MOV-2, SOV-2	0	3 1-inch, Lg Coil, SOV-1
3	3 MOV-1, MOV-2, SWGR	2 1-inch, SOV-2	2 Lg Coil, SOV-1
4	2 MOV-1, SOV-2	0	5 1-inch, Lg Coil, MOV-2, SOV-1, SWGR
5	5 Lg Coil, MOV-1, MOV-2, SOV-2, SWGR	1 SOV-1	1 1-inch
6	4 1-inch, MOV-1, SOV-1, SWGR	0	3 MOV-2, SOV-2, SWGR
7	3 1-inch, SOV-1, SWGR	0	4 Lg Coil, MOV-1, MOV-2, SOV-2

Table 5-18. Summary of initial failure mode for inter-cable test circuits

Test #	Intra-cable SA	Inter-cable SA (Gnd equivalent SA)	Fuse Clear
8	2 Lg Coil, SOV-1	1 MOV-1	3 1-inch, MOV-2, SOV-2
9	2 1-inch, SOV-1	3 MOV-1, MOV-2, SOV-2	2 Lg Coil, SWGR
10	2 1-inch, SWGR	2 MOV-1, MOV-2	3 Lg Coil, SOV-1, SOV-2
11	4 1-inch, Lg Coil, MOV-1, SWGR	1 SOV-2	2 MOV-2, SOV-1
12	0	3 Lg Coil, MOV-2, SOV-1	4 1-inch, MOV-1, SOV-2, SWGR
Avg.	2.75/test 40.25% of population	1.25/test 18.25% of population	3.83/test 41.5% of population

It is interesting to note that a fair portion of inter-cable hot short-induced spurious operations occurred in the intermediate-scale testing. In particular, these types of failures occurred between cable trays located in different thermal exposure conditions. The fact that location E was only used in one test (Test 4) causes the authors to question whether there would have been more hot short inter-cable interactions with similar exposure conditions and cable loading configurations in locations C and E. Had these two locations used similar cable types and loading, this may have resulted in cable failures occurring within a similar time frame, and may have resulted in more inter-cable interactions. This is strictly the authors' conception, and no data is available to confirm this hypothesis. However, this observation does bring into question the conservatism of the number of inter-cable hot short interactions that may have resulted in more realistic scenarios. The number of ground fault equivalent hot short induced spurious operations would depend on the cable loading within the affected fire area, the associated components that the cables are connected to, and the availability of a common power supply among the affected cables.

6. SUMMARY OF FINDINGS

6.1 Alternating Current Test Results (EPRI/NEI, CAROLFIRE, DESIREE-FIRE)

Section 2 evaluated the experimental alternating current (ac) data by looking at various physical attributes that may influence the likelihood of an ac circuit experiencing a particular fire-induced fault mode, and also by evaluating the effects that these parameters have on hot short duration. This evaluation has proven difficult in numerous instances because the experimental set-up was based on configurations typically encountered in U.S. nuclear power plants (NPPs). Thus, in many cases, there is a large amount of data for one particular bin or configuration and minimal to no data to allow other configurations to provide an adequate comparison. The following parameters showed this to be true for the ac circuit fire-induced fault mode likelihood evaluation:

- Conductor count (95% of data for 7-9/C count)
- Cable orientation (95% of data for horizontal orientation)
- Raceway routing (95% of data for cable tray; 3% conduit; 2% air drop)
- Circuit grounding (88% of data is for grounded circuits)
- Wiring configuration (95% of data has two sources, four targets, and one return)

This review also showed that additional data may be useful in providing a more detailed evaluation of thermal exposure conditions. Here radiant exposures only contribute to 4.5% of the data set.

Note that these recommendations only identify areas where additional data is needed to provide more information to better understand the associated physical configuration effect of the parameter under evaluation. These recommendations are not based on the applicability of the parameter's actual use in U.S. NPPs. For instance, although it may be beneficial to have more data on ungrounded circuits to better evaluate their fault modes and hot short durations, it is likely that only a small portion of U.S. NPPs actually use ungrounded ac configurations. In this instance, priorities and resources may be better served collecting data to evaluate the effects of other parameters, such as cable orientation or cables in conduits.

Parameters that showed signs of influencing the fault mode likelihood of fire-induced damage include:

- Thermal exposure conditions
 - In the flame region, there is a higher likelihood of experiencing hot shorts (72%) and spurious operations (68%) than there is in the plume (46% SA, 59% HS) or hot gas layer (51% SA, 58% HS) exposures.
- Raceway fill
 - Bundle configurations show a higher likelihood of hot shorts (74%) and spurious operations (70%) than cable trays with intermediate fill (47% HS, 37% SA) or single fill (48% HS, 35% SA).

An interesting observation from analysis of the data is the fact that thermoset (TS)- and thermoplastic (TP)-insulated cables have nearly the same likelihood of experiencing a spurious operation. The EPRI/NEI data report identifies that thermoset insulated cables spuriously

operated 26 out of 126 trials (20.6%), while the thermoplastic insulated cables spuriously operated 19 out of 39 trials (48.7%). During the EPRI expert elicitation panel, one member identified this cable insulation material influence on spurious operation likelihood as a moderate dependence for intra-cable and significant for inter-cable hot shorts, while other members were silent on the insulation material influence on spurious operation likelihood. However, the EPRI expert elicitation report states the following with regard to the differences between thermoset and thermoplastic cables;

“It is important to point out that, once cable damage has occurred, be it manifested as a hot short or as another phenomenon, the probability of spurious actuation given cable damage (P_{SACD}) does not display significant differences between thermoset and thermoplastic cables”

NUREG/CR-6850 adopted the conclusion from the EPRI expert elicitation report that insulation type does not influence spurious operation likelihood. At the beginning of the electrical expert PIRT panel a common belief among the panel members was that the two cable insulation types would have different likelihood of experiencing hot short-induced spurious operations; however, the data presented in this report does not substantiate this effect, and in fact shows that TP-insulated cables have a 51% likelihood of spurious operation, while TS-insulated cables have a 52% likelihood, based on the data. After the material contained in this report was presented to the PIRT panel, they agreed unanimously that insulation type has no effect on spurious operation likelihood. Therefore, the data presented here and the PIRT panel's conclusions suggest that insulation type makes no difference to the likelihood of experiencing one failure mode over another for the intra-cable category, although the polymer properties do influence the thermal failure point, that is, the point where the cable begins to degrade physically.

In addition to evaluating the fault mode likelihoods, this report also explored the parameter effects on the duration of hot shorts and spurious operations. Those parameters where the data indicated an effect on the duration of hot shorts or spurious operations included:

- Thermal exposure conditions
 - As the thermal exposure conditions become less severe, the durations of the hot shorts/spurious operations increase.
- Raceway routing
 - Data indicated that air drops and conduit raceways have a longer duration than cable trays; however, there is only a limited data set for the air drop (2 tests) and conduit (4 tests) configurations.
- Raceway fill
 - Intermediate raceway loading configurations have longer-lasting hot shorts/spurious operations than the other two configurations (bundle, single).
- Conductor size

The data shows that cables with 14 AWG conductors experience longer durations than cables with 12 AWG conductors.

6.2 Direct Current Test Results (DESIREE-FIRE)

Section 4 evaluated the experimental data by looking at various physical attributes that may influence the likelihood of a direct current (dc) circuit experiencing a particular fire-induced fault mode, and also by evaluating the effects that these parameters have on hot short duration of dc circuits. The entire dc test data set came from a single test series, namely, the U.S. Nuclear Regulatory Commission (NRC)-sponsored DESIREE-FIRE project. As a result of this being the first and only testing of dc circuits, not every configuration could be tested with the limited amount of resources available to perform the testing. This resulted in a number of configurations that lacked a sufficient variety of configurations to provide comparisons for the parameter under evaluation in this effort. Examples include:

- Conductor count (94% 7-9/C, 3% 2-6/C, and 3% 10-15/C)
- Cable orientation (100% of dc data utilized horizontal orientation)
- Raceway routing (87% cable tray, 13% conduit, 0% air drop)
- Conductor size (92% for #12 AWG conductors)
- Cable shielding (93% non-shielded cable)

Parameters that showed signs of influencing the fault mode likelihood of fire-induced damage include:

- Raceway Fill (bundled configurations showed lower likelihood of spurious operations)
- Armor (non-grounded circuits result in high spurious operation likelihood)
- Circuit Type (motor-operated valve (MOV) circuit has larger likelihood of experiencing a spurious operation – two active targets)

In the evaluation of the dc test data, the following parameters showed signs of influencing hot short duration:

- Insulation type (TP longer than TS)
- Insulation/Jacket type (TP-TP longest, followed by TS-TS, followed by TS-TP)
- Conductor size (12 AWG has shorter durations than 14 AWG)
- Fuse Size (larger fuses have longer hot short durations)

6.3 Ground Equivalent Hot Shorts

The analysis of the dc testing results has shown that shorts through ground plane or common conductors are possible, provided that the circuits involved are ungrounded and use a common power supply. Although this phenomenon was only observed in dc tests, it is likely that similar results would have occurred in the ac testing, had that testing been set up in a similar manner. Since the ac tests only had one circuit ungrounded, there was no chance for such a failure mode to present itself in the ac tests.

This testing is the first observation of the ground equivalent hot short phenomenon. This phenomenon was theorized in NUREG/CR-6834, "Circuit Analysis – Failure Mode and Likelihood Analysis," as multiple shorts to ground. However, little to no evidence was available at that time to substantiate the likelihood of such events.

The results from the DESIREE-FIRE testing now show that these events occurred quite frequently during the intermediate-scale testing. An important concept to take away from the data is that a maximum of eight circuits could be instrumented in each test, thus limiting the likelihood of multiple circuits shorting to ground at the same time to cause these ground fault equivalent hot shorts. Had the cable trays been loaded to the more typical loading configurations found in plants, it could be postulated that a higher percentage of ground equivalent hot shorts would have occurred. Another complicating factor is the fact that most dc circuits have fuses on both ends of the circuit. Thus, clearing a single fuse does not eliminate the possibility of experiencing a short to ground that may interact with another circuit shorted to ground. The last thought on this phenomenon is that some licensees have placed safety-significant cables in dedicated conduits to provide some sort of separation or protection. The dc testing results have shown that, from a fire-induced failure standpoint, these cables are still vulnerable to ground equivalent hot shorts.

7. CONCLUSIONS AND FUTURE RESEARCH RECOMMENDATIONS

Fire-induced circuit failure testing has evolved over the years, and today's focus on obtaining realistic test results to advance the state-of-the-art in fire probabilistic risk assessment (PRA) has allowed the scientific community to better understand the failure modes of fire-induced electrical cable damage. The consolidation of the three major fire testing programs has allowed for a better understanding of key circuit parameters that can affect the likelihood of a circuit experiencing a particular failure mode and the duration of hot shorts.

This report has identified that cable armor, raceway fill configurations, and circuit type can influence the fire-induced failure modes of electrical cable. To better understand the effect armor has, it is suggested that additional testing be conducted on armor and cables with metallic shields or drain wires.

This consolidation has identified that concurrent hot shorts can occur and have occurred during testing. The opportunities for concurrent hot shorts to occur are increased when fire conditions exist to cause cable to fail at the same time. The information presented here shows that even different cable insulation types can experience concurrent spurious operation hot shorts due to different thermal exposure conditions causing the different cable types to fail during the same timeframe.

This work has determined that multiple cable shorts to ground are plausible failure modes, and should be addressed in both deterministic and performance-based methods. Provided that an ungrounded power supply is used (such as is common for station batteries), the fire damage to control circuits powered from the same common power supply can result in shorts to ground causing system spurious operations. Although this failure mode was identified in NUREG/CR-6834, "Circuit Analysis – Failure Mode and Likelihood Analysis," it wasn't until the DESIREE-Fire results were thoroughly reviewed that this failure mode was actually identified as actually occurring.

This report has also identified areas where additional data would provide a better understanding of a parameter's effect on a cable failure mode. Such areas include, expanding the range of conductor count within a multi-conductor control cable. The core set of data collected thus far has focused on 7-9/C cables. In the field, large multi-conductor cables commonly referred to as "trunk cables" are used to transmit control signals from the main control room to relay rooms, and auxiliary control rooms. There is no publicly available data on the fire-induced failures of these types of cables which commonly have 37 or more conductors per cable.

The variation of cable types and failure criteria has also been limited in past testing. The majority of the cables tested was of a control type, and even when instrumentation or power cables were tested, the failure criteria were not tailored to the specific thresholds that would constitute a failure of the associated system in the field. As such the authors believe that there should be a fire testing standard developed to standardize the testing methods and acceptance/failure criteria of when cables experience functional failure. This standard would likely reduce the costs associated with testing and allow for an entity such as EPRI or NEI to collect such data for improvement of fire PRA estimation of conditional probabilities of cable damage.

With the exception of a limited set of the EPRI/NEI test data, the cables were tested in a horizontal straight configuration. In field applications, there are commonly cable runs in vertical

and inclined configurations as well as bends and t-connections. Future testing should consider such configurations.

A large majority of the ac testing has been limited to testing grounded ac circuits as this is a common configuration found in the field. However, the authors are aware of some plants that use ungrounded ac systems and as such it is suggested that future research include a larger portion of ungrounded circuits to generate a more substantial set of data from which to develop conclusions. In particular the likelihood of hot short and subsequent hot short durations for ungrounded ac circuits should specifically be evaluated. In addition, the ac data is sparse, and the use of conduits and any ac grounded/ungrounded tests should include conduit raceways to better understand the applicability of the current methodology in NUREG/CR-6850 related to the credit given for reducing the likelihood of spurious operation when a cable is routed in conduit.

8. REFERENCES

NRC NUREG/CR-6931, Vol. 1, "Cable Response to Live Fire (CAROLFIRE) Volume 1: Test Descriptions and Analysis of Circuit Response Data," April 2008.

NRC NUREG/CR-6931, Vol. 2, "Cable Response to Live Fire (CAROLFIRE) Volume 2: Cable Fire Response Data for Fire Model Improvement," April 2008.

NRC NUREG/CR-6931, Vol. 3, "Cable Response to Live Fire (CAROLFIRE) Volume 3: Thermally-Induced Electrical Failure (THIEF) Model," April 2008.

EPRI TR1003326, "Characterization of Fire-Induced Circuit Faults, Results of Cable Fire Testing," December 2002.

NRC NUREG/CR-7100, "Direct Current Electrical Shorting in Response to Exposure Fire (DESIREE-FIRE): Test Result" April 2012.

Freund, J. and Perles, B., "A New Look at Quartiles of Ungrouped Data," The American Statistician, Volume 41, Number 3, pgs 200-203, 1978.

Anixter wire and cable handbook.

NRC NUREG-1475, "Applying Statistics," March 2011.

NRC NUREG/CR-6834, "Circuit Analysis – Failure Mode and Likelihood Analysis," September 2003

NRC NUREG/CR-6850, "EPRI/NRC-RES Fire PRA Methodology for Nuclear Power Facilities, Volume 2: Detailed Methodology" September 2005.

**Appendix A: Penlight Ground Fault Equivalent Inter-Cable
Failure Mode Evaluation**

A. Penlight Ground Fault Equivalent Inter-Cable Failure Mode Evaluation

This section is going to review the inter-cable interactions for the direct current (dc) penlight tests. They will be discussed based on circuit (solenoid-operated valve (SOV), motor-operated valve (MOV), Large Coil, 1-inch valve, and switchgear (SWGR)). Since these tests were performed in Penlight, the only route for inter-cable interaction is through the ground via the cable tray. The tests displayed in this section are the tests that displayed inter-cable interactions.

A.1 Penlight MOV Tests

A.1.1 Penlight MOV Test #8

The first MOV test to display inter-cable interactions was Penlight Test #8. The timeline for this experiment is shown below in Table A-1. Figure A-1 shows the outstanding current plot for this test, displaying inter-cable interactions between MOV-1 and MOV-2. Figure A-2 and Figure A-3 display the current plots for MOV-1 and MOV-2, respectively, during the same time period as the outstanding current displayed in Figure A-1. From this, it is apparent that the red lamp on MOV-2 is flickering between times 478-480 because of the inter-cable interaction with MOV-1 conductor P via the ground plane.

Table A-1: Penlight test #8 sequence of events

Time (s)	Event/Observation
0	Penlight on
300	Cable Ignition
465-514	Chatter – MOV-2 – Open & Close Coils False Indication – MOV-2 – Green & Red lamps flicker
467-513	ON/OFF MOV-2 Red lamp flicker due to inter-cable interactions with MOV-1 conductor P via ground.
478-480	MOV-2 Red lamp flicker due to inter-cable interactions with MOV-1 conductor P via ground.
498-502	Chatter – MOV-1 Open Coil
502	False Indication – MOV-1 – Green Flickers Off/On
505-538	False Indication – MOV-1 – Green lamp OFF
514	Fuse Clear – MOV-2 MOV-1 SA – Open Coil (8s duration)
538-546	False Indication – MOV-2 – Green lamp ON & Red lamp OFF
546	Fuse Clear – MOV-1
780	Penlight off




Figure A-1: Outstanding current shorting in Penlight MOV test #8




Figure A-2: Penlight MOV-1 test #8 current plot




Figure A-3: Penlight MOV-2 test #8 current plot

A.1.2 Penlight MOV Test #12

The timeline for Penlight MOV Test #12 is shown below in Table A-2. Highlighted in red type are the inter-cable interactions between MOV-1 conductor N and MOV-2 conductor P via the ground plane. These low-current interactions did not cause any failure mode effects. This is represented graphically in Figure A-4, which shows the outstanding current shorting for this test. Figure A-5 and Figure A-6 display the conductors' current for MOV-1 and MOV-2, respectively.

Table A-2: Penlight test #12 sequence of events

Time (s)	Event/Observation
0	Penlight on
863-1066	MOV-1 SA – Open Coil (203s duration)
863-966	False Indication (Red off - No Voltage Pickup on R)
945-1062	HS MOV-1 – Close Coil
990-1066	Grounding of Positive battery lead
1066	Fuse Clear MOV-1 – Positive
1066	Grounding of Negative battery lead
1066	Current increase to 0.08A on Negative of MOV-2
1323-2321	Inter-cable interactions off and on between MOV-1 conductor N and MOV-2 conductor P via ground
1335	Penlight off
1350	Fuse Clear – MOV-2 – Negative
1635	Penlight turned back on
2350	Fuse Clear – MOV-1 – Negative
2400	Penlight off




Figure A-4: Outstanding current shorting in Penlight MOV test #12




Figure A-5: Penlight MOV-1 test #12 current plot




Figure A-6: Penlight MOV-2 test #12 current plot

A.1.3 Penlight MOV Test #22

The sequence of events for Penlight MOV Test #22 is presented below in Table A-3. As shown, there are four spurious operations caused by inter-cable interactions. These are highlighted in red in Table A-3. Figure A-7 displays the outstanding current shorting for this test relative to the time frame of those four spurious operations. The specific conductors causing the inter-cable interactions were identified from the conductors' current plots for MOV-1 and MOV-2 (Figure A-8 and Figure A-9, respectively),.

Table A-3: Penlight test #22 sequence of events

Time (s)	Event/Observation
0	Penlight on
174	Smoke observed
285-572	Cable ignition of the outer jacket material
585-592	Intermittent grounding of battery positive and negative
585-587	SA MOV-1 – Open Coil (2s duration) due to inter-cable interactions between MOV-1 conductor YO and MOV-2 conductor G via ground
586-595	Chatter – MOV-1 & MOV-2 – Open & Close coils
589-591	SA MOV-1 – Open Coil (2s duration) due to inter-cable interactions between MOV-1 conductor YO and MOV-2 conductor G via ground
595-631	Grounding of positive lead
593-633	Battery Positive shorts to ground
595-633	SA MOV-2 – Open Coil (38s duration) due to inter-cable interactions between MOV-2 conductor YO and MOV-1 conductor G via ground
595-633	False Indication – MOV-2 – Green lamp ON

Table A-3: Penlight test #22 sequence of events

Time (s)	Event/Observation
596-633	HS MOV-2 – Close Coil (37s duration)
633	Fuse Clear - MOV-1
633	Fuse Clear - MOV-2
785	Penlight off




Figure A-7: Outstanding current shorting in Penlight MOV test #22




Figure A-8: Penlight MOV-1 test #22 current plot




Figure A-9: Penlight MOV-2 Test #22 current plot

A.1.4 Penlight MOV Test #33

For Penlight MOV Test #33, the sequence of events is displayed in Table A-4. As shown, there is one inter-cable interaction between MOV-1 and MOV-2 that does not cause any cable failure modes to occur. This is shown to display a sharp single spike in the outstanding current calculation (Figure A-10). From this current spike and looking at Figure A-11 and Figure A-12 (MOV-1's and MOV-2's conductors' current plots, respectively), the inter-cable interaction was identified as occurring between MOV-1 conductor P with MOV-2 conductors N and YC via the ground plane.

Table A-4: Penlight test #33 sequence of events

Time (s)	Event/Observation
0	Penlight on
538-626	Battery Negative Shorts to Ground
575	Fuse Clear – MOV-2
611-626	HS MOV-1 – Close coil – no corresponding current
620-621	Inter-cable interactions with MOV-1 conductor P with MOV-2 conductor N, and YC via ground
627	Fuse Clear – MOV-1
705	Penlight off




Figure A-10: Outstanding current shorting in Penlight MOV test #33




Figure A-11: Penlight MOV-1 test #33 current plot




Figure A-12: Penlight MOV-2 test #33 current plot

A.1.5 Penlight MOV Test #37

For Penlight MOV Test #37, there was one spurious operation caused by inter-cable interactions. This is highlighted below in Table A-5 in the sequence of events for this test. Figure A-13 displays the outstanding current calculation for MOV-1 and MOV-2. From this plot, it is noted that there are inter-cable interactions during the time of the spurious operation on MOV-1 close coil. From Figure A-14 and Figure A-15 (MOV-1 and MOV-2 conductor current plots respectively), the inter-cable interaction is between MOV-1 conductor G and MOV-2 conductor YC via the ground plane.

Table A-5: Penlight test #37 sequence of events

Time (s)	Event/Observation
0	Penlight on
1681-1711	SA MOV-1 – Close Coil (30s duration)
	False Indication – MOV-1 – Red ON
1692-1712	(note: auxiliary contact failure)
1712	Fuse Clear – MOV-1
1723-1739	SA MOV-2 – Close Coil (16s duration) Inter-cable interactions between MOV-1 conductor G and MOV-2 conductor YC via ground
	False Indication – MOV-2 – Red ON
1731-1739	(note: auxiliary contact failure)
1740	Fuse Clear - MOV-2
1830	Penlight off




Figure A-13. Outstanding current shorting in Penlight MOV Test #37




Figure A-14. Penlight MOV-1 Test #37 current plot




Figure A-15. Penlight MOV-2 Test #37 current plot

A.1.6 Penlight MOV Test #41

The sequence of events for Penlight MOV Test #41 is presented below in Table A-6. As shown, there are two spurious operations caused by inter-cable interactions and one inter-cable interaction that does not cause an immediate failure mode effect. These are highlighted in red in Table A-6. Figure A-16 displays the outstanding current shorting for this test relative to the time frame of those four spurious operations. The specific conductors causing the inter-cable interactions were identified from the conductors' current plots for MOV-1 and MOV-2 (Figure A-17 and Figure A-18, respectively).

Table A-6. Penlight Test #41 sequence of events.

Time (s)	Event/Observation
0	Penlight on
317	Smoke observed
1307-1405	SA MOV-2 – Close Coil (98s duration)
2462-2894	HS MOV-2 – Open Coil
2560-2649	Battery Negative shorts to ground
2562 – 2895	Cable thermocouple within conduit displaying off-normal readings
2626-2648	SA MOV-2 – Close Coil (22s duration)
2692-2755	Battery Positive shorts to ground
2699-2759	SA MOV-1 – Open Coil (60s duration)
2753-2759	SA MOV-2 – Close Coil (6s duration) due to inter-cable interactions with MOV-1 conductor G via ground.
2755-2790	Battery Negative shorts to ground
2776-2777	SA MOV-1 – Open Coil (1s duration) weak signs of inter-cable interactions with MOV-2 conductor G via ground.

Table A-6. Penlight Test #41 sequence of events.

Time (s)	Event/Observation
2776-2838	HS MOV-1 – Open & Close coils – 118 & 112 Vdc, respectively
2790-2791	SA MOV-1 – Open Coil (1s duration)
2790-2840	Battery Positive shorts to ground
2825-2834	Inter-cable interactions with MOV-1 conductor P and MOV-2 conductor N via ground.
2837-2838	SA MOV-1 – Open Coil (1s duration)
2839	Fuse Clear – MOV-1
2872-2874	SA MOV-2 – Close Coil (2s duration)
2894	Fuse Clear – MOV-2
3255	Penlight off




Figure A-16. Outstanding current shorting in Penlight MOV Test #41




Figure A-17. Penlight MOV-1 Test #41 current plot




Figure A-18. Penlight MOV-2 Test #41 current plot

A.1.7 Penlight MOV Test #49

The sequence of events for Penlight MOV Test #49 is presented below in Table A-7. As shown, there is one spurious operation and one fuse clear caused by inter-cable interactions. These are highlighted in red in Table A-7. Figure 19 displays the outstanding current shorting for this test relative to the time frame of those four spurious operations. The specific conductors causing the inter-cable interactions were identified from the conductors' current plots for MOV-1 and MOV-2 (Figure 20 and Figure 21, respectively).

Table A-7. Penlight Test #49 sequence of events.

Time (s)	Event/Observation
0	Penlight on
755	Liquid exiting TC cable
2400	Penlight increased to 440 °C
4394-4401	SA MOV-1 – Close Coil (7s duration)
4402	MOV-1 Fuse Clear
4402-4824	Battery Negative shorts to ground
4620	Penlight off
~4820	Interactions between MOV-1 and MOV-2 circuits
4823	SA MOV-2 – Open Coil (<1s duration) with intra-cable interactions with conductors P and N also with inter-cable interaction with MOV-1 conductor N via ground.
4824	MOV-2 Fuse Clear caused by inter-cable interactions between MOV-1 conductor N and MOV-2 conductors R and N.




Figure A-19. Outstanding current shorting in Penlight MOV Test #49




Figure A-20. Penlight MOV-1 Test #49 current plot




Figure A-21. Penlight MOV-2 Test #49 current plot

A.1.8 Penlight MOV Test #50

The sequence of events for Penlight MOV Test #50 is presented below in Table A-8. As shown, there is one hot short and one fuse clear caused by inter-cable interactions. These are highlighted in red in Table A-8. Figure A-22 displays the outstanding current shorting for this test relative to the time frame of those four spurious operations. The specific conductors causing the inter-cable interactions were identified from the conductors' current plots for MOV-1 and MOV-2 (Figure A-23 and Figure A-24, respectively).

Table A-8. Penlight Test #50 sequence of events.

Time (s)	Event/Observation
0	Penlight on
420	Liquid exiting end of TC cable
822	Cable Ignition
1164-1181	False Indication MOV-2 – Red lamp ON
1242-1334	Battery Positive shorts to ground
	SA MOV-2 – Close Coil (22s duration) caused by inter-cable interactions between MOV-2 conductor YC and MOV-1 conductor G via ground.
1242-1264	Fuse Clear – MOV-2 caused by inter-cable interactions between MOV-2 conductor YC and N with MOV-1 conductor N via ground.
1267	Fuse Clear – MOV-2 caused by inter-cable interactions between MOV-2 conductor YC and N with MOV-1 conductor N via ground.
1279-1300	False Indication – MOV-1 – Red lamp ON
1334	Fuse Clear – MOV-1
1440	Penlight off




Figure A-22. Outstanding current shorting in Penlight MOV Test #50




Figure A-23. Penlight MOV-1 Test #50 current plot




Figure A-24. Penlight MOV-2 Test #50 current plot

A.1.9 Penlight MOV Test #JPN-3

For Penlight MOV Test #JPN-3, the sequence of events is displayed in Table A-9. As shown, there is one inter-cable interaction between MOV-1 and MOV-2 that caused the red light to turn on. The outstanding current shorting is displayed in Figure A-25 for MOV-1 and MOV-2. From this current spike and from looking at Figure A-26 and Figure A-27 (MOV-1 and MOV-2 conductor current plots, respectively), the inter-cable interaction was identified as occurring between MOV-1 conductor R with MOV-2 conductors N and P via the ground plane.

Table A-9. Penlight Test #JPN-3 sequence of events.

Time (s)	Event/Observation
0	Penlight on
1974-2501	Battery Positive shorts to ground
	SA MOV-2 – Open Coil (194s duration)
2308-2502	HS MOV-2 – Close Coil
2318-2501	False Indication – MOV-2 – Green lamp ON
2320-2502	False Indication – MOV-1 – Red lamp ON due to inter-cable interactions with MOV-2 conductor N and P via ground.
2463	Cable Ignition
2502	Fuse Clear – MOV-2
2626-2759	False Indication – MOV-1 – Red lamp OFF & Green lamp ON
2626-2866	SA MOV-1 – Open Coil (240s duration)
	Battery Negative shorts to ground
2761-2866	False Indication – MOV-1 Red lamp OFF & Green lamp ON
2866	Fuse Clear – MOV-1
2930	Penlight off




Figure A-25. Outstanding current shorting in Penlight MOV Test #JPN-3




Figure A-26. Penlight MOV-1 Test # JPN-3 current plot




Figure A-27. Penlight MOV-2 Test # JPN-3 current plot

A.2 Penlight SOV Tests

This section will discuss the inter-cable interaction results for the Penlight SOV tests. The tests that showed inter-cable interactions will be discussed. There were some issues with some of the current transducers drifting during these tests, so the tests that clearly showed signs of inter-cable interactions are the ones described below.

A.2.1 Penlight SOV Test #20

For Penlight SOV Test #20, the sequence of events is displayed in Table A-10. The spurious operation caused by the inter-cable interaction is highlighted in red. The outstanding current plot, the SOV-1 conductors' current plot, and the SOV-2 conductors' current plot are shown in Figure A-28, Figure A-29, and Figure A-30, respectively. From these three plots, the inter-cable interaction was determined to occur between SOV-2 conductor S2 and SOV-1 conductor G via the ground plane.

Table A-10. Penlight Test #20 sequence of events.

Time (s)	Event/Observation
0	Penlight on
250	Cable Ignition
483-526	Battery Positive Shorts to Ground
484-526	SOV-1 False Indication Red lamp ON
502-526	SOV-1 SA (~0.078 A) [24s duration] SOV-2 SA (~0.059 A) [20s duration] due to inter-cable interactions with
508-528	SOV-1 conductor G via ground.
524-528	SOV-2 False Indication Red lamp ON
526	SOV-1 Fuse Clear
529-556	Battery Positive Shorts to Ground
530-556	SOV-2 SA (~0.082 A) [26s duration] and SOV-2 False Indication Red Lamp ON
556	SOV-2 Fuse Clear
646	Penlight off




Figure A-28. Outstanding current shorting in Penlight SOV Test #20




Figure A-29. Penlight SOV-1 Test #20 current plot




Figure A-30. Penlight SOV-2 Test #20 current plot

A.2.2 Penlight SOV Test #28

For Penlight SOV Test #28, the sequence of events is displayed in Table A-11. The spurious operation caused by the inter-cable interaction is highlighted in red. The outstanding current plot, SOV-1 conductors' current plot, and SOV-2 conductors' current plot are shown in Figure A-31, Figure A-32, and Figure A-33, respectively. From these three plots, the inter-cable interaction was determined to occur between SOV-2 conductor S2 and SOV-1 conductor P via the ground plane.

Table A-11. Penlight Test #28 sequence of events.

Time (s)	Event/Observation
0	Penlight on
2400	Penlight Increased to 350 °C
2958-3384	SOV-1 False Indication Red lamp ON
3360	Penlight Increased to 375 °C
3384	SOV-1 Fuse Clear
3393-3690	SOV-2 SA (~0.071 A) [297s duration] due to inter-cable interactions between MOV-2 conductor P
3597-3690	SOV-2 False Indication Red lamp ON
3690	SOV-2 Fuse Clear
3820	Penlight off




Figure A-31. Outstanding current shorting in Penlight SOV Test #28




Figure A-32. Penlight SOV-1 Test #28 current plot




Figure A-33. Penlight SOV-2 Test #28 current plot

A.2.3 Penlight SOV Test #31

For Penlight SOV Test #31, the sequence of events is displayed in Table A-12. The hot short caused by the inter-cable interaction is highlighted in red. The outstanding current plot, SOV-1 conductors' current plot, and SOV-2 conductors' current plot are shown in Figure A-34, Figure A-35, and Figure A-36, respectively. From these three plots, the inter-cable interaction was determined to occur between SOV-2 conductor R and SOV-1 conductor N via the ground plane.

Table A-12. Penlight Test #31 sequence of events.

Time (s)	Event/Observation
0	Penlight on
414	Battery Positive Shorts to Ground
414-431	SOV-2 False Indication Green Lamp ON caused by inter-cable interactions with SOV-1 conductor N.
432	SOV-2 Fuse Clear
455-420	Battery Positive Shorts to Ground and SOV-1 False Indication Red lamp ON
517-520	SOV-1 SA (~0.084 A) [3s duration]
520	SOV-1 Fuse Clear
579	Penlight off




Figure A-34. Outstanding current shorting in Penlight SOV Test #31




Figure A-35. Penlight SOV-1 Test #31 current plot




Figure A-36 Penlight SOV-2 Test #31 current plot

A.3 Penlight large coil and 1-inch valve tests

A.3.1 Penlight large coil and 1-inch valve Test #11

For the Penlight large coil and the 1-inch valve circuit in Test #11, the sequence of events is displayed in Table A-13. There were two spurious operations caused by inter-cable interactions, which are highlighted in red. The outstanding current plot, 1-inch valve conductors' current plot, and large coil conductors' current plot are shown in Figure A-37, Figure A-38, and Figure A-39, respectively. From these three plots, the first inter-cable interaction was determined to occur between large coil conductor S and 1-inch valve conductors G and R via the ground plane. The second inter-cable interaction was determined to occur between 1-inch valve conductor S and large coil conductor P via the ground plane.

Table A-13. Penlight Test #11 sequence of events.

Time (s)	Event/Observation
0	Penlight on
1087-1141	Battery Positive shorts to ground
1089-1104	False Indication – 1-inch valve – Red lamp ON
1089-1141	SA – Large Coil (52s duration) – caused by inter-cable interaction with 1-inch valve conductor G and R via ground.
	SA – 1-inch valve (<1s duration)
1109	False Indication – 1-inch valve – Green lamp ON
1110-1130	False Indication – 1-inch valve – Red lamp ON
	SA – 1-inch valve (11s duration)
1130-1141	False Indication – 1-inch valve – Green lamp ON
1142-1455	Battery Negative shorts to ground
1142-1455	False Indication – 1-inch valve – Green lamp OFF

Table A-13. Penlight Test #11 sequence of events.

Time (s)	Event/Observation
1456-1464	False Indication – 1-inch valve – Red lamp ON
1456-2457	SA – Large Coil (1001s duration)
1464-1835	False Indication – 1-inch valve – Green lamp ON
1464-2457	Battery Positive shorts to ground
1464-2262	SA – 1-inch valve (798s duration) due to inter-cable interaction between Large Coil conductor P via ground.
1534-2457	False Indication – 1-inch valve – Red lamp ON
1930-2262	False Indication – 1-inch valve – Green lamp ON
2262	Fuse Clear – 1-inch valve (10A)
2457	Fuse Clear – Large Coil (25A)
2495	Cable Ignition
2795	Penlight off




Figure A-37. Outstanding current shorting in Penlight 1-inch valve and large coil Test #11




Figure A-38. Penlight 1-inch valve Test #11 current plot




Figure A-39. Penlight large coil Test #11 current plot

A.3.2 Penlight Large Coil and 1-inch valve Test #40

For the Penlight Large Coil and the 1-inch valve Test #40, the sequence of events is displayed in Table A-14. There were two spurious operations caused by inter-cable interactions, which are highlighted in red. The outstanding current plot, 1-inch valve conductors' current plot, and Large Coil conductors' current plot are shown in Figure A-40, Figure A-41, and Figure A-42, respectively. From these three plots, the first inter-cable interaction was determined to occur between Large Coil conductor S and 1-inch valve conductors G and R via the ground plane. The second inter-cable interaction was determined to occur between Large Coil conductor S and 1-inch valve conductors N2 and S via the ground plane.

Table A-14. Penlight Test #40 sequence of events.

Time (s)	Event/Observation
0	Penlight on
3345	Penlight increased to 475 °C
3985	Penlight increased to 500 °C
4063-4166	Battery Positive shorts to ground
4068-4166	False Indication – Large Coil – Red lamp ON SA – Large coil (64s duration) due to inter-cable interaction between 1"Valve conductors G and R via ground.
4100-4164	SA – Large coil (64s duration) due to inter-cable interaction between 1"Valve conductors G and R via ground.
4167-4312	Battery Negative shorts to ground
4167	Fuse Clear – 1-inch valve (10A)
4280	Penlight off
4314-4329	SA – Large coil (15s duration) cause by inter-cable interactions with 1-inch valve conductors N2 and S via ground.
4317-4329	False Indication – Large Coil – Red lamp ON
4330-4330	Battery negative shorts to ground
4330	Fuse Clear – Large coil (25A)




Figure A-40. Outstanding current shorting in Penlight 1-inch valve and large Coil Test #40




Figure A-41. Penlight 1-inch valve Test #40 current plot




Figure A-42. Penlight large coil Test #40 current plot

A.4 Penlight SWGR Tests

The last set of penlight tests to be discussed is the SWGR tests for both the trip and close circuits. This section will discuss the SWGR tests where inter-cable interactions were identified.

A.4.1 Penlight SWGR Test #4

For Penlight SWGR Test #4, the sequence of events is displayed in Table A-15. There was one spurious operation caused by inter-cable interactions, which is highlighted in red. The outstanding current plot, Close Circuit conductors' current plot, and Trip Circuit conductors' current plot are shown in Figure A-43, Figure A-44, and Figure A-45, respectively. From these three plots, the inter-cable interaction was determined to occur between Trip Circuit conductor PT and the Close Circuit conductor N1 via the ground plane.

Table A-15. Penlight Test #4 sequence of events.

Time (s)	Event/Observation
0	Penlight on
299	Cable Ignition
550-597	False Indication Red lamp ON
568-640	Cable thermocouples providing abnormal results, perhaps due to the arcing behavior
577-581	False Indication Green lamp OFF
589-625	HS Trip Coil (Breaker remains Open)
598-625	False Indication Green lamp OFF
623-638	Positive Battery Lead Shorts to Ground
625	SA Close Coil (Breaker Closes)
625-626	HS Close Coil (Breaker remains Closed)
625-626	False Indication Red lamp OFF
626	SA Trip Coil (Breaker Opens)
626-632	False Indication Green lamp OFF
632	SA Close Coil (Breaker Closes)
632-634	HS Close Coil (Breaker remains Closed)
632-635	False Indication Red lamp OFF
635	SA Trip Coil (Breaker Opens) due to inter-cable interaction with SWGR Close Circuit conductor N1 via ground.
635-698	HS Trip Coil (Breaker remains Open)
635-700	False Indication Green lamp OFF
638	Fuse Clear Close Circuit (15A)
639-1638	Battery Negative shorts to ground
701-1440	False Indication Red lamp ON
719-728	HS Trip Coil (Breaker remains Open)
1441-1637	False Indication Green lamp OFF
1638	Penlight off




Figure A-43. Outstanding current shorting in Penlight SWGR Test #4




Figure A-44 Penlight SWGR Close Test #4 current plot




Figure A-45 Penlight SWGR Trip Test #4 current plot

A.4.2 Penlight SWGR Test #JPN-2

For Penlight SWGR Test #JPN-2, the sequence of events is displayed in Table A-16. There was one false red lamp indication caused by inter-cable interactions, which is highlighted in red. The outstanding current plot, Close Circuit conductors' current plot, and Trip Circuit conductors' current plot are shown in Figure A-46, Figure A-47, and Figure A-48, respectively. From these three plots, the inter-cable interaction was determined to occur between Trip Circuit conductor R and the Close Circuit conductor N1 via the ground plane. This is a weak indication of an inter-cable interaction, and most of this current analysis may not have picked up all of these types of indications of inter-cable interactions.

Table A-16. Penlight Test #JPN-2 sequence of events.

Time (s)	Event/Observation
0	Penlight on
978-1361	Voltage loss on Trip circuit "R" conductor (~100Vdc)
1322-1456	Battery Negative shorts to Ground
1362-1456	False Indication Red lamp ON This is an Inter-cable hot short between Trip cable "R" conductor and Close cable N1 conductor via ground
1457	Fuse Clear – Close Coil
1457-2071	Battery Positive shorts to Ground
2072-2120	False Indication Red lamp ON
2072-2111	Battery Negative shorts to Ground
2112-2430	Battery Positive shorts to Ground
2121-2430	False Indication Red lamp ON
2430	Penlight off




Figure A-46. Outstanding current shorting in Penlight SWGR Test #JPN-2




Figure A-47. Penlight SWGR Close Test #JPN-2 current plot




Figure A-48. Penlight SWGR Trip Test #JPN-2 current plot

**Appendix B: Supplemental Information for the CAROLFIRE
Reports, Including Additional Data Retrieval**

B. Supplemental Information for the CAROLFIRE Reports, Including Additional Data Retrieval

B.1. Introduction

This document is meant to help readers of the Cable Response to Live Fire (CAROLFIRE) reports⁶ to better understand the project, its diagnostic equipment, and certain of its data, including some that is not explicitly discussed in the reports. It is not intended to be a stand-alone document, and makes frequent reference to the CAROLFIRE reports and the extensive data files distributed with them. It is therefore essential that the referenced material be available to users of this document. This document provides a better explanation of certain aspects of the equipment and tests by collecting and organizing material that is scattered among different locations in Volumes 1 and 2, and it also presents additional details obtained from the Sandia National Laboratories (SNL) authors that are not in those volumes.

CAROLFIRE utilized two different, complementary electrical performance monitoring systems, which together provided a comprehensive knowledge of fire damage to electric cables and its effects on electric circuits. The Insulation Resistance Measurement System (IRMS) provided a general overall knowledge of electric cable damage as the fire progressed by measuring the electrical insulation resistance (IR) between all pairs of conductors in the cable, and between each individual conductor and ground. IRMS measurements were totally independent of any circuit that might be connected to the cable in an actual nuclear power plant. The Surrogate Circuit Diagnostic System (SCDS) provided a detailed knowledge of the effects on one specific electric circuit of fire damage to an electric cable connected to that circuit. Both systems were necessary, because neither was capable of performing both functions by itself.

B.2. The Insulation Resistance Measurement System (IRMS)

B.2.1 Operating Principles

The IRMS is described in detail in Appendix B of Volume 1. It determines the IR between a pair of conductors, each of which can be a single conductor or an electrically connected group of conductors, and between each of those conductors and the ground. It operates by energizing one conductor (the “source” conductor) with a known voltage source and then measuring the voltage across a known resistance connected in series with the source conductor, and also measuring the voltage across a separate known resistance connected in series with another conductor (the “target” conductor). It then switches the known voltage source to the opposite conductor (i.e., the former “target” becomes the “source,” and the former “source” becomes the “target”) and repeats the voltage measurements. The resulting two pairs of measurements, along with the known source voltage and the two known resistances, are mathematically sufficient to enable calculation of the above-specified IR values. The two pairs of measurements are made as described above (i.e., in immediate sequence—within two seconds⁷) to minimize errors resulting from the implicit mathematical assumption that all four voltages exist at the exact same moment.

⁶ “Cable Response to Live Fire (CAROLFIRE) Volume 1: Test Descriptions and Analysis of Circuit Response Data,” NUREG/CR-6931, Volume 1, April, 2008; and “Cable Response to Live Fire (CAROLFIRE) Volume 2: Cable Fire Response Data for Fire Model Development,” NUREG/CR-6931, Volume 2, April, 2008.

⁷ In earlier IRMS applications, (e.g., NUREG/CR-6776, “Cable Insulation Resistance Measurements Made During Cable Fire Tests,” June, 2002), IR measurements were made by connecting the source voltage to one conductor, sequentially measuring all other (i.e.,

B.2.2 Uncertainties Due to IRMS Cycle Time

SNL developed and patented two IRMSs for CAROLFIRE—each can be connected to as many as 14 conductors, and has sufficient switching and data recording equipment to determine the IR values between all pairs of those conductors and between each of those conductors and the ground. Depending on the number of conductors being monitored, however, one cycle (i.e., one measurement of the IR values for all pairs) can take from seconds (e.g., ~42 sec) to a few minutes (e.g., ~3 min). Thus, in practice, it is desirable to limit the number of monitored conductors, because long cycle times limit the data's time resolution. That is, any event that occurs just after measurement of an IR value that would have been affected by the event would not be measured and recorded until that IR is again measured during the next cycle. If any additional events occurred before that next IR measurement, only the composite result of all such events would be measured and recorded (i.e., they would not be resolved in time and recorded as separate events).

An important example is if a hot short occurs between two conductors just after measurement of those conductors' IR values, and then, just before the next measurement of their IR values, they short to ground. The occurrence of the hot short would be missed—all that would be measured and recorded is that the conductors were, at the time of the second IR measurement, shorted to each other and to ground. Another important example is if a hot short occurs between two conductors just before measurement of their IR values, and then, just after that same measurement, one of the conductors shorts to ground—this termination by grounding of the hot short would not be measured and recorded until the next cycle's measurement, resulting in the recording of a much longer-lasting hot short than actually occurred. The inaccuracies in both of these examples occur because the time resolution of IRMS data is limited by its cycle time, which increases as the number of monitored conductors increases.

This is one of the reasons that surrogate circuit diagnostic units (SCDUs, discussed later) were also used in CAROLFIRE—SCDUs have a vastly better time resolution (0.2 seconds cycle time), but they lack the IRMS's ability to detect progressive cable deterioration well before ultimate cable failure. The IRMS and SCU systems thus complement each other, and together provide the most complete knowledge of electric cable behavior in fires.

B.2.3 Criteria for Spurious Operation (SA)

The IRMS provided a stream of cable IR data indicating progressive degradation of the cables' insulating ability. The numerical IR limit that should be considered sufficient to induce a spurious operation (SA) depends on the nature and sensitivity of the circuit. However, for CAROLFIRE, a specific criterion was applied to reflect a typical 120 VAC control circuit and to reflect the typical faulting behavior observed in previous testing. In particular, a control cable was considered to have caused an SA when it shorted to another conductor with an IR of less than or equal to 1000 Ω . This IR limit was selected as a representative of expected failure onset conditions for control and instrument circuits because the typical behavior of such cables during fire exposure involves a fairly steady degradation of IR with rising temperature until the IR value degrades to some value considerably above 1000 Ω , at which point the cable typically experiences rapid degradation to IR values typically under 100 Ω . Thus, use of the 1000 Ω

"target") conductors, then switching the source voltage to the second conductor, etc. That method required more time to collect the two pairs of measurements needed, and resulted in increased uncertainties in IR during the transition phase.

failure criterion should acceptably represent this behavior⁸. The SA was considered to terminate when either conductor shorted to ground with an IR of less than or equal to 1000Ω.

B.2.4 Presentation of IRMS Data

The IRMS results are provided in the form of extensive shorting sequence tables. Chapter 6 of Volume 1 provides the Penlight Test (PT) IRMS tables, and Chapter 7.1 provides the Intermediate-Scale Test (IT) IRMS tables. The tables provide specific sequences of observed short circuits between pairs of conductors (or conductor groups) and between each conductor (or conductor group) and ground.

The shorting sequence tables provide the most significant events (“highlights”) of each test, subject to the time resolution limits discussed previously. Full details are provided in the Excel data files on the CDs distributed with CAROLFIRE Volumes 1 and 2, and on the U.S. Nuclear Regulatory Commission (NRC) website. Those files include plots of the data, which can be enlarged on-screen. This method is recommended for viewing the data, because “hovering” over any plotted point will result in the appearance of its exact numerical coordinates, in addition to the plot showing how it fits into the overall test results. An example is provided in Figure 1, “IRMS Data Plot Example,” which represents one of the tests involving a single⁹ 7-conductor cable. The relative location of the conductors in the cable is shown in Figure 2, “Seven-Conductor Cable,” which applies to all 7-conductor cables monitored during CAROLFIRE by either the IRMS or the SCDUs.

B.2.5 IRMS Set-Up to Detect Inter-Cable Hot Shorts

A primary interest of the CAROLFIRE project was the interactions between cables (inter-cable shorts), as opposed to interactions between conductors within a single cable (intra-cable shorts, such as the above example, in which each of the seven conductors in a single 7-conductor cable was monitored by an IRMS channel). This indicated that many tests should involve a bundle or bundles of multi-conductor electric cables. It was not possible to connect each conductor within such bundles to an IRMS channel, because each IRMS unit can only accommodate a maximum of 14 channels (and because of the need to minimize cycle times, as previously discussed).

Thus, the typical IRMS practice was to group conductors from each of several co-located (bundled) cables into two groups. For a 7-conductor cable (Figure 2), there was one central conductor surrounded by six cables forming an outer ring. The six outer conductors were collected into two groups of three conductors each, with each group comprising alternate conductors in the outer ring. In this way, the IRMS was able to determine when one conductor group shorted internally to the other conductor group in the same cable (intra-cable shorting), when each conductor group shorted to ground, and when either conductor group in one cable shorted to either conductor group in another cable (inter-cable shorting). The typical conductor grouping, using the Figure 2 conductor numbering scheme, is shown in Figure 3, “Grouping of Seven Conductors.” Note that for these bundled tests (in contrast to the single cable example given above), the central conductor (“1” in Figure 2) was not connected to the IRMS and was not grounded (i.e., was a “spare” conductor, and so was not connected to anything). In some

⁸ Instrument cables might begin to cause instrument errors at IR values above 1000Ω, but fire damage is expected to cause IR decreases to begin considerably above 1000Ω and then proceed rapidly, so the 1000Ω criterion should be reasonably acceptable.

⁹ This “single cable” designation can be misleading, because in all cases (except the “Spec 1” test described on pg. 77 of Volume 1) this actually means a single cable for electrical monitoring, plus a nearby (identical) single cable for thermal monitoring (i.e., two cables were actually used).

nuclear power plant (NPP) systems, spare conductors are grounded, so note that the CAROLFIRE IRMS data might be somewhat less representative of such cables¹⁰. Also note that for all tests involving the IRMS, the electrical raceway was grounded to a common ground, along with the IRMS power supply, and that none of the conductors or shields within the IRMS-monitored cables were grounded. Thus, conductor-to-ground IR values always indicated interactions between conductors and the raceway (i.e., cable tray or conduit).

Given the above grouping of conductors, each cable was associated with two channels of the IRMS. In the data tables given in Chapters 6 and 7, this arrangement is designated by conductor labels that indicate the cable and IRMS channel. For example, Cable A was generally connected to IRMS channels 1 and 2, so the two Cable A conductor groups were referred to as “conductor A1” and “conductor A2.” Similarly, Cable B was generally connected to IRMS channels 3 and 4, so the two Cable B conductor groups were referred to as “conductor B3” and “conductor B4,” and so on for the rest of the monitored cables. Thus, if a data table entry says “conductors A1 and A2 shorted together” or “conductors B3 and B4 shorted together,” these entries indicate intra-cable, conductor group to conductor group shorts (i.e., between conductor groups within the same cable). If the entry says “conductors A1 and B1 shorted together,” however, this indicates an inter-cable short between conductor groups (i.e., between conductor groups in separate cables). Cable bundles with three, six, and twelve individual cables arranged as shown in Figure 4 were used in CAROLFIRE.

B.2.6 Summary of IRMS Conductor-to-Conductor-Short Data

As indicated above, the CAROLFIRE IRMS data are presented in Volume 1 in the form of extensive shorting sequence tables. These tables do not include summary tables like the ones provided for data from the CAROLFIRE surrogate circuit diagnostic units (SCDUs, discussed later in this document). Thus, for this document, the IRMS data were examined using the process described below, resulting in identification of 20 conductor-to-conductor-short data points in an IRMS summary table (attached).

The IRMS data’s principal purpose was to identify conductor-to-conductor-shorts that could likely cause spurious operations. Other conductor-to-conductor-shorts were of far less interest, and were not compatible with the SCU data discussed later in this document. Therefore, the following process was applied to the IRMS shorting sequence tables:

- Only data from primary events were selected—that is, if either conductor group involved had previously shorted to ground at less than or equal to 1000Ω , then the event was not listed in the summary table because existence of the ground would likely prevent the availability of sufficient power for a spurious operation.
- The time when two conductor groups meeting the above condition shorted together at less than or equal to 1000Ω was taken as the short’s initiation time. If different times were given for the two conductor groups, the earlier of the two was used.
- The time when either conductor group shorted to ground at less than or equal to 1000Ω was taken as the short’s termination time. If different times were given for the two conductor groups, the earlier of the two was used. However, the recorded time when conductor

¹⁰ Since thermal damage to cables begins on the outside and proceeds inward, effects of this difference should be minimized - most shorts to ground would likely occur to the outside raceway, not to any inside grounded conductor.

groups shorted to ground is subject to the uncertainties discussed in Section 2.7, which can be of considerable importance, especially for hot shorts with shorter durations.

- The short's duration time was defined as the difference between the above-described initiation and termination times. However, if the duration was less than one cycle, the short was not included in the summary table because of uncertainty resulting from the data's time resolution (as discussed above).

B.2.7 Termination Time Uncertainties in IRMS-detected Hot Shorts

These uncertainties are explained using the data given on page 55 of Volume 1 as an example; the second and third lines of the table "Results for Test PT-34" are:

1304 seconds – Conductors A1 and A2 short together at 23Ω
1309¹¹-1332 seconds – Conductors A1 and A2 short to ground at 303 and 455Ω

These two entries indicate that a hot short occurred sometime during the previous cycle (i.e., the 185 seconds prior to 1304 seconds), and that it still existed at the indicated time (1304 seconds). Furthermore, the entries indicate that the hot short continued to endure within the then-present cycle (i.e., after 1304 seconds) for between 5 and 28 additional seconds. According to previous explanations by the IRMS, however, the IR values between the conductors and between each of the conductors and the ground were all determined by the same voltage measurements, which were made within less than 2 seconds of the indicated time (1304 seconds). Thus, an uncertainty is indicated, because no relevant data would have been taken during those additional 5 to 28 seconds. However, looking in more detail at IRMS data recording processes reveals that relevant data was in fact taken during that time interval, as follows.

In the Excel file for test PT-34, under the "Plot for Each Conductor" tab, the "Behavior of Cable A, Conductor 1" and the "Behavior of Cable A, Conductor 2" plots show the conductor-to-conductor IR for A1-A2 and for A2-A1 (both at exactly 1303.999999 seconds penlight time) to be exactly 22.75434601Ω . This matches the first line of the "Results" table copied above. The IR values to ground given on the two referenced plots near 1304 seconds also match the IR values given in the second line of the "Results" table copied above; A1's IR is 302.67Ω (at 1309.7 seconds), and A2's is 454.7Ω (at 1332.1 seconds).

In the "key" block of the referenced plot for Cable A, Conductor 1, however, note that its IR to ground is referred to as "A1 – Grnd (min)," and that it appears below the column of entries A1 – A2, A1 – B3, A1 – B4, A1 – C5, and A1 – C6. Each of those five data pairs were taken at successively later times as the IRMS proceeded through its cycle, and each was used to make a separate "A1 – Grnd" IR calculation. Exact values for those successively later times can be obtained under the "A1-A2," "A1-B3," etc. tabs of the Excel data file. If all five times involving "A1" are noted and their average found, it is equal to 1309.7 sec, the "A1- Grnd (min)" time given in the "Results" table. Similarly, if the five successively later times for Cable A, Conductor 2 are obtained under the "A1-A2," "A2-B3," "A2-B4," "A2-C5," and "A2-C6" tabs and their average found, it is equal to 1332.1 sec, the "A2 – Grnd (min)" time given in the "Results" table.

¹¹ Per the following discussion, this time is actually 1309.7 seconds and should have been shown as 1310 seconds in the "Results" table, but was erroneously rounded to 1309 seconds.

These details demonstrate that the short-to-ground data are presented as the minimum IR value from the several calculations of each conductor's IR-to-ground, at the average of the times when those measurements were taken. This is the origin of the noted uncertainty. It's also noted in passing that the Excel data plots given under the "conductor-to-conductor mins" tabs use the same data averages described above for short-to-ground times, presented in a slightly different manner. In the above example, if the ten times (five times involving A1 to ground and five times involving A2 to ground) are averaged, the resulting time (1320.9 seconds) is used under the "A-B mins" and the "A-C mins" tabs for the time of the minimum IR for "A to Ground."

In the above example, taking the uncertainties into account, what the data actually indicate is that sometime during the 185-second cycle preceding 1304 seconds, conductors A1 and A2 shorted to each other and also shorted to ground, but, due to the uncertainties, the data cannot support knowledge of which occurred first, nor of the time between them (if any). Thus, as stated previously, this hot short and others (some discussed below) given in the IRMS data that endured less than one cycle are not included in the attached IRMS data summary table.

B.2.8 Effects of Cycle and Termination Time Uncertainties on Results

The two strongest IRMS indications of inter-cable hot shorts from the Penlight tests cited in Volume 1, Section 6.11, page 77, "Summary of Penlight Test Results in the Bin 2 Context," are called into question by the cycle length issue. That section states that tests PT-45 and PT-60 gave clear indications of inter-cable hot shorts, but the timing in both cases is such that it's not possible to determine the time interval between the conductor-to-conductor shorts and the shorts to ground (which could be zero, making these invalid examples of "hot" shorts capable of causing an SA). Therefore, they were not included in the attached Inter-Cable section of the summary table.

However, the two strongest IRMS indications of inter-cable hot shorts from the intermediate-scale tests (ITs) cited in Volume 1, Section 7.1.16, page 109, "Summary of Intermediate-scale IRMS Results," appear to be valid. On the attached Inter-Cable section of the summary table, the first of those indications is for the IT-1 test for the conductor C5 to conductor B4 hot short with a duration of five minutes (according to data from the Volume 1 table at the bottom of page 83). Excel data indicates that even in the worst case (i.e., assuming the first conductor to short to ground does so one second after its last non-shortened measurement), the hot short endured for at least 144 seconds. Similarly, Excel data for the other IT-1 hot short on the summary table (the C5 to A1 short with duration 3.6 minutes, according to data from the Volume 1 table) show that it endured for at least 65 seconds.

B.2.9 Recommendations for Future IRMS Improvements

Since the above discussions concern uncertainties in the IRMS data principally caused by the IRMS's rather long cycle times, it is worth noting that those uncertainties could be reduced for future IRMS applications without reducing the amount of data provided. The data provided are for IR values between adjacent IRMS-monitored cables, but measurements were made for IR values between all possible pairs of IRMS-monitored cables. For example, with reference to the "Six-Cable Bundle Arrangement" shown in Figure 4, IR values were provided between conductor groups in Cable A and the adjacent Cables B and C, but IR values were also measured (but not reported) between Cable A and non-adjacent Cables D, E, and F. This same degree of overmeasurement existed for the other corner cables D and F, but a lesser degree of overmeasurement existed for the side cables B, C, and E because they each had only one non-

adjacent cable. Re-programming the IRMS to eliminate the less important measurements would significantly shorten its cycle time and improve time resolution of the event sequences.

B.3. Surrogate Circuit Diagnostic Units (SCDUs)

B.3.1 Introduction

CAROLFIRE's second electrical performance-monitoring system utilized SCDUs, which are described in detail in Appendix C of Volume 1. The SCDUs provided an opportunity to assess how various simulated circuits responded to fire-induced cable failures. They could be configured to represent a range of circuits, although, in practice, most of the CAROLFIRE tests used a standard alternating current (ac)-powered motor-operated valve (MOV) control circuit such as those used in both the Nuclear Energy Institute/Electric Power Research Institute (EPRI/NEI) (2001) and Duke Energy Corporation (2006) test programs. Some tests varied the number of energized source conductors and/or the number of grounded conductors present in the tested cable.

B.3.2 Differences Between the IRMS and the SCDU Tests

These differences included:

- most of the SCDU tests were configured with intra-cable shorting in mind, whereas most of the IRMS tests were configured with inter-cable shorting in mind;
- each SCDU contained a specific circuit which was tested for the occurrence of an SA; thus, it was not subject to uncertainty resulting from the IRMS's generic assumption that an IR of 1000 Ω or less represented an SA;
- all 64 channels of SCDU data were recorded every 0.2 seconds (i.e., the SCDU's cycle time was 0.2 seconds), as compared to the IRMS's cycle time of 185 seconds (or less, in a few cases);
- most of the SCDU test cables contained a grounded conductor, whereas none of the IRMS cables contained a grounded conductor or shield;
- each SCDU tested only for the actual occurrence of a hot short or SA due to cable failure; it seldom gave any indication of cable degradation prior to cable failure, whereas the IRMS provided a complete history of IR degradation between all pairs of adjacent conductors prior to cable failure.

B.3.3 Individual SCDU Circuits

SNL constructed four SCDUs for CAROLFIRE (Figure 5). Their permanent wiring was identical, with the exception that SCDU #1's power supply was not grounded (it was grounded in the other three SCDUs). Although the electrical capacity of the Control Power Transformers (CPTs) used on the four SCDUs could be varied, in practice SCDUs #1 and #2 used 150 volt-amp (VA) CPTs, SCDU #3 used a 200 VA CPT, and SCDU #4 used a 100 VA CPT with the exception of four tests (IT-11, -12, -13, and -14) in which SCDU #4 was used without a CPT.

B.3.4 Application Configurations

Each of the four SCDUs could be connected in any of the four configurations discussed below.

B.3.4.1 SCDU-MOV-1

As stated previously, the most frequently used configuration was SCDU-MOV-1 (see Figure 5). A hot short between Circuit Paths 1 or 2 (conductors 1 or 2) and Circuit Paths 4, 5, or 6 (conductors 4, 3, or 7) would cause an SA.

Note that Circuit Path 7 (conductor 5) was a return path to the power supply in all four SCDUs and was also grounded in SCDUs #2, #3, and #4, but not in SCDU #1 (this is one reason for the previous statement that “most of the SCDU test cables contained a grounded conductor”). The effect was that, for all four SCDUs, a hot short to Circuit Path 7 (conductor 5) would cause a fuse blow failure. However, whereas a single hot short to external ground (i.e., to the cable tray or conduit) would cause a fuse blow failure for SCDUs #2, #3, and #4, a single hot short to external ground would not cause a fuse blow failure for SCDU #1. Also, for SCDU #1, a short to ground on Circuit Paths 1 or 2 (conductors 1 or 2) and Circuit Paths 4, 5, or 6 (conductors 4, 3, or 7) would cause an SA, and a short to ground on Circuit Path 1 or 2 (conductor 1 or 2) and Circuit Path 7 (conductor 5) would cause a fuse blow.

B.3.4.2 SCDU-MOV-1a

This configuration resulted from an inadvertent hookup wiring error made on all four SCDUs for test IP-4 only. The effects of this error were minor, and, once discovered, were negated by corrections to the recorded data.

B.3.4.3 SCDU Operation Circuit 1

This configuration was used only in test IT-3, which included SCDU #4, connected to a 3-conductor-plus-drain-wire cable. In this configuration, one of the three insulated conductors was connected to Circuit Path 1, which was energized (i.e., it became the single source conductor). The second insulated conductor was connected to Circuit Path 5, and the third insulated conductor was connected to Circuit Path 6, making two target conductors. The uninsulated drain wire was connected to Circuit Path 7 (grounded on SCDU #4). The other Circuit Paths were not connected to anything for this test (IT-3). This configuration, with a grounded drain wire within the cable, represented typical practice for cables with drain wires or shields.

B.3.4.4 SCDU Inter-Cable Configuration (IC)

Figure 6 shows the most frequently used (six-cable bundle) version of this configuration, which was used for a total of ten cable bundles in tests IT-2, IT-3, IT-4, and IT-5 (IT-2 also tested two twelve-cable bundles, which are discussed later). As shown in Figure 6, for all ten of the six-cable bundle IC tests, Circuit Path 1 was connected to all of the conductors of one 7-conductor cable, and Circuit Path 2 was connected to all of the conductors of another 7-conductor cable, thus creating two source cables. A third 7-conductor cable was used as the target cable and connected as shown: conductors 2 and 5 were connected to Circuit Path 4, conductors 3 and 6 were connected to Circuit Path 5, and conductors 4 and 7 were connected to Circuit Path 6. Conductor 1 (the center conductor) was not connected to anything, becoming an “unconnected spare.” Since no target conductor was connected to Circuit Path 7, there were no conductors in the fire test structure that connected directly to the CPT return path. There were conductors that led from the fire to the return path, but they led through the 1750Ω ballast resistor (from Source 1, the normal undamaged situation), through the 1750Ω passive operation device, or through the K1 or K2 active operation devices, all of which had sufficient resistance to preclude a fuse blow (energizing any of the three operation devices was the definition of an SA event).

This was a significant difference from the other three SCDU configurations (i.e., the two “MOV-1” and the “Operation Circuit 1” configurations), in which Circuit Path 7 (on all four SCDU circuits, both grounded and ungrounded) always served as a return path to the power supply from target conductor 5, as well as an internal ground for SCDUs #2, #3, and #4 (the grounded SCDUs).

The three cables (two source cables and one target cable, as described above) were bundled as shown in the “Six-Cable Bundle Arrangement” part of Figure 4; Cables A and B were the source cables, Cable C was the target, and Cables D, E, and F (between Cables A, B, and C and the cable tray) were not connected to the SCDU and were not grounded, in keeping with their intended function of providing an additional level of isolation between the active cables and the grounded cable tray.

For the above “IC” configurations using grounded SCDUs, hot shorts or spurious operations impacting the target cable could only occur given inter-cable shorting that remained independent of the external ground. Any short between an energized source conductor and the external ground (i.e., the raceway) would have caused a fuse blow. (Recall that there was no direct internal return path from the target conductors to the CPTs, so even for the grounded CPTs there was no internal ground).

For the above “IC” configurations using the ungrounded SCDU #1, as with the grounded SCDUs, there was no direct internal return path to the CPTs, but, unlike the grounded SCDUs, there was also no external return path to the CPTs. Therefore, given fire damage to the cables, a fuse blow failure was not possible, and an SA was inevitable. An SA could result from direct interaction between either of the source cables and any of the three conductors in the target cable, or from multiple interactions with the ground (i.e., when either of the source cables shorted to ground and any of the three target conductors also shorted to ground). In principle, it might be possible to distinguish this latter case because voltage in the target conductor might tend to build slowly and never reach full source potential.

As noted above, IT-2 also included two twelve-cable bundles. One bundle, consisting of twelve thermoset (TS) cables (cross-linked polyethylene/chlorosulfonated polyethylene (XLPE/CSPE), Cable ID #10¹²), was connected to SCDU Circuit #1 (ungrounded). The other bundle, consisting of a mixture of TS and thermoplastic (TP) cables (six XLPE/CSPE TS cables (Cable ID #10 - footnote 7 applies), and six polyethylene/polyvinyl chloride (PE/PVC) TP cables (Cable ID #15)), was connected to SCDU Circuit #2 (grounded). The response of both SCDUs to the various cable interactions was identical to that described above for the ten six-cable bundles. The only differences were the size and extent of the conductors used. The “Twelve-Cable Bundle Arrangement” part of Figure 4, and Figure 6, “SCDU IC Configuration for Six-Cable Bundles,” provide material that was created for six cable bundle purposes, but which can nevertheless be used to illustrate the following text about twelve-cable bundles.

For SCDU Circuit #1 (connected to the all-TS twelve-cable bundle), Circuit Path 1 (source 1) was connected to 21 conductors, consisting of all 7 of the conductors in Cables J, G, and B. Circuit Path 2 (source 2) was connected to 21 conductors, consisting of all 7 of the conductors in Cables K, M, and C. Each of the three target paths (Circuit Paths 4, 5, and 6) was connected to all 7 of the conductors in a separate cable, H, A, or L, respectively. Thus, there were two sources, each consisting of all 21 conductors in three connected cables, and three targets, each consisting of all 7 conductors in a separate cable. Cables D, E, and F (between Cables G, B, C,

¹² In Volume 1’s SCDU results table on page 115, the Cable ID # is incorrectly given as #3.

M, and the cable tray) were not connected to the SCDU and were not grounded, in keeping with their intended function of providing an additional level of isolation between the active cables and the grounded cable tray. The above-described connections are consistent with the Excel datasheet for “Test IT_02 SCDU Data,” under the “Test Conditions” tab, in the “Circuit #1” column and the “Wiring Config:” row.

For SCDU Circuit #2 (connected to the mixed TS and TP twelve-cable bundle), information presented in the Excel datasheet for “Test IT_02 SCDU Data,” under the “Test Conditions” tab, in the “Circuit #2” column and the “Wiring Config:” row, indicates that all six TP cables were connected. However, the information presented for IT-2 in Volume 2, page 110, indicates that Cables B, D, F, H, K, and M were the locations of the six TP cables¹³. Taken together, this means that two of the three “isolation” cables between the active cables and the tray (i.e., D and F) were connected to the SCDU. This would not have been consistent with the intended isolation function for the bottom row of cables (D, E, and F), and the SNL personnel who conducted the test stated that it was not something they would have done. After consulting all available records, the SNL personnel determined the most likely connections: Circuit Path 1 (source 1) was connected to all seven conductors in each of two TS and one TP cables (Cables J, G, and B, respectively); Circuit Path 2 (source 2) was connected to all seven conductors in each of two TP and one TS cables (Cables K, M, and C, respectively); Circuit Path 4 (Passive Target 4) was connected to all seven conductors in TP Cable H; and Circuit Paths 5 and 6 (Active Targets 5 and 6) were each connected to all seven conductors in TS Cables A and L, respectively. Cables D (TP), E (TS), and F (TP) were left unconnected to any Circuit Path (and were not grounded).

B.3.5 Summary of SCDU Conductor-to-Conductor-Short Data

The SCDU data is well organized and sufficiently detailed to enable its use for many purposes. For example, the tables on pages 113 to 126 in Volume 1 proceed in columns from the left, giving the test number, the SCDU circuit number, the circuit configuration, CPT size and whether or not it’s grounded, cable type, number of conductors, cable ID number, bundle size, and an event summary (i.e., narration of the SAs and fuse blows that occurred due to both intra- and inter-cable interactions). These items are discussed in this document, and should be understood to enable the selection of appropriate sets of data that avoid combining the results of vastly different tests. For example, an ungrounded SCDU in the IC configuration is quite different from a grounded SCDU in the MOV-1 configuration, and their data should be interpreted and used in significantly different ways.

In addition, a two-page summary of the intra-cable interactions is presented on pages 131 and 132 in Volume 1 (the nine inter-cable interactions are presented in the detailed tables on pages 113 to 126, but are not repeated in the two-page summary).

The Excel data files on the CDs distributed with CAROLFIRE Volumes 1 and 2 (and on the NRC website) provide detailed data recorded from the voltage and current transducers on Circuit Paths 1 through 8 (shown on Figures 5 and 6—note that Circuit Path 9 was not used, and was not monitored during any CAROLFIRE test). Since there was a voltage and a current transducer on each of the eight Circuit Paths, and four SCDUs were used in each CAROLFIRE IT, a total of 64 data points were collected during the CAROLFIRE ITs using a 64-channel data recorder (SCDUs were not used during the CAROLFIRE Penlight tests).

¹³ Cables A, C, E, G, J, and L were the six TS cables.

All 64 data points were recorded every 0.2 seconds, and have been preserved for archival purposes. During the time intervals in which cable degradation occurred (i.e., immediately before, during, and after SAs and fuse blows), all data is presented in the Excel data files. However, during other times, intervals of 30 seconds to a minute are typically presented. The detailed data at 0.2-second intervals can be of interest in the many places where hot shorts of SA events are reported in the Volume 1 event summary tables, particularly when durations of a second or less are noted.

NRC FORM 335 (12-2010) NRCMD 3.7		U.S. NUCLEAR REGULATORY COMMISSION		1. REPORT NUMBER (Assigned by NRC, Add Vol., Supp., Rev., and Addendum Numbers, if any.) <p style="text-align: center;">NUREG-2128</p>					
BIBLIOGRAPHIC DATA SHEET (See instructions on the reverse)				3. DATE REPORT PUBLISHED					
2. TITLE AND SUBTITLE Electrical Cable Test Results and Analysis During Fire Exposure (ELECTRA-FIRE), A Consolidation of the Three Major Fire-Induced Circuit and Cable Failure Experiments Performed Between 2001 and 2011 Draft for Comment				<table border="1" style="width: 100%; text-align: center;"> <tr> <td style="width: 50%;">MONTH</td> <td style="width: 50%;">YEAR</td> </tr> <tr> <td>June</td> <td>2012</td> </tr> </table>		MONTH	YEAR	June	2012
				MONTH	YEAR				
June	2012								
5. AUTHOR(S) G.Taylor, N.Melly, H.Woods, T.Pennywell (NRC) T.Oliver, C.Lopez (SNL)				4. FIN OR GRANT NUMBER					
				6. TYPE OF REPORT <p style="text-align: center;">Technical</p>					
8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.) Division of Risk Analysis Office of Nuclear Regulatory Research U.S. Nuclear Regulatory Commission Washington, DC 20555-0001				7. PERIOD COVERED (Inclusive Dates) <p style="text-align: center;">July 2011 - January 2012</p>					
				9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above", if contractor, provide NRC Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address.) Division of Risk Analysis Office of Nuclear Regulatory Research U.S. Nuclear Regulatory Commission Washington, DC 20555-0001					
10. SUPPLEMENTARY NOTES									
11. ABSTRACT (200 words or less) Over the past 10 years there have been three major test projects focusing on the functionality of electrical cable under severe fire conditions. The tests were performed by EPRI/NEI and the NRC. During a Phenomena Identification and Ranking Table (PIRT) exercise, an expert panel identified that the three data sets would require a systematic evaluation and presentation to allow for the experts to use the data to make informed judgements. This report provides such an evaluation by assessing the fire-induced electrical cable failure parameter effects using available test data. This report documents the background work that was done to analyze the three data sets and provide the results in graphical form. This report presents the data in a factual and coherent format to allow the PIRT expert panel and other end users to make informed decisions.									
12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.) Fire, fire-induced, circuit failure, electrical cable, spurious operation, spurious actuation, maloperation, hot short, fire protection, confirmatory testing, experimental testing.				13. AVAILABILITY STATEMENT <p style="text-align: center;">unlimited</p>					
				14. SECURITY CLASSIFICATION <i>(This Page)</i> <p style="text-align: center;">unclassified</p>					
				<i>(This Report)</i> <p style="text-align: center;">unclassified</p>					
				15. NUMBER OF PAGES					
16. PRICE									



Federal Recycling Program



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, DC 20555-0001

OFFICIAL BUSINESS

**NUREG-2128
Draft**

**Electrical Cable Test Results and Analysis During Fire
Exposure (ELECTRA-FIRE)**

June 2012